



a division of Englobe



Final Report for:

KNEEHILL COUNTY

HAMLET OF HUXLEY WASTEWATER STUDY TM-01

Prepared by:

Kim Schurtz, B.A., P.Tech.(Eng.)
Environmental Systems Manager

Date: March 18, 2024
Project #: 4290-021-00

MPE a division of Englobe
#320, 6715 – 8 Street NE
Calgary, AB T2E 7H7
403-219-6307

kschurtz@mpe.ca

Proud of Our Past... Building the Future

www.mpe.ca

Kneehill County
1600 – 2 Street NE
Three Hills, AB
T0M 2A0

March 18, 2024
File: N:\4290\021-00\TM01-1.0.R2

Attention: John McKiernan
Manager of Environmental Services

Dear Mr. McKiernan:

Re: Kneehill County – Hamlet of Huxley Wastewater Study TM-01

We are pleased to submit the above-noted final report. We thank you for the opportunity to be of service and to have prepared this report on your behalf. We look forward to assisting you in implementing the recommendations within the report.

If you have any inquiries regarding our report or if clarification is required, please contact the undersigned at 403-219-6307.

Yours truly,

MPE a division of Englobe



Kim Schurtz, B.A., P.Tech.(Eng.)
Project Manager

KS/akk
Enclosure


CORPORATE AUTHORIZATION

This report has been prepared by MPE a division of Englobe under authorization of Kneehill County. The material in this report represents the best judgment of MPE a division of Englobe given the available information. Any use that a third party makes of this report, or reliance on or decisions made based upon it is the responsibility of the third party. MPE a division of Englobe accepts no responsibility for damages, if any, suffered by a third party as a result of decisions made or actions taken based upon this report.

Should any questions arise regarding content of this report, please contact the undersigned.

MPE a division of Englobe

Prepared by:



Kim Schurtz, B.A., P.Tech.(Eng.)

Professional Seal

Corporate Permit

EXECUTIVE SUMMARY

Project Overview

Kneehill County (County) retained MPE a division of Englobe (MPE) to complete an assessment of the Hamlet of Huxley's (Hamlet) low pressure wastewater collection system. The scope of work and assessment consisted of the following core components:

- Collect data and review of existing record drawings, equipment specifications, equipment manuals, WWTP operational data, laboratory test results, etc.
- Evaluate sizing and capacity of low pressure wastewater collection system.
- Participate in public engagement and consultation of the Hamlet of Huxley residents.
- Develop a model of the existing low pressure wastewater collection system to assess the overall capabilities of the system and restriction any potential growth within the Hamlet.
- Develop upgrades options based on MPE's evaluation and modelling of the Hamlet's existing wastewater collection system.
- Identify alternative wastewater collection and treatment options in addition to reviewing upgrade options for the existing wastewater collection system.
- Develop Technical Memorandum 01 (TM-01) identifying all conceptual upgrade options for the Hamlet's wastewater collection system considered.

Conclusions

Based on the assessment study completed for the Hamlet of Huxley, the following is a summary of the conclusions identified:

- A maximum of 10 pumps of 0.5 HP and 15 pumps of 0.375 HP should be pumping sewage into the forcemain at the same time for the system to operate without any issues.
- Ensure there is a check valve or backflow preventor installed in every household to prevent sewage backflow from the low pressure forcemain.
- Addition of manholes in the system for flushing the system would be beneficial; manholes installed complete with flushing connections added upstream of the system located at the east end of the system would be sufficient.

Recommendations

The following is a summary of the recommended improvements for the Hamlet of Huxley low pressure wastewater collection system:

- Standardize pump design for all lots in the Hamlet. This upgrade consists of standardizing all residential sewage pumps in the Hamlet with the same model. The standardized pump model would be 41 Orenco PF100511-20 pumps with 0.631 L/s and 0.5 HP. The cost to replace all 41 pumps would cost approximately **\$351,600** (supply only); assume an additional 25% for installation. Standardized pump design will provide ease in operation and maintenance. Pump quotes and information can be found in **Appendix C**.
- Kneehill County to obtain a third party to inspect the condition of each pump and septic tank. An inspection of the pumps and septic tanks could determine the problems that need to be addressed and provide information on the data for the existing system.
- Install flushing connections in the following locations:
 - East end of 1 Street N,
 - East end of Main Street,
 - East end of 1 Street S,
 - East end of 2 Street S,
 - South and north end of Queens Avenue.
- Each flushing connection would comprise of a manhole complete with a flush connection at the end of the forcemain. The cost of each flushing connection would be approximately **\$14,000**.
- Ensure there is a check valve or backflow preventor installed in every household to prevent sewage backflow from the low pressure forcemain.
- Initiate a flushing regime to remove the blocked sewage inside the forcemain. A flushing mechanism would require adding flushing connections/manholes in the system.
- Upgrading the following section of forcemain to a 75 mm line would improve the flow and ease the system capacity:
 - 50 mm forcemain along Railway Avenue between Main Street and 1 Street N,
 - 50 mm forcemain on 1 Street N between Railway and Queens Avenue.

TABLE OF CONTENTS

LETTER OF TRANSMITTAL

CORPORATE AUTHORIZATION

EXECUTIVE SUMMARY

1.0 INTRODUCTION1

 1.1 Study Background 1

2.0 GENERAL OVERVIEW2

 2.1 Location..... 2

 2.2 General..... 2

3.0 REVIEW OF AVAILABLE INFORMATION3

 3.1 Record Drawings, Reports and Manuals..... 3

 3.2 Missing or Conflicting Data 3

4.0 REGULATORY REQUIREMENTS.....4

 4.1 General..... 4

 4.2 Regulatory Review 4

5.0 SANITARY INFRASTRUCTURE6

 5.1 General..... 6

 5.2 Historical Data Review 6

 5.3 Current and Projected Wastewater Flows..... 6

 5.4 Alberta Environment Standards and Guidelines..... 7

 5.5 Sanitary Infrastructure Assessment..... 8

 5.6 Proposed Upgrades and Improvements 13

6.0 COST ESTIMATES.....15

 6.1 General..... 15

 6.2 Capital Cost 15

7.0 CONCLUSIONS AND RECOMMENDATIONS16

 7.1 Conclusions 16

 7.2 Recommendations 16

APPENDICES

- Appendix A – Code of Practice
- Appendix B – Modelling Data
- Appendix C – Submersible Pumps
- Appendix D – Cost Estimates

1.0 INTRODUCTION

1.1 Study Background

Kneehill County (County) retained MPE a division of Englobe (MPE) to complete an assessment of the Hamlet of Huxley's (Hamlet) low pressure wastewater collection system. The scope of work and assessment consisted of the following core components:

- Collect data and review of existing record drawings, equipment specifications, equipment manuals, WWTP operational data, laboratory test results, etc.
- Evaluate sizing and capacity of low pressure wastewater collection system.
- Participate in public engagement and consultation of the Hamlet of Huxley residents.
- Develop a model of the existing low pressure wastewater collection system to assess the overall capabilities of the system and restriction any potential growth within the Hamlet.
- Develop upgrades options based on MPE's evaluation and modelling of the Hamlet's existing wastewater collection system.
- Identify alternative wastewater collection and treatment options in addition to reviewing upgrade options for the existing wastewater collection system.
- Develop Technical Memorandum 01 (TM-01) identifying all conceptual upgrade options for the Hamlet's wastewater collection system considered.

This document provides an analysis of the Hamlet of Huxley's low pressure wastewater collection system as well as upgrade options and costs.

2.0 GENERAL OVERVIEW

2.1 Location

The Hamlet of Huxley is located in Kneehill County and is located 550 m east of Highway 21, 11 km north of Trochu and 160 km northeast of Calgary. **Figure 2.1** illustrates the location plan of the Hamlet of Huxley.




Figure 2.1: Hamlet of Huxley

2.2 General

The Hamlet's wastewater collection system consists of a low pressure forcemain ranging from 50 mm and 75 mm diameter high-density polyethylene (HDPE) pipe which conveys wastewater to a wastewater stabilization pond to the west of the Hamlet. Each service lot has a septic tank and a submersible effluent pump installed in the septic tank which pumps wastewater into the low pressure wastewater collection system.

3.0 REVIEW OF AVAILABLE INFORMATION

3.1 Record Drawings, Reports and Manuals

The following data, plans, reports, and manuals were compiled and reviewed for this report:

- Opus Stewart Weir Ltd. 2016. *Huxley Infrastructure Assessment* (Report Excerpt).
- WSP. Date Unknown. *Huxley Lagoon Upgrades* (Report Excerpt).
- EXH Engineering Services Ltd. 2016. *Sanitary Sewer System and Lagoon* – Figure 5.

3.2 Missing or Conflicting Data

MPE noted the following missing or conflicting data:

- No documentation, record drawings or specifications were available for the original construction of the low pressure wastewater collection system.
- Operation and maintenance information was not available from the original construction.
- Historical lab testing and flow data has not been made available for any time period.
- Capacity and design information for piping, septic tank submersible pumps and related equipment was not available.

4.0 REGULATORY REQUIREMENTS

4.1 General

The performance requirements of the existing low pressure sewage collection system are proposed based on regulatory requirements of the provincial government. The following section summarizes the review of regulatory requirements.

4.2 Regulatory Review

4.2.1 Standards and Guidelines

The following standards and guidelines will be used to review the Hamlet's low pressure wastewater collection system as a minimum:

- *Standards and Guidelines for Municipal Waterworks, Wastewater, and Storm Drainage*, Alberta Environment and Parks, 2013.
- *Wastewater Systems Standards for Performance and Design*, Alberta Environment and Parks, 2013.
- *Wastewater Systems Guidelines for Design, Operating and Monitoring*, Alberta Environment and Parks, 2013.

4.2.2 Environmental Protection and Enhancement Act Approval

The Hamlets wastewater treatment system operates under a Code of Practice registration number 793-02-00 from Alberta Environmental and Protected Areas (APEA, formerly known as Alberta Environment and Parks) for Wastewater Systems Using a Wastewater Lagoon through the EPEA. The code of practice allows for operation of a low pressure wastewater collection system with treatment and discharge from the Hamlet's wastewater lagoon. **Table 4.2.2** provides a summary of the facility approval and registration.

Table 4.2.2: Facility Code of Practice Summary

Municipality	Approval No.	Effective Date
Kneehill County	793-01-00 (95-MUN-319)	June 15, 2004

All EPEA approvals and Codes of Practice contain conditions and requirements pertaining to:

- Construction.
- Management and operation.
- System classification and operator requirements.
- Sampling and monitoring.
- Monitoring and reporting.
- Record keeping.
- Effluent quality limits.

A copy of the AEPA Code of Practice registration number 793-02-00 can be found in **Appendix A**.

5.0 SANITARY INFRASTRUCTURE

5.1 General

The sanitary sewer infrastructure in the Hamlet of Huxley consists of a low pressure forcemain which transfers the wastewater to a wastewater stabilization pond located approximately 400 m northwest from the residents. The Hamlet has a septic tank effluent pumping (STEP) system for wastewater collection where each service lot has a submersible pump installed in the septic tank which pumps wastewater into the low pressure wastewater collection system. The collection system was constructed in 1989 and consists of approximately 2.1 km of forcemain ranging in size from 50 mm diameter pipe to 75 mm diameter pipe. The network of pipes consists of HDPE pipe. The collection system has no manholes and does not have any flushing mechanisms installed.

5.2 Historical Data Review

5.2.1 Data Collection

The Hamlet has not historically collected data on wastewater flows entering their wastewater collection and treatment system; therefore, wastewater flows have been determined based on a ratio of water usage per capita.

5.2.2 Historical Wastewater Flows

The Hamlet does not record data on the wastewater flows entering the wastewater system. According to the *Huxley Infrastructure Assessment* report by Opus Stewart Weir Ltd., with an assumption of 2% annual growth rate, there would be 126 persons in Huxley by 2035. The wastewater flows have been estimated to be at a rate of 233 lpcd for the estimated population. For reference purposes, the 2021 population for the Hamlet is 75.

5.3 Current and Projected Wastewater Flows

Daily wastewater flows were determined using litre per capita day of 233 lpcd. Based on a current population of 75 and a projected 2035 population of 126, the current and projected wastewater flow rates are 17.5 m³/day and 29.4 m³/day, respectively.

5.3.1 Wastewater Production

Future wastewater flows were calculated based on population projections noted previously. To account for the diurnal fluctuations in wastewater flows, maximum daily flows are calculated based on the peaking factor derived from the Harmon equation:

$$\text{Harmon's Peaking Factor} = 1 + 14 / (4 + P^{1/2})$$

Where: P = design contributing population in thousands

Assuming a population of 126 in 2035, the Harmon's Peaking Factor will be equal to 4.21, therefore the current and projected peak flows are 73.7 m³/day and 123.7 m³/day, respectively. Due to the collection system being comprised of a low pressure STEP system, there will be no surface inflow and infiltration into the sanitary collection system from wet weather conditions. Groundwater infiltration will be minimal as the system is comprised predominantly of HDPE pipe. Furthermore, it operates under positive pressure conditions when a resident's effluent pump is active. Therefore, inflow and infiltration has not been included in the current or projected flow and capacity calculations.

5.4 Alberta Environment Standards and Guidelines

As noted in **Section 4.2.1**, the Hamlet's low pressure wastewater collection system is governed under the *Standards and Guidelines for Municipal Waterworks, Wastewater, and Storm Drainage*, Alberta Environment and Parks, 2013. The following information summarizes the standards and guidelines as they relate to the components of the low pressure wastewater collection system:

- Consideration should be given to the location of forcemains and their accessories to allow for operation and accessibility.
- Forcemains should be installed deep enough to avoid freezing and protection from heavy external loads.
- Piping should be sized to meet peak flows with velocities of 0.6 m/s to 3.0 m/s.
- A sufficient number of air release valves should be installed at appropriate points in the forcemain to prevent hydraulic problems.

5.5 Sanitary Infrastructure Assessment

5.5.1 Sanitary Collection System

5.5.1.1 Existing Collection System


The Hamlet of Huxley uses a STEP system for its wastewater collection system. Wastewater is pumped by individual pumps at each household through low pressure forcemains to the existing lagoon system located 400 m northwest of the community.

The sanitary collection network consists of 2.1 km of forcemain sewer piping ranging from 50 mm to 75 mm diameter pipe. The network of forcemains consists of HDPE. Physical data for the sanitary collection system was obtained from record drawings. In general, the collection system has adequate capacity to carry current Average Dry Weather Flow (ADWF) and Peak Wet Weather Flow (PWWF) only when a maximum of 10 pumps are running at the same time. Additional analysis for the pump modelling can be found in the following sections. A summary of the collection system is presented in **Table 5.5.1.1**.

Table 5.5.1.1: Sanitary Main Summary

Year	Material	Diameter (mm)	Length (m)
1989	HDPE	50	1,720
1989	HDPE	75	400

The existing wastewater collection system is illustrated in **Figure 5.1**.




NW17 34-23-4

300m DEVELOPMENT
SETBACK FROM
WASTEWATER LAGOON

CANADIAN NATIONAL RAILWAY

HUXLEY

NE17 34-



NW17 34-23-4

NE17 34

M:\2006\1006099-Kneehill Water & Wastewater Study\ORA\WSS\Huxley.dwg

EXH Engineering Services Ltd.

project
**KNEEHILL COUNTY
WATER AND WASTEWATER SYSTEMS STUDY
HAMLET OF HUXLEY
SANITARY SEWER SYSTEM AND LAGOON**

designed	scale	date
drawn	N.T.S	AUG 2006
checked	project no.	contract no.
approved	1006099	
	drawing no.	rev.

FIGURE 6

5.5.1.2 Wastewater Collection System Modeling

After determining the peak design flow, Bentley SewerCAD modelling software was selected for hydraulic analysis. A total of 41 services were modelled. The service lots were identified based on a combination of the Huxley map from Google Earth Pro and the existing sanitary collection system (**Figure 5.1**). Each lot has a wet well and a submersible pump. The pump and wet well for each lot are connected by a 500 mm pressure pipe in the model to simulate that the pump is submerged in the wet well and to ensure there are negligible friction losses during computation. Individual lots, including pumps, tanks, and services, were not explicitly modelled. Each lot has been modelled to attach to a separate junction/node in the sewer system. The design flows, along with a standard 0.631 L/s (10 gpm) pump for each lot were used, assuming Orenco STEP systems would be utilized for on-lot servicing. The County provided GIS data of the elevations and the junctions were updated with the elevations based on interpolated values. A copy of the GIS data and modelling results can be found in **Appendix B**.

Five different design options were considered in designing the low pressure system:

- 5 connections serviced.
- 10 connections serviced.
- 15 connections serviced.
- 20 connections serviced.
- 25 connections serviced.

The various scenarios mentioned above were created separately and the results of each scenario can be found in **Appendix B**. A specific number of pumps were switched on for each scenario and computed for results. The pumps that were switched on for the scenarios were chosen at random over the modelled region. Two different pumps were used to run the scenarios, one with a standard 0.5 HP pump and another with a smaller 0.375 HP pump. Each scenario was monitored based on an important junction (J-3) and pressure pipe (P-3) located at the northwest corner of the Hamlet. This junction and pipe were crucial, since all the sewage that is collected from the Hamlet converges at this junction and starts to flow towards the lagoon. Modelled data for each scenario at junction (J-3) and pipe (P-3) are mentioned in **Table 5.5.1.2a** and **Table 5.5.1.2b**.

In scenario 1, five (5) pumps with 0.5 HP were modelled to be running at the same time to pump the sewage into the system. The system performed ideally at this situation with a velocity of 2.53 m/s and a pressure of 21 psi at J-3 and P-3, respectively. The rest of the system works well with a maximum pressure of 31 psi. In scenario 2, 10 pumps with 0.5 HP were switched on to run simultaneously. The model begins to reach its capacity with P-3 having a velocity of 3.64 m/s and J-3 with a moderate pressure of 50 psi. The maximum pressure in the model for 10 pumps switched on is 71 psi. Based on these results, a maximum of 10 pumps should pump sewage into the forcemain for the system to operate without any issues. As the number of active pumps increases, the velocity, flow, and pressure gradually increase in the system. When 25 pumps are running, velocity at P-3 reaches 4.4 m/s and the maximum pressure in the system peaks at 101 psi.

Table 5.5.1.2a: Flow, Pressure and Velocity at Crucial Junction - 0.5 HP Pump

Scenario	Velocity (m/s) Pipe P-3	Flow (m/s) Pipe P-3	Pressure (m/s) Junction P-3
5 pumps on	2.53	4.71	21
10 pumps on	3.64	6.78	50
15 pumps on	4.13	7.69	66
20 pumps on	4.27	7.95	71
25 pumps on	4.4	8.19	75

Since only a maximum of 10 pumps with 0.5 HP were recommended to pump sewage into the system, a smaller pump with 0.375 HP could permit an increase the number of active pumps in the system. The model was then updated with a smaller pump. The results summarized in **Table 5.5.1.2b** indicate that the system reaches its capacity when 15 pumps are running simultaneously with P-3 having a velocity of 3.57 m/s and J-3 with a pressure of 48 psi. Running 20 or 25 pumps further increases the velocity and pressure, which is not recommended. An additional five pumps can pump sewage into the system when a smaller pump is utilized. However, with a smaller pump the total head (m) decreases as the flow has to be constant to be able to pump sewage and empty the septic tank. The 0.375 HP pump has lesser head compared to a 0.5 HP pump. If the pump cannot overcome the required head elevation (m) then the sewage will not be pumped into the forcemain leading to overflow in the septic tanks.

Table 5.5.1.2b: Flow, Pressure and Velocity at Crucial Junction - 0.375 HP Pump

Scenario	Velocity (m/s) Pipe P-3	Flow (m/s) Pipe P-3	Pressure (m/s) Junction P-3
5 pumps on	2.41	4.48	19
10 pumps on	3.19	5.95	38
15 pumps on	3.57	6.66	48
20 pumps on	3.7	6.89	52
25 pumps on	3.83	7.13	56

In conclusion, the modelled sewer system operates within capacity when five 0.5 HP pumps are running, and the system reaches its capacity when 10 0.5 HP pumps are simultaneously pumping into the system. A smaller 0.375 HP pump can operate 15 pumps simultaneously but with a lower head elevation. As the number of active pumps increases, the velocity, flow, and pressure gradually increase in the system. According to standards and guidelines set by AEP, a small diameter low pressure or vacuum sewer collection system should provide hydraulic calculations and/or supporting information to confirm the ability of the system. The ability of the system to handle a maximum of 10 pumps of 0.5 HP and 15 pumps of 0.375 HP operating at the same time was determined through this model; however, there are more pumps in this system. Increasing the size of the forcemain will possibly increase the number of pumps that can pump sewage into the system at the same time; a larger forcemain can also handle the flows in the case of a torrential rainfall.

5.5.1.3 Collection System Analysis

The average typical design life expectancy for HDPE pipe is 75 years. The collection system was installed entirely in 1989 and is only 35 years old, therefore is projected to serve at an adequate level of service for at least another 40 years.

Piping should be sized to meet peak flows with velocities of 0.6 m/s to 3.0 m/s, therefore the forcemain is adequately sized for projected peak flows only when less than 10 pumps are pumping into the forcemain. To meet the required peak flows without any limit on the number of active pumps, the forcemain either needs an upgradation in the pipe size or a lift station could be installed.

As shown in the modelling, the flow restrictions occur upstream of junction (J-3) and pipe (P-3). In particular, the 50 mm forcemain along Railway Avenue between Main and 1 Street N and the 50 mm

forcemain on 1 Street N between Railway and Queens Avenue have high flows and velocities. Upgrading the following section of forcemain to a 75 mm line would improve the flow and ease the system capacity:

- 50 mm forcemain along Railway Avenue between Main and 1 Street N.
- 50 mm forcemain on 1 Street N between Railway and Queens Avenue.

Alternatively, installing a lift station/catch basin at the west end of the Hamlet was considered and the following observations were made:

- Installing a lift station at the west end of the Hamlet (where the various lines converge) may help to relieve some of the built-up line pressure but may not solve the problem.
- The main issue is the numbers of 50 mm forcemain lines upstream of the proposed lift station. It will be easy enough for the lift station to pump down the 75 mm forcemain to the lagoon, but it is the upstream 50 mm forcemain that will continue to restrict the flows.
- As shown in the modelling, the flow restrictions occur upstream. In particular the 50 mm forcemain along Railway Ave between Main and 1 Street N and the 50 mm forcemain on 1 Street N between Railway and Queens Avenue have high flows and velocities.
- It would be more cost effective to upsize the mentioned sections of forcemain to increase flow and system capacity rather than installing a lift station.
- In all modelling results, it was these two sections of forcemain that had the most flow and pressure restrictions.

Installing a lift station would not necessarily address the flow restriction issues in the Hamlet; however, upsizing the two noted sections of forcemain would help relieve the flow restriction and increase overall system capacity.

5.6 Proposed Upgrades and Improvements

Based on MPE's assessment of the Hamlet's low pressure forcemain, we have developed several proposed upgrades and improvements. These proposed upgrades and improvements are summarized as follows:

- Standardize pump design for all lots in the Hamlet. This upgrade consists of standardizing all residential sewage pumps in the Hamlet with the same model. The standardized pump model would be 41 Orenco PF100511-20 pumps with 0.631 L/s and 0.5 HP. The cost to replace all 41 pumps would cost approximately **\$351,600** (supply only); assume an additional 25% for

installation. Standardized pump design will provide ease in operation and maintenance. Pump quotes and information can be found in **Appendix C**.

- Kneehill County to obtain a third party to inspect the condition of each pump and septic tank. An inspection of the pumps and septic tanks could determine the problems that need to be addressed and provide information on the data for the existing system.
- Install flushing connections in the following locations:
 - East end of 1 Street N,
 - East end of Main Street,
 - East end of 1 Street S,
 - East end of 2 Street S,
 - South and north end of Queens Avenue.
- Each flushing connection would comprise of a manhole complete with a flush connection at the end of the forcemain. The cost of each flushing connection would be approximately **\$14,000**.
- Ensure there is a check valve or backflow preventor installed in every household to prevent sewage backflow from the low pressure forcemain,
- Initiate a flushing regime to remove the blocked sewage inside the forcemain. A flushing mechanism would require adding flushing connections/manholes in the system.
- For cost comparison, details on the replacement of the existing low pressure system with a new gravity sewer system can be found in **Section 6.0**.
- Upgrading the following section of forcemain to a 75 mm line would improve the flow and ease the system capacity:
 - 50 mm forcemain along Railway Avenue between Main Street and 1 Street N,
 - 50 mm forcemain on 1 Street N between Railway and Queens Avenue.

6.0 COST ESTIMATES

6.1 General

Order-of-magnitude estimates for the costs for replacing the existing low pressure wastewater collection system with a gravity collection system were prepared utilizing a Class 4 cost estimate. A Class 4 cost estimate (-30% to + 40%) is a feasibility level cost estimate that was developed utilizing the following cost assumptions:

- Includes total costs for all Immediate, Short-term and Mid-term priority level projects.
- Includes 40% contingency.
- Includes 15% engineering.
- Includes 10% for contractor mobilization/demobilization/bonding/insurance/profit.

6.2 Capital Cost

Table 6.1 presents the capital cost for upgrading the existing low pressure wastewater collection system with a 200 mm diameter piping gravity collection system. A breakdown of each cost estimate can be found in **Appendix D**.

Table 6.1: Cost Estimate

Option No.	Project Description	Cost Estimate
1	Gravity Sewer Collection System	\$3,790,000

7.0 CONCLUSIONS AND RECOMMENDATIONS

7.1 Conclusions

Based on the assessment study completed for the Hamlet of Huxley, the following is a summary of the conclusions identified:

- A maximum of 10 pumps of 0.5 HP and 15 pumps of 0.375 HP should be pumping sewage into the forcemain at the same time for the system to operate without any issues.
- Ensure there is a check valve or backflow preventor installed in every household to prevent sewage backflow from the low pressure forcemain.
- Addition of manholes in the system for flushing the system would be beneficial; manholes installed complete with flushing connections added upstream of the system located at the east end of the system would be sufficient.

7.2 Recommendations

The following is a summary of the recommended improvements for the Hamlet of Huxley low pressure wastewater collection system:

- Standardize pump design for all lots in the Hamlet. This upgrade consists of standardizing all residential sewage pumps in the Hamlet with the same model. The standardized pump model would be 41 Orenco PF100511-20 pumps with 0.631 L/s and 0.5 HP. The cost to replace all 41 pumps would cost approximately **\$351,600** (supply only); assume an additional 25% for installation. Standardized pump design will provide ease in operation and maintenance. Pump quotes and information can be found in *Appendix C*.
- Kneehill County to obtain a third party to inspect the condition of each pump and septic tank. An inspection of the pumps and septic tanks could determine the problems that need to be addressed and provide information on the data for the existing system.
- Install flushing connections in the following locations:
 - East end of 1 Street N,
 - East end of Main Street,
 - East end of 1 Street S,
 - East end of 2 Street S,
 - South and north end of Queens Avenue.

- Each flushing connection would comprise of a manhole complete with a flush connection at the end of the forcemain. The cost of each flushing connection would be approximately **\$14,000**.
- Ensure there is a check valve or backflow preventor installed in every household to prevent sewage backflow from the low pressure forcemain.
- Initiate a flushing regime to remove the blocked sewage inside the forcemain. A flushing mechanism would require adding flushing connections/manholes in the system.
- Upgrading the following section of forcemain to a 75 mm line would improve the flow and ease the system capacity:
 - 50 mm forcemain along Railway Avenue between Main Street and 1 Street N,
 - 50 mm forcemain on 1 Street N between Railway and Queens Avenue.

APPENDIX A

Code of Practice



Regional Services
Southern Region

Room 203, Deerfoot Square
2938 – 11 Street NE
Calgary, Alberta
Canada T2E 7L7

Telephone: (403) 297-7602
Fax: (403) 297-5944

June 8, 2004

File No. 003-793

Attn. Mr. Gene Kiviaho
Kneehill County
Box 400
Three Hills, AB
T0M 2A0

Dear Mr. Kiviaho,

**RE: Registration No. 793-02-00
Huxley Wastewater System, Application No. 003-793
Notice – Code of Practice for Wastewater Systems Using a Wastewater Lagoon**

The Huxley wastewater system operated by the Kneehill County is operating under a registration under the *Environmental Protection and Enhancement Act*, and has been required to follow the requirements of the latest approval issued for the system, 793-01-00 (95-MUN-319), as amended, until this notice comes into effect.

In accordance with section 3.2(2) of the *Wastewater and Storm Drainage Regulation*, the Director is providing notice that the Code of Practice for Wastewater Systems Using a Wastewater Lagoon will now be applied to the operation of the Huxley wastewater system.

Pursuant to section 3.2(3) of the *Wastewater and Storm Drainage Regulation*, all of the Code of Practice applies on June 15, 2004.

If you have any questions regarding this Notice, please contact Brock Rush at (403) 297-7884.

Sincerely,


May Mah-Paulson, M.Sc., P.Eng.
District Approvals Manager
Designated Director under the Act

cc: Regulatory Approvals Centre
Pete McRae, Utilities Officer, Kneehill County

APPENDIX B


Modelling Data

Huxley Topography



Legend

- | | | | |
|--|-----------------------------|--|-------------------------|
| | Provincial Paved Primary | | Perennial |
| | Provincial Paved Secondary | | non-Perennial |
| | Provincial Gravel Secondary | | Contours 10m |
| | Gravel Road | | Hydrology |
| | Paved Road | | Digital Elevation Model |
| | County Unimproved | | 950m |
| | Driveway | | 832m |




Kneehill County makes no representations or warranties regarding the information contained in this document including, without limitation, whether said information is accurate or complete. Persons using this document do so solely at their own risk, and Kneehill County shall have no liability to such persons for any loss or damage whatsoever. This document shall not be copied or distributed to any person without the express written consent of Kneehill County. ©2023 Kneehill County. All rights reserved.

AltaLIS LiDAR15 DEM

The AltaLIS LiDAR15 DEM is a high accuracy and high resolution DEM that has been collected by LiDAR technology and processed into 15 meter post spacing, XYZ ASCII coordinates.


DEM collected with LiDAR (Light Detection and Ranging) technology offers a very high vertical accuracy, which enhances the quality of relief, hydrological features, sub-catchment boundaries (basins and watersheds) and drainage networks.

Bare Earth LiDAR DEM includes the returns within the point cloud from the ground, and returns from vegetation and man-made structures have been removed. Laser beams from an aircraft platform scan the ground perpendicular to the line of flight. Laser returns, or reflections from the ground and foliage are processed to determine the ground elevations. As LiDAR penetrates tree cover, it provides the most accurate ground definition possible.




LiDAR15 DEM features **30cm** vertical, **50cm** horizontal accuracy, and is available in two formats: **ESRI Arc Grid ASCII** and **LiDAR15 ASCII**. The AltaLIS DEM product has an accuracy of **5m** and consists of grid points, break lines, and spot heights that have been compiled using 1:60 000 aerial photography.

Compare the detail:



AltaLIS DEM



LiDAR15 DEM

LiDAR15 DEM METADATA

15 meter post spacing, Bare Earth

Ellipsoid: Nad83

Projection: UTM (6TM)

Vertical Datum: CGVD28 (HT2)

Accuracy: 30cm vertical (Z) & 50cm horizontal (X/Y)

ESRI ARC GRID ASCII format:

ARC GRID ASCII refers to a specific ESRI interchange format developed for ARC Map raster data in ASCII format. The format consists of a header that specifies the geographic domain and resolution, followed by the actual grid cell values.

Example:

```
ncols          1194
nrows          981
xllcorner      654792.500
yllcorner      5735492.500
cellsize       15
nodata_value   -9999
1193.06 1193.836 1194.682 1193.477 1192.764 1192.479 1192.249 1190.09 1190.109 1190.564
1190.654
```

Records 1-6 Geographic Header: Coordinates may be in decimal or integer format.

ncols: refers to the number of columns in the grid

nrows: refers to the number of rows in the grid

xllcorner: refers to the western edge of the grid

yllcorner: refers to the southern edge of the grid

cellsize: refers to the resolution of the grid

nodata value: refers to the value that represents missing data. This is optional and your parser should not assume it will be present. Note: The ESRI default is -9999.

Record 7-End of File: Data values of the individual cells that represent the elevation of an area.

$val(nox, noy) (f)$ = individual grid values, column varying fastest in integer format. Grid values are stored as floating point values.

xllcorner and *yllcorner* are given as the lower left edges of the grid, NOT the centers of the edge cells.

LiDAR15 ASCII format:


LiDAR15 ASCII DEM refers to a custom 15 meter DEM in a straight ASCII file developed in a generic format. The ASCII file displays coordinates in an XYZ space delimited format, and does not have any header information.

Example:


```
654800 5750200 1193.060
654800 5750185 1193.733
654800 5750170 1194.460
654800 5750155 1194.991
654800 5750140 1195.748
654800 5750125 1196.456
654800 5750110 1196.105
```

Records: The records are listed in an XYZ space delimited sequence. X and Y coordinates are listed as integers, and the Z coordinates are listed as decimal values.

Scenario: Base



Scenario: Base




Scenario: Base




23-4

Scenario: Base



Scenario: Base



Scenario: Base


CANADIAN NATIC




Scenario: Base



Scenario: Base




Scenario: Base




NW17 34-23-4


Scenario: Base




Scenario: Base




Scenario: Base




Scenario: Base




Scenario: Base



Scenario: Base



Scenario: Base





Scenario: 5 Pumps On







Scenario: 5 Pumps On

Color Coding Legend
Pump: Status (Initial)

 = On
 = Off

Color Coding Legend
Pressure Pipe: Velocity (m/s)

 <= 0.01
 <= 1.50
 <= 3.00
 Other

NW17 34-23-4



Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On)

Executive Summary

Scenario	
Label	5 Pumps On
Computation Results	
Subnetwork Results	Number of Gravity Subnetworks: 1 Number of Pressure Subnetworks: 1 >>>> Info: Pressure subnetwork flowing to: MH-1 >>>> Info: Pressure analysis iterations: 11 >>>> Info: Convergence was achieved. >>>> Info: Gravity subnetwork draining to: O-8 >>>> Info: Convergence was achieved.

Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On) Calculation Options

<General>			
Label	Base Calculation Options	Calculation Type	Analysis
Time Analysis Type	Steady State		
Gravity Hydraulics			
Maximum Network Traversals	5	Governing Upstream Pipe Selection Method	Pipe with Maximum QV
Flow Convergence Test	0.001	Structure Loss Mode	Hydraulic Grade
Tractive Stress (Global Minimum)	0.000 Pascals	Report Hydrologic Time Step?	True
Flow Profile Method	Backwater Analysis	Save Detailed Headloss Data?	False
Number of Flow Profile Steps	5	Gravity Friction Method	Manning's Water at 20C (68F)
Hydraulic Grade Convergence Test	0.00 m	Liquid Label	
Average Velocity Method	Actual Uniform Flow Velocity	Use Explicit Depth and Slope Equations?	False
Minimum Structure Headloss	0.00 m		
Pressure			
Peak Flow Ratio	75.0 %	Pattern Setup	<None>
Extreme Flow Setup	<None>	Steady State Hydrograph Equivalent	Peak
Pressure Hydraulics			
Use Controls During Steady State?	True	Use Linear Interpolation For Multipoint Pumps?	False
Wet Well Convergence Increment	0.2 m	Use Controls During Steady State?	True
Use Pumped Flows?	True	Liquid Specific Gravity	0.998
Pressure Subnetwork Accuracy	0.001	Pressure Subnetwork Minimum Possible Pressure	-14 psi
Pressure Subnetwork Trials	40	Pressure Friction Method	Hazen-Williams
SWMM Hydrology			
Default Infiltration Method	Horton	SWMM Hydrologic Increment	0.250 hours
Headloss (AASHTO)			
Expansion, Ke	0.350	Shaping Adjustment, Cs	0.500
Contraction, Kc	0.250	Non-Piped Flow Adjustment, Cn	1.300

Bend Angle vs. Bend Loss Curve

Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On)

Bend Angle vs. Bend Loss Curve

Bend Angle (degrees)	Bend Loss Coefficient, Kb	
0.00	0.000	0.000
15.00	0.190	0.190
30.00	0.350	0.350
45.00	0.470	0.470
60.00	0.560	0.560
75.00	0.640	0.640
90.00	0.700	0.700

HEC-22 Energy Losses

Consider Non-Piped Plunging Flow?	True
-----------------------------------	------

HEC-22 Energy Losses (Second Edition)

Elevations Considered Equal Within	0.15 m	Half Bench Submerged Factor	0.950
Flat Unsubmerged Factor	1.000	Full Bench Unsubmerged Factor	0.070
Flat Submerged Factor	1.000	Full Bench Submerged Factor	0.750
Depressed Unsubmerged Factor	1.000	Improved Bench Unsubmerged Factor	0.035
Depressed Submerged Factor	1.000	Improved Bench Submerged Factor	0.375
Half Bench Unsubmerged Factor	0.150		

HEC-22 Energy Losses (Third Edition)

Flat Submerged Coefficient	-0.050	Half Bench Unsubmerged Coefficient	-0.850
Flat Unsubmerged Coefficient	-0.050	Full Bench Submerged Coefficient	-0.250
Depressed Submerged Coefficient	0.000	Full Bench Unsubmerged Coefficient	-0.930
Depressed Unsubmerged Coefficient	0.000	Improved Submerged Coefficient	-0.600
Half Bench Submerged Coefficient	-0.050	Improved Unsubmerged Coefficient	-0.980

Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On)
Calculation Summary (498: 5 Pumps On)

Time (hours)	Balanced?	Trials	Relative Flow Change
All Time Steps (0)	True	11	0.0000753
0.00	True	11	0.0000753

Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On)

Pipe Report

Subnetwork Summary	
Subnetwork	Gravity Subnetwork

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-3	0.000	4.71	2.53	(N/A)
P-4	0.000	2.55	1.37	(N/A)
P-18	0.000	4.71	1.16	(N/A)
P-139	0.000	4.71	1.16	(N/A)
P-17	0.000	4.71	1.16	(N/A)
P-2	0.000	2.16	1.16	(N/A)
P-122	0.000	2.16	1.16	(N/A)
P-121	0.000	2.16	1.16	(N/A)
P-120	0.000	2.16	1.16	(N/A)
P-119	0.000	2.16	1.16	(N/A)
P-118	0.000	2.16	1.16	(N/A)
P-127	0.000	1.29	0.69	(N/A)
P-126	0.000	1.29	0.69	(N/A)
P-125	0.000	1.29	0.69	(N/A)
P-124	0.000	1.29	0.69	(N/A)
P-123	0.000	1.29	0.69	(N/A)
P-10	0.000	1.26	0.68	(N/A)
P-88	0.000	1.22	0.65	(N/A)
P-79	0.000	0.95	0.51	(N/A)
P-113	0.000	0.95	0.51	(N/A)
P-112	0.000	0.95	0.51	(N/A)
P-111	0.000	0.95	0.51	(N/A)
P-63	0.000	0.94	0.51	(N/A)
P-69	0.000	0.94	0.50	(N/A)
P-61	0.000	0.94	0.50	(N/A)
P-1	0.000	0.94	0.50	(N/A)
P-84	0.000	0.93	0.50	(N/A)
P-89	0.000	0.93	0.50	(N/A)
P-9	0.000	0.67	0.36	(N/A)
P-135	0.000	0.67	0.36	(N/A)
P-134	0.000	0.67	0.36	(N/A)
P-133	0.000	0.67	0.36	(N/A)
P-132	0.000	0.67	0.36	(N/A)
P-131	0.000	0.67	0.36	(N/A)
P-130	0.000	0.67	0.36	(N/A)
P-8	0.000	0.62	0.33	(N/A)
P-104	0.000	0.62	0.33	(N/A)
P-13	0.000	0.59	0.32	(N/A)
P-136	0.000	0.59	0.32	(N/A)
P-137	0.000	0.59	0.32	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On)
Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-11	0.000	0.59	0.32	(N/A)
P-138	0.000	0.59	0.32	(N/A)
P-6	0.000	0.35	0.19	(N/A)
P-129	0.000	0.35	0.19	(N/A)
P-128	0.000	0.35	0.19	(N/A)
P-12	0.000	0.34	0.18	(N/A)
P-5	0.000	0.27	0.15	(N/A)
P-49	0.000	0.95	0.00	(N/A)
P-33	0.000	0.94	0.00	(N/A)
P-39	0.000	0.94	0.00	(N/A)
P-31	0.000	0.94	0.00	(N/A)
P-57	0.000	0.93	0.00	(N/A)
P-90	0.000	0.00	0.00	(N/A)
P-114	0.000	0.00	0.00	(N/A)
P-91	0.000	0.00	0.00	(N/A)
P-115	0.000	0.00	0.00	(N/A)
P-105	0.000	0.00	0.00	(N/A)
P-116	0.000	0.00	0.00	(N/A)
P-87	0.000	0.00	0.00	(N/A)
P-106	0.000	0.00	0.00	(N/A)
P-117	0.000	0.00	0.00	(N/A)
P-86	0.000	0.00	0.00	(N/A)
P-85	0.000	0.00	0.00	(N/A)
P-101	0.000	0.00	0.00	(N/A)
P-74	0.000	0.00	0.00	(N/A)
P-102	0.000	0.00	0.00	(N/A)
P-75	0.000	0.00	0.00	(N/A)
P-76	0.000	0.00	0.00	(N/A)
P-103	0.000	0.00	0.00	(N/A)
P-72	0.000	0.00	0.00	(N/A)
P-77	0.000	0.00	0.00	(N/A)
P-16	0.000	0.00	0.00	(N/A)
P-60	0.000	0.00	0.00	(N/A)
P-100	0.000	0.00	0.00	(N/A)
P-73	0.000	0.00	0.00	(N/A)
P-99	0.000	0.00	0.00	(N/A)
P-66	0.000	0.00	0.00	(N/A)
P-70	0.000	0.00	0.00	(N/A)
P-68	0.000	0.00	0.00	(N/A)
P-64	0.000	0.00	0.00	(N/A)
P-65	0.000	0.00	0.00	(N/A)
P-67	0.000	0.00	0.00	(N/A)
P-78	0.000	0.00	0.00	(N/A)
P-96	0.000	0.00	0.00	(N/A)
P-21	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On) Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-24	0.000	0.00	0.00	(N/A)
P-71	0.000	0.00	0.00	(N/A)
P-81	0.000	0.00	0.00	(N/A)
P-23	0.000	0.00	0.00	(N/A)
P-97	0.000	0.00	0.00	(N/A)
P-25	0.000	0.00	0.00	(N/A)
P-93	0.000	0.00	0.00	(N/A)
P-82	0.000	0.00	0.00	(N/A)
P-80	0.000	0.00	0.00	(N/A)
P-62	0.000	0.00	0.00	(N/A)
P-110	0.000	0.00	0.00	(N/A)
P-107	0.000	0.00	0.00	(N/A)
P-83	0.000	0.00	0.00	(N/A)
P-29	0.000	0.00	0.00	(N/A)
P-14	0.000	0.00	0.00	(N/A)
P-58	0.000	0.00	0.00	(N/A)
P-59	0.000	0.00	0.00	(N/A)
P-53	0.000	0.00	0.00	(N/A)
P-19	0.000	0.00	0.00	(N/A)
P-98	0.000	0.00	0.00	(N/A)
P-30	0.000	0.00	0.00	(N/A)
P-94	0.000	0.00	0.00	(N/A)
P-20	0.000	0.00	0.00	(N/A)
P-54	0.000	0.00	0.00	(N/A)
P-95	0.000	0.00	0.00	(N/A)
P-43	0.000	0.00	0.00	(N/A)
P-34	0.000	0.00	0.00	(N/A)
P-37	0.000	0.00	0.00	(N/A)
P-41	0.000	0.00	0.00	(N/A)
P-32	0.000	0.00	0.00	(N/A)
P-26	0.000	0.00	0.00	(N/A)
P-22	0.000	0.00	0.00	(N/A)
P-35	0.000	0.00	0.00	(N/A)
P-38	0.000	0.00	0.00	(N/A)
P-46	0.000	0.00	0.00	(N/A)
P-48	0.000	0.00	0.00	(N/A)
P-40	0.000	0.00	0.00	(N/A)
P-42	0.000	0.00	0.00	(N/A)
P-44	0.000	0.00	0.00	(N/A)
P-47	0.000	0.00	0.00	(N/A)
P-27	0.000	0.00	0.00	(N/A)
P-51	0.000	0.00	0.00	(N/A)
P-45	0.000	0.00	0.00	(N/A)
P-92	0.000	0.00	0.00	(N/A)
P-50	0.000	0.00	0.00	(N/A)

**Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On)
Pipe Report**

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-108	0.000	0.00	0.00	(N/A)
P-15	0.000	0.00	0.00	(N/A)
P-109	0.000	0.00	0.00	(N/A)
P-56	0.000	0.00	0.00	(N/A)
P-55	0.000	0.00	0.00	(N/A)
P-28	0.000	0.00	0.00	(N/A)
P-36	0.000	0.00	0.00	(N/A)
P-52	0.000	0.00	0.00	(N/A)
P-7	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On)

Node Report

Subnetwork Summary	
Subnetwork	Gravity Subnetwork

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
J-10	0.000	894.82	(N/A)	31
J-13	0.000	896.08	(N/A)	31
J-19	0.000	896.08	(N/A)	31
J-20	0.000	896.08	(N/A)	31
J-21	0.000	896.08	(N/A)	31
J-9	0.000	894.49	(N/A)	31
J-53	0.000	895.13	(N/A)	30
J-45	0.000	894.74	(N/A)	30
J-52	0.000	895.19	(N/A)	30
J-46	0.000	894.87	(N/A)	30
J-47	0.000	894.96	(N/A)	30
J-51	0.000	895.29	(N/A)	30
J-48	0.000	895.03	(N/A)	30
J-49	0.000	895.10	(N/A)	30
J-11	0.000	895.36	(N/A)	30
J-1	0.000	895.34	(N/A)	30
J-14	0.000	895.34	(N/A)	30
J-17	0.000	895.34	(N/A)	30
J-50	0.000	895.16	(N/A)	30
J-42	0.000	894.80	(N/A)	29
J-8	0.000	895.24	(N/A)	29
J-22	0.000	895.17	(N/A)	29
J-41	0.000	894.58	(N/A)	29
J-43	0.000	894.82	(N/A)	29
J-40	0.000	894.31	(N/A)	29
J-44	0.000	894.85	(N/A)	29
J-39	0.000	894.07	(N/A)	29
J-5	0.000	894.86	(N/A)	29
J-38	0.000	893.81	(N/A)	29
J-18	0.000	894.80	(N/A)	29
J-26	0.000	895.52	(N/A)	29
J-27	0.000	895.64	(N/A)	29
J-4	0.000	893.07	(N/A)	28
J-2	0.000	894.55	(N/A)	28
J-28	0.000	895.88	(N/A)	28
J-37	0.000	893.96	(N/A)	28
J-23	0.000	894.86	(N/A)	28
J-31	0.000	895.36	(N/A)	28
J-36	0.000	893.35	(N/A)	27
J-29	0.000	895.88	(N/A)	27

Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On) Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
J-35	0.000	892.80	(N/A)	27
J-24	0.000	894.86	(N/A)	26
J-32	0.000	895.36	(N/A)	26
J-30	0.000	895.88	(N/A)	26
J-7	0.000	895.88	(N/A)	25
J-34	0.000	891.67	(N/A)	25
J-25	0.000	894.86	(N/A)	25
J-12	0.000	895.36	(N/A)	25
J-33	0.000	891.07	(N/A)	25
J-6	0.000	894.86	(N/A)	24
J-3	0.000	888.08	(N/A)	21
J-15	0.000	873.61	(N/A)	2
W-11	0.000	874.39	(N/A)	1
W-13	0.000	873.92	(N/A)	1
W-14	0.000	873.47	(N/A)	1
W-15	0.000	873.76	(N/A)	1
W-16	0.000	874.05	(N/A)	1
W-19	0.000	874.10	(N/A)	1
W-20	0.000	874.36	(N/A)	1
W-26	0.000	876.16	(N/A)	1
W-27	0.000	877.65	(N/A)	1
W-30	0.000	874.31	(N/A)	1
W-1	0.000	874.50	(N/A)	1
W-2	0.000	874.50	(N/A)	1
W-3	0.000	874.24	(N/A)	1
W-4	0.000	874.12	(N/A)	1
W-5	0.000	874.37	(N/A)	1
W-6	0.000	873.72	(N/A)	1
W-7	0.000	874.50	(N/A)	1
W-8	0.000	874.50	(N/A)	1
W-9	0.000	873.85	(N/A)	1
W-10	0.000	874.50	(N/A)	1
W-12	0.000	873.62	(N/A)	1
W-17	0.000	874.24	(N/A)	1
W-18	0.000	875.28	(N/A)	1
W-21	0.000	873.51	(N/A)	1
W-22	0.000	873.78	(N/A)	1
W-23	0.000	873.98	(N/A)	1
W-24	0.000	874.24	(N/A)	1
W-25	0.000	875.24	(N/A)	1
W-28	0.000	873.87	(N/A)	1
W-29	0.000	874.03	(N/A)	1
W-31	0.000	875.84	(N/A)	1
W-32	0.000	877.11	(N/A)	1
W-33	0.000	878.00	(N/A)	1

**Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On)
Node Report**

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
W-34	0.000	874.50	(N/A)	1
W-35	0.000	874.50	(N/A)	1
W-36	0.000	874.50	(N/A)	1
W-37	0.000	876.22	(N/A)	1
W-38	0.000	875.53	(N/A)	1
W-39	0.000	876.85	(N/A)	1
W-40	0.000	874.50	(N/A)	1
W-41	0.000	877.22	(N/A)	1
MH-1	0.000	(N/A)	(N/A)	0
AV-3	0.000	867.02	(N/A)	0
J-16	0.000	866.36	(N/A)	-1

Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On)

Pond Report

Subnetwork Summary

Subnetwork Gravity
Subnetwork Subnetwork

Pond Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)
-------	---	-------------------------------

Scenario: 10 Pumps On



LAGOON DISCHARGE

SEWAGE LAGOON SITE

NW17 34-23-4

300m DEVELOPMENT
SETBACK FROM
WASTEWATER LAGOON

Color Coding Legend	
Pump: Status (Initial)	
	= On
	= Off

Color Coding Legend	
Pressure Pipe: Velocity (m/s)	
	≤ 0.01
	≤ 1.50
	≤ 3.00
	Other

Scenario: 10 Pumps On



Color Coding Legend
Pump: Status (Initial)

↻ = On
↻ = Off

Color Coding Legend
Pressure Pipe: Velocity (m/s)

— ≤ 0.01
— ≤ 1.50
— ≤ 3.00
— Other

NW17 34--23-4

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps On)

Executive Summary

Scenario	
Label	10 Pumps On
<hr/>	
Computation Results	
<hr/>	
Subnetwork Results	Number of Gravity Subnetworks: 1 Number of Pressure Subnetworks: 1 >>>> Info: Pressure subnetwork flowing to: MH-1 >>>> Info: Pressure analysis iterations: 11 >>>> Info: Convergence was achieved. >>>> Info: Gravity subnetwork draining to: O-8 >>>> Info: Convergence was achieved.

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps On)

Calculation Options

<General>			
Label	Base Calculation Options	Calculation Type	Analysis
Time Analysis Type	Steady State		
Gravity Hydraulics			
Maximum Network Traversals	5	Governing Upstream Pipe Selection Method	Pipe with Maximum QV
Flow Convergence Test	0.001	Structure Loss Mode	Hydraulic Grade
Tractive Stress (Global Minimum)	0.000 Pascals	Report Hydrologic Time Step?	True
Flow Profile Method	Backwater Analysis	Save Detailed Headloss Data?	False
Number of Flow Profile Steps	5	Gravity Friction Method	Manning's Water at 20C (68F)
Hydraulic Grade Convergence Test	0.00 m	Liquid Label	
Average Velocity Method	Actual Uniform Flow Velocity	Use Explicit Depth and Slope Equations?	False
Minimum Structure Headloss	0.00 m		
Pressure			
Peak Flow Ratio	75.0 %	Pattern Setup	<None>
Extreme Flow Setup	<None>	Steady State Hydrograph Equivalent	Peak
Pressure Hydraulics			
Use Controls During Steady State?	True	Use Linear Interpolation For Multipoint Pumps?	False
Wet Well Convergence Increment	0.2 m	Use Controls During Steady State?	True
Use Pumped Flows?	True	Liquid Specific Gravity	0.998
Pressure Subnetwork Accuracy	0.001	Pressure Subnetwork Minimum Possible Pressure	-14 psi
Pressure Subnetwork Trials	40	Pressure Friction Method	Hazen-Williams
SWMM Hydrology			
Default Infiltration Method	Horton	SWMM Hydrologic Increment	0.250 hours
Headloss (AASHTO)			
Expansion, Ke	0.350	Shaping Adjustment, Cs	0.500
Contraction, Kc	0.250	Non-Piped Flow Adjustment, Cn	1.300

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps On)

Bend Angle vs. Bend Loss Curve

Bend Angle (degrees)	Bend Loss Coefficient, Kb
0.00	0.000
15.00	0.190
30.00	0.350
45.00	0.470
60.00	0.560
75.00	0.640
90.00	0.700

HEC-22 Energy Losses

Consider Non-Piped Plunging Flow?	True
-----------------------------------	------

HEC-22 Energy Losses (Second Edition)

Elevations Considered Equal Within	0.15 m	Half Bench Submerged Factor	0.950
Flat Unsubmerged Factor	1.000	Full Bench Unsubmerged Factor	0.070
Flat Submerged Factor	1.000	Full Bench Submerged Factor	0.750
Depressed Unsubmerged Factor	1.000	Improved Bench Unsubmerged Factor	0.035
Depressed Submerged Factor	1.000	Improved Bench Submerged Factor	0.375
Half Bench Unsubmerged Factor	0.150		

HEC-22 Energy Losses (Third Edition)

Flat Submerged Coefficient	-0.050	Half Bench Unsubmerged Coefficient	-0.850
Flat Unsubmerged Coefficient	-0.050	Full Bench Submerged Coefficient	-0.250
Depressed Submerged Coefficient	0.000	Full Bench Unsubmerged Coefficient	-0.930
Depressed Unsubmerged Coefficient	0.000	Improved Submerged Coefficient	-0.600
Half Bench Submerged Coefficient	-0.050	Improved Unsubmerged Coefficient	-0.980

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps On)

Calculation Summary (499: 10 Pumps On)

Time (hours)	Balanced?	Trials	Relative Flow Change
All Time Steps (0)	True	0	(N/A)
0.00	True	(N/A)	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps On)

Pipe Report

Subnetwork Summary

Subnetwork Gravity
Subnetwork Subnetwork

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-3	0.000	6.78	3.64	(N/A)
P-4	0.000	3.78	2.03	(N/A)
P-17	0.000	6.78	1.67	(N/A)
P-18	0.000	6.78	1.67	(N/A)
P-139	0.000	6.78	1.67	(N/A)
P-122	0.000	3.00	1.61	(N/A)
P-121	0.000	3.00	1.61	(N/A)
P-120	0.000	3.00	1.61	(N/A)
P-119	0.000	3.00	1.61	(N/A)
P-118	0.000	3.00	1.61	(N/A)
P-2	0.000	2.29	1.23	(N/A)
P-10	0.000	2.03	1.09	(N/A)
P-126	0.000	1.75	0.94	(N/A)
P-125	0.000	1.75	0.94	(N/A)
P-124	0.000	1.75	0.94	(N/A)
P-123	0.000	1.75	0.94	(N/A)
P-5	0.000	1.59	0.86	(N/A)
P-88	0.000	1.59	0.86	(N/A)
P-105	0.000	1.37	0.73	(N/A)
P-111	0.000	1.34	0.72	(N/A)
P-8	0.000	1.30	0.70	(N/A)
P-104	0.000	1.30	0.70	(N/A)
P-133	0.000	1.11	0.59	(N/A)
P-132	0.000	1.11	0.59	(N/A)
P-131	0.000	1.11	0.59	(N/A)
P-130	0.000	1.11	0.59	(N/A)
P-6	0.000	1.07	0.58	(N/A)
P-129	0.000	1.07	0.58	(N/A)
P-128	0.000	1.07	0.58	(N/A)
P-127	0.000	1.07	0.58	(N/A)
P-137	0.000	0.92	0.49	(N/A)
P-11	0.000	0.92	0.49	(N/A)
P-138	0.000	0.92	0.49	(N/A)
P-24	0.000	0.71	0.38	(N/A)
P-61	0.000	0.70	0.37	(N/A)
P-1	0.000	0.70	0.37	(N/A)
P-93	0.000	0.69	0.37	(N/A)
P-106	0.000	0.69	0.37	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps On)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-82	0.000	0.68	0.37	(N/A)
P-117	0.000	0.68	0.37	(N/A)
P-116	0.000	0.68	0.37	(N/A)
P-71	0.000	0.68	0.36	(N/A)
P-66	0.000	0.68	0.36	(N/A)
P-97	0.000	0.68	0.36	(N/A)
P-114	0.000	0.68	0.36	(N/A)
P-113	0.000	0.68	0.36	(N/A)
P-112	0.000	0.68	0.36	(N/A)
P-78	0.000	0.66	0.36	(N/A)
P-72	0.000	0.66	0.35	(N/A)
P-102	0.000	0.65	0.35	(N/A)
P-9	0.000	0.45	0.24	(N/A)
P-135	0.000	0.45	0.24	(N/A)
P-134	0.000	0.45	0.24	(N/A)
P-12	0.000	0.41	0.22	(N/A)
P-13	0.000	0.27	0.14	(N/A)
P-136	0.000	0.27	0.14	(N/A)
P-27	0.000	0.71	0.00	(N/A)
P-31	0.000	0.70	0.00	(N/A)
P-92	0.000	0.69	0.00	(N/A)
P-55	0.000	0.68	0.00	(N/A)
P-41	0.000	0.68	0.00	(N/A)
P-36	0.000	0.68	0.00	(N/A)
P-95	0.000	0.68	0.00	(N/A)
P-48	0.000	0.66	0.00	(N/A)
P-42	0.000	0.66	0.00	(N/A)
P-52	0.000	0.65	0.00	(N/A)
P-89	0.000	0.00	0.00	(N/A)
P-90	0.000	0.00	0.00	(N/A)
P-87	0.000	0.00	0.00	(N/A)
P-101	0.000	0.00	0.00	(N/A)
P-103	0.000	0.00	0.00	(N/A)
P-76	0.000	0.00	0.00	(N/A)
P-75	0.000	0.00	0.00	(N/A)
P-77	0.000	0.00	0.00	(N/A)
P-91	0.000	0.00	0.00	(N/A)
P-85	0.000	0.00	0.00	(N/A)
P-86	0.000	0.00	0.00	(N/A)
P-84	0.000	0.00	0.00	(N/A)
P-74	0.000	0.00	0.00	(N/A)
P-73	0.000	0.00	0.00	(N/A)
P-99	0.000	0.00	0.00	(N/A)
P-96	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps On)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-81	0.000	0.00	0.00	(N/A)
P-79	0.000	0.00	0.00	(N/A)
P-64	0.000	0.00	0.00	(N/A)
P-70	0.000	0.00	0.00	(N/A)
P-69	0.000	0.00	0.00	(N/A)
P-68	0.000	0.00	0.00	(N/A)
P-65	0.000	0.00	0.00	(N/A)
P-115	0.000	0.00	0.00	(N/A)
P-80	0.000	0.00	0.00	(N/A)
P-67	0.000	0.00	0.00	(N/A)
P-14	0.000	0.00	0.00	(N/A)
P-83	0.000	0.00	0.00	(N/A)
P-100	0.000	0.00	0.00	(N/A)
P-16	0.000	0.00	0.00	(N/A)
P-60	0.000	0.00	0.00	(N/A)
P-63	0.000	0.00	0.00	(N/A)
P-107	0.000	0.00	0.00	(N/A)
P-110	0.000	0.00	0.00	(N/A)
P-21	0.000	0.00	0.00	(N/A)
P-23	0.000	0.00	0.00	(N/A)
P-25	0.000	0.00	0.00	(N/A)
P-62	0.000	0.00	0.00	(N/A)
P-29	0.000	0.00	0.00	(N/A)
P-39	0.000	0.00	0.00	(N/A)
P-53	0.000	0.00	0.00	(N/A)
P-57	0.000	0.00	0.00	(N/A)
P-58	0.000	0.00	0.00	(N/A)
P-59	0.000	0.00	0.00	(N/A)
P-94	0.000	0.00	0.00	(N/A)
P-98	0.000	0.00	0.00	(N/A)
P-54	0.000	0.00	0.00	(N/A)
P-30	0.000	0.00	0.00	(N/A)
P-19	0.000	0.00	0.00	(N/A)
P-33	0.000	0.00	0.00	(N/A)
P-20	0.000	0.00	0.00	(N/A)
P-32	0.000	0.00	0.00	(N/A)
P-37	0.000	0.00	0.00	(N/A)
P-34	0.000	0.00	0.00	(N/A)
P-43	0.000	0.00	0.00	(N/A)
P-22	0.000	0.00	0.00	(N/A)
P-35	0.000	0.00	0.00	(N/A)
P-40	0.000	0.00	0.00	(N/A)
P-44	0.000	0.00	0.00	(N/A)
P-47	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps On)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-51	0.000	0.00	0.00	(N/A)
P-28	0.000	0.00	0.00	(N/A)
P-26	0.000	0.00	0.00	(N/A)
P-49	0.000	0.00	0.00	(N/A)
P-56	0.000	0.00	0.00	(N/A)
P-46	0.000	0.00	0.00	(N/A)
P-45	0.000	0.00	0.00	(N/A)
P-50	0.000	0.00	0.00	(N/A)
P-109	0.000	0.00	0.00	(N/A)
P-38	0.000	0.00	0.00	(N/A)
P-15	0.000	0.00	0.00	(N/A)
P-7	0.000	0.00	0.00	(N/A)
P-108	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps On)

Node Report

Subnetwork Summary

Subnetwork Gravity
Subnetwork Subnetwork

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
J-10	0.000	922.94	(N/A)	71
J-53	0.000	923.63	(N/A)	71
J-52	0.000	923.77	(N/A)	71
J-51	0.000	923.80	(N/A)	70
J-48	0.000	923.55	(N/A)	70
J-47	0.000	923.38	(N/A)	70
J-46	0.000	923.13	(N/A)	70
J-49	0.000	923.58	(N/A)	70
J-11	0.000	923.81	(N/A)	70
J-13	0.000	923.81	(N/A)	70
J-19	0.000	923.81	(N/A)	70
J-20	0.000	923.81	(N/A)	70
J-21	0.000	923.81	(N/A)	70
J-45	0.000	922.80	(N/A)	70
J-50	0.000	923.61	(N/A)	70
J-9	0.000	922.18	(N/A)	70
J-8	0.000	923.64	(N/A)	70
J-26	0.000	924.18	(N/A)	69
J-22	0.000	923.38	(N/A)	69
J-27	0.000	924.24	(N/A)	69
J-31	0.000	924.09	(N/A)	68
J-28	0.000	924.37	(N/A)	68
J-29	0.000	924.51	(N/A)	68
J-5	0.000	922.15	(N/A)	68
J-44	0.000	922.01	(N/A)	68
J-43	0.000	921.83	(N/A)	68
J-42	0.000	921.61	(N/A)	68
J-41	0.000	921.46	(N/A)	67
J-23	0.000	922.75	(N/A)	67
J-32	0.000	924.36	(N/A)	67
J-40	0.000	920.97	(N/A)	67
J-39	0.000	920.54	(N/A)	67
J-30	0.000	924.51	(N/A)	67
J-24	0.000	922.95	(N/A)	66
J-38	0.000	920.09	(N/A)	66
J-7	0.000	924.51	(N/A)	66
J-12	0.000	924.36	(N/A)	66
J-1	0.000	920.42	(N/A)	65

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps On)

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
J-14	0.000	920.42	(N/A)	65
J-17	0.000	920.42	(N/A)	65
J-18	0.000	920.37	(N/A)	65
J-4	0.000	918.78	(N/A)	65
J-25	0.000	922.95	(N/A)	65
J-2	0.000	919.97	(N/A)	65
J-6	0.000	922.95	(N/A)	64
J-37	0.000	919.31	(N/A)	64
J-36	0.000	918.18	(N/A)	62
J-35	0.000	917.16	(N/A)	61
J-34	0.000	915.07	(N/A)	59
J-33	0.000	913.94	(N/A)	57
J-3	0.000	908.44	(N/A)	50
J-15	0.000	879.97	(N/A)	11
W-11	0.000	874.39	(N/A)	1
W-13	0.000	873.92	(N/A)	1
W-14	0.000	873.47	(N/A)	1
W-15	0.000	873.76	(N/A)	1
W-16	0.000	874.05	(N/A)	1
W-19	0.000	874.10	(N/A)	1
W-20	0.000	874.36	(N/A)	1
W-26	0.000	876.16	(N/A)	1
W-27	0.000	877.65	(N/A)	1
W-30	0.000	874.31	(N/A)	1
W-1	0.000	874.50	(N/A)	1
W-2	0.000	874.50	(N/A)	1
W-3	0.000	874.24	(N/A)	1
W-4	0.000	874.12	(N/A)	1
W-5	0.000	874.37	(N/A)	1
W-6	0.000	873.72	(N/A)	1
W-7	0.000	874.50	(N/A)	1
W-8	0.000	874.50	(N/A)	1
W-9	0.000	873.85	(N/A)	1
W-10	0.000	874.50	(N/A)	1
W-12	0.000	873.62	(N/A)	1
W-17	0.000	874.24	(N/A)	1
W-18	0.000	875.28	(N/A)	1
W-21	0.000	873.51	(N/A)	1
W-22	0.000	873.78	(N/A)	1
W-23	0.000	873.98	(N/A)	1
W-24	0.000	874.24	(N/A)	1
W-25	0.000	875.24	(N/A)	1
W-28	0.000	873.87	(N/A)	1
W-29	0.000	874.03	(N/A)	1

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps On)

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
W-31	0.000	875.84	(N/A)	1
W-32	0.000	877.11	(N/A)	1
W-33	0.000	878.00	(N/A)	1
W-34	0.000	874.50	(N/A)	1
W-35	0.000	874.50	(N/A)	1
W-36	0.000	874.50	(N/A)	1
W-37	0.000	876.22	(N/A)	1
W-38	0.000	875.53	(N/A)	1
W-39	0.000	876.85	(N/A)	1
W-40	0.000	874.50	(N/A)	1
W-41	0.000	877.22	(N/A)	1
MH-1	0.000	(N/A)	(N/A)	0
AV-3	0.000	867.02	(N/A)	0
J-16	0.000	866.64	(N/A)	-1

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps On)

Pond Report

Subnetwork Summary

Subnetwork Gravity
Subnetwork Subnetwork

Pond Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)
-------	---	-------------------------------

Scenario: 15 Pumps On



Color Coding Legend
Pump: Status (Initial)



	= On
	= Off





Color Coding Legend
Pressure Pipe: Velocity (m/s)

	≤ 0.01
	≤ 1.50
	≤ 3.00
	Other

Scenario: 15 Pumps On



Color Coding Legend	
Pump: Status (Initial)	
	= On
	= Off

Color Coding Legend	
Pressure Pipe: Velocity (m/s)	
	≤ 0.01
	≤ 1.50
	≤ 3.00
	Other

NW17 34--23-4

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps On)

Executive Summary

Scenario	
Label	15 Pumps On
<hr/>	
Computation Results	
<hr/>	
Subnetwork Results	Number of Gravity Subnetworks: 1 Number of Pressure Subnetworks: 1 >>>> Info: Pressure subnetwork flowing to: MH-1 >>>> Info: Pressure analysis iterations: 11 >>>> Info: Convergence was achieved. >>>> Info: Gravity subnetwork draining to: O-8 >>>> Info: Convergence was achieved.

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps On)

Calculation Options

<General>			
Label	Base Calculation Options	Calculation Type	Analysis
Time Analysis Type	Steady State		
Gravity Hydraulics			
Maximum Network Traversals	5	Governing Upstream Pipe Selection Method	Pipe with Maximum QV
Flow Convergence Test	0.001	Structure Loss Mode	Hydraulic Grade
Tractive Stress (Global Minimum)	0.000 Pascals	Report Hydrologic Time Step?	True
Flow Profile Method	Backwater Analysis	Save Detailed Headloss Data?	False
Number of Flow Profile Steps	5	Gravity Friction Method	Manning's Water at 20C (68F)
Hydraulic Grade Convergence Test	0.00 m	Liquid Label	
Average Velocity Method	Actual Uniform Flow Velocity	Use Explicit Depth and Slope Equations?	False
Minimum Structure Headloss	0.00 m		
Pressure			
Peak Flow Ratio	75.0 %	Pattern Setup	<None>
Extreme Flow Setup	<None>	Steady State Hydrograph Equivalent	Peak
Pressure Hydraulics			
Use Controls During Steady State?	True	Use Linear Interpolation For Multipoint Pumps?	False
Wet Well Convergence Increment	0.2 m	Use Controls During Steady State?	True
Use Pumped Flows?	True	Liquid Specific Gravity	0.998
Pressure Subnetwork Accuracy	0.001	Pressure Subnetwork Minimum Possible Pressure	-14 psi
Pressure Subnetwork Trials	40	Pressure Friction Method	Hazen-Williams
SWMM Hydrology			
Default Infiltration Method	Horton	SWMM Hydrologic Increment	0.250 hours
Headloss (AASHTO)			
Expansion, Ke	0.350	Shaping Adjustment, Cs	0.500
Contraction, Kc	0.250	Non-Piped Flow Adjustment, Cn	1.300

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps On)

Bend Angle vs. Bend Loss Curve

Bend Angle (degrees)	Bend Loss Coefficient, Kb
0.00	0.000
15.00	0.190
30.00	0.350
45.00	0.470
60.00	0.560
75.00	0.640
90.00	0.700

HEC-22 Energy Losses

Consider Non-Piped Plunging Flow?	True
-----------------------------------	------

HEC-22 Energy Losses (Second Edition)

Elevations Considered Equal Within	0.15 m	Half Bench Submerged Factor	0.950
Flat Unsubmerged Factor	1.000	Full Bench Unsubmerged Factor	0.070
Flat Submerged Factor	1.000	Full Bench Submerged Factor	0.750
Depressed Unsubmerged Factor	1.000	Improved Bench Unsubmerged Factor	0.035
Depressed Submerged Factor	1.000	Improved Bench Submerged Factor	0.375
Half Bench Unsubmerged Factor	0.150		

HEC-22 Energy Losses (Third Edition)

Flat Submerged Coefficient	-0.050	Half Bench Unsubmerged Coefficient	-0.850
Flat Unsubmerged Coefficient	-0.050	Full Bench Submerged Coefficient	-0.250
Depressed Submerged Coefficient	0.000	Full Bench Unsubmerged Coefficient	-0.930
Depressed Unsubmerged Coefficient	0.000	Improved Submerged Coefficient	-0.600
Half Bench Submerged Coefficient	-0.050	Improved Unsubmerged Coefficient	-0.980

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps On)

Calculation Summary (501: 15 Pumps On)

Time (hours)	Balanced?	Trials	Relative Flow Change
All Time Steps (1)	True	11	0.0000465
0.00	True	11	0.0000465

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps On)

Pipe Report

Subnetwork Summary

Subnetwork Gravity
Subnetwork Subnetwork

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-3	0.000	7.69	4.13	(N/A)
P-4	0.000	4.02	2.16	(N/A)
P-118	0.000	3.66	1.97	(N/A)
P-18	0.000	7.69	1.90	(N/A)
P-139	0.000	7.69	1.90	(N/A)
P-17	0.000	7.69	1.90	(N/A)
P-119	0.000	3.06	1.64	(N/A)
P-2	0.000	2.48	1.33	(N/A)
P-122	0.000	2.48	1.33	(N/A)
P-121	0.000	2.48	1.33	(N/A)
P-120	0.000	2.48	1.33	(N/A)
P-10	0.000	2.07	1.11	(N/A)
P-125	0.000	1.96	1.05	(N/A)
P-124	0.000	1.96	1.05	(N/A)
P-123	0.000	1.96	1.05	(N/A)
P-88	0.000	1.94	1.04	(N/A)
P-126	0.000	1.45	0.78	(N/A)
P-5	0.000	1.41	0.76	(N/A)
P-8	0.000	1.32	0.71	(N/A)
P-104	0.000	1.32	0.71	(N/A)
P-132	0.000	1.05	0.56	(N/A)
P-131	0.000	1.04	0.56	(N/A)
P-130	0.000	1.04	0.56	(N/A)
P-11	0.000	1.02	0.55	(N/A)
P-138	0.000	1.02	0.55	(N/A)
P-116	0.000	1.00	0.53	(N/A)
P-112	0.000	0.99	0.53	(N/A)
P-111	0.000	0.99	0.53	(N/A)
P-127	0.000	0.95	0.51	(N/A)
P-12	0.000	0.90	0.48	(N/A)
P-29	0.000	0.60	0.32	(N/A)
P-62	0.000	0.59	0.31	(N/A)
P-9	0.000	0.57	0.31	(N/A)
P-135	0.000	0.57	0.31	(N/A)
P-134	0.000	0.57	0.31	(N/A)
P-133	0.000	0.57	0.31	(N/A)
P-13	0.000	0.56	0.30	(N/A)
P-136	0.000	0.56	0.30	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps On)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-137	0.000	0.56	0.30	(N/A)
P-110	0.000	0.54	0.29	(N/A)
P-107	0.000	0.54	0.29	(N/A)
P-106	0.000	0.54	0.29	(N/A)
P-105	0.000	0.54	0.29	(N/A)
P-61	0.000	0.53	0.29	(N/A)
P-1	0.000	0.53	0.29	(N/A)
P-63	0.000	0.53	0.28	(N/A)
P-14	0.000	0.51	0.28	(N/A)
P-83	0.000	0.51	0.28	(N/A)
P-117	0.000	0.51	0.28	(N/A)
P-68	0.000	0.50	0.27	(N/A)
P-66	0.000	0.50	0.27	(N/A)
P-69	0.000	0.50	0.27	(N/A)
P-79	0.000	0.50	0.27	(N/A)
P-113	0.000	0.50	0.27	(N/A)
P-96	0.000	0.49	0.26	(N/A)
P-81	0.000	0.48	0.26	(N/A)
P-76	0.000	0.48	0.26	(N/A)
P-84	0.000	0.46	0.25	(N/A)
P-89	0.000	0.46	0.25	(N/A)
P-101	0.000	0.46	0.25	(N/A)
P-6	0.000	0.45	0.24	(N/A)
P-129	0.000	0.45	0.24	(N/A)
P-128	0.000	0.45	0.24	(N/A)
P-28	0.000	0.60	0.00	(N/A)
P-32	0.000	0.59	0.00	(N/A)
P-109	0.000	0.54	0.00	(N/A)
P-31	0.000	0.53	0.00	(N/A)
P-33	0.000	0.53	0.00	(N/A)
P-56	0.000	0.51	0.00	(N/A)
P-38	0.000	0.50	0.00	(N/A)
P-36	0.000	0.50	0.00	(N/A)
P-39	0.000	0.50	0.00	(N/A)
P-49	0.000	0.50	0.00	(N/A)
P-94	0.000	0.49	0.00	(N/A)
P-54	0.000	0.48	0.00	(N/A)
P-46	0.000	0.48	0.00	(N/A)
P-57	0.000	0.46	0.00	(N/A)
P-51	0.000	0.46	0.00	(N/A)
P-108	0.000	0.00	0.00	(N/A)
P-90	0.000	0.00	0.00	(N/A)
P-114	0.000	0.00	0.00	(N/A)
P-87	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps On)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-102	0.000	0.00	0.00	(N/A)
P-86	0.000	0.00	0.00	(N/A)
P-85	0.000	0.00	0.00	(N/A)
P-91	0.000	0.00	0.00	(N/A)
P-103	0.000	0.00	0.00	(N/A)
P-75	0.000	0.00	0.00	(N/A)
P-74	0.000	0.00	0.00	(N/A)
P-72	0.000	0.00	0.00	(N/A)
P-77	0.000	0.00	0.00	(N/A)
P-73	0.000	0.00	0.00	(N/A)
P-99	0.000	0.00	0.00	(N/A)
P-78	0.000	0.00	0.00	(N/A)
P-82	0.000	0.00	0.00	(N/A)
P-70	0.000	0.00	0.00	(N/A)
P-64	0.000	0.00	0.00	(N/A)
P-65	0.000	0.00	0.00	(N/A)
P-97	0.000	0.00	0.00	(N/A)
P-67	0.000	0.00	0.00	(N/A)
P-71	0.000	0.00	0.00	(N/A)
P-80	0.000	0.00	0.00	(N/A)
P-115	0.000	0.00	0.00	(N/A)
P-93	0.000	0.00	0.00	(N/A)
P-60	0.000	0.00	0.00	(N/A)
P-16	0.000	0.00	0.00	(N/A)
P-100	0.000	0.00	0.00	(N/A)
P-21	0.000	0.00	0.00	(N/A)
P-24	0.000	0.00	0.00	(N/A)
P-23	0.000	0.00	0.00	(N/A)
P-25	0.000	0.00	0.00	(N/A)
P-58	0.000	0.00	0.00	(N/A)
P-59	0.000	0.00	0.00	(N/A)
P-53	0.000	0.00	0.00	(N/A)
P-95	0.000	0.00	0.00	(N/A)
P-30	0.000	0.00	0.00	(N/A)
P-19	0.000	0.00	0.00	(N/A)
P-20	0.000	0.00	0.00	(N/A)
P-98	0.000	0.00	0.00	(N/A)
P-37	0.000	0.00	0.00	(N/A)
P-41	0.000	0.00	0.00	(N/A)
P-34	0.000	0.00	0.00	(N/A)
P-43	0.000	0.00	0.00	(N/A)
P-26	0.000	0.00	0.00	(N/A)
P-22	0.000	0.00	0.00	(N/A)
P-27	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps On)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-52	0.000	0.00	0.00	(N/A)
P-55	0.000	0.00	0.00	(N/A)
P-92	0.000	0.00	0.00	(N/A)
P-35	0.000	0.00	0.00	(N/A)
P-40	0.000	0.00	0.00	(N/A)
P-50	0.000	0.00	0.00	(N/A)
P-44	0.000	0.00	0.00	(N/A)
P-45	0.000	0.00	0.00	(N/A)
P-42	0.000	0.00	0.00	(N/A)
P-48	0.000	0.00	0.00	(N/A)
P-47	0.000	0.00	0.00	(N/A)
P-15	0.000	0.00	0.00	(N/A)
P-7	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps On)

Node Report

Subnetwork Summary

Subnetwork Gravity
Subnetwork Subnetwork

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
J-10	0.000	935.52	(N/A)	89
J-53	0.000	936.37	(N/A)	89
J-52	0.000	936.43	(N/A)	89
J-13	0.000	936.78	(N/A)	88
J-19	0.000	936.78	(N/A)	88
J-20	0.000	936.78	(N/A)	88
J-21	0.000	936.78	(N/A)	88
J-51	0.000	936.52	(N/A)	88
J-11	0.000	936.58	(N/A)	88
J-47	0.000	935.68	(N/A)	88
J-46	0.000	935.45	(N/A)	88
J-45	0.000	935.16	(N/A)	88
J-48	0.000	935.73	(N/A)	87
J-9	0.000	934.60	(N/A)	87
J-49	0.000	935.78	(N/A)	87
J-50	0.000	935.82	(N/A)	87
J-8	0.000	935.88	(N/A)	87
J-31	0.000	937.15	(N/A)	87
J-22	0.000	935.61	(N/A)	87
J-26	0.000	936.18	(N/A)	87
J-27	0.000	936.31	(N/A)	86
J-28	0.000	936.38	(N/A)	85
J-32	0.000	937.30	(N/A)	85
J-41	0.000	934.11	(N/A)	85
J-42	0.000	934.23	(N/A)	85
J-43	0.000	934.28	(N/A)	85
J-40	0.000	933.77	(N/A)	85
J-44	0.000	934.31	(N/A)	85
J-5	0.000	934.34	(N/A)	85
J-39	0.000	933.24	(N/A)	85
J-29	0.000	936.38	(N/A)	85
J-12	0.000	937.41	(N/A)	84
J-38	0.000	932.69	(N/A)	84
J-23	0.000	934.45	(N/A)	84
J-30	0.000	936.38	(N/A)	83
J-18	0.000	932.91	(N/A)	83
J-7	0.000	936.38	(N/A)	83
J-24	0.000	934.58	(N/A)	83

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps On)

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
J-1	0.000	932.61	(N/A)	82
J-14	0.000	932.61	(N/A)	82
J-17	0.000	932.61	(N/A)	82
J-4	0.000	931.07	(N/A)	82
J-2	0.000	932.33	(N/A)	82
J-25	0.000	934.71	(N/A)	82
J-37	0.000	931.56	(N/A)	81
J-6	0.000	934.71	(N/A)	81
J-36	0.000	930.77	(N/A)	80
J-35	0.000	930.06	(N/A)	79
J-34	0.000	928.59	(N/A)	78
J-33	0.000	927.42	(N/A)	76
J-3	0.000	919.45	(N/A)	66
J-15	0.000	883.47	(N/A)	16
W-11	0.000	874.39	(N/A)	1
W-13	0.000	873.92	(N/A)	1
W-14	0.000	873.47	(N/A)	1
W-15	0.000	873.76	(N/A)	1
W-16	0.000	874.05	(N/A)	1
W-19	0.000	874.10	(N/A)	1
W-20	0.000	874.36	(N/A)	1
W-26	0.000	876.16	(N/A)	1
W-27	0.000	877.65	(N/A)	1
W-30	0.000	874.31	(N/A)	1
W-1	0.000	874.50	(N/A)	1
W-2	0.000	874.50	(N/A)	1
W-3	0.000	874.24	(N/A)	1
W-4	0.000	874.12	(N/A)	1
W-5	0.000	874.37	(N/A)	1
W-6	0.000	873.72	(N/A)	1
W-7	0.000	874.50	(N/A)	1
W-8	0.000	874.50	(N/A)	1
W-9	0.000	873.85	(N/A)	1
W-10	0.000	874.50	(N/A)	1
W-12	0.000	873.62	(N/A)	1
W-17	0.000	874.24	(N/A)	1
W-18	0.000	875.28	(N/A)	1
W-21	0.000	873.51	(N/A)	1
W-22	0.000	873.78	(N/A)	1
W-23	0.000	873.98	(N/A)	1
W-24	0.000	874.24	(N/A)	1
W-25	0.000	875.24	(N/A)	1
W-28	0.000	873.87	(N/A)	1
W-29	0.000	874.03	(N/A)	1

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps On)

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
W-31	0.000	875.84	(N/A)	1
W-32	0.000	877.11	(N/A)	1
W-33	0.000	878.00	(N/A)	1
W-34	0.000	874.50	(N/A)	1
W-35	0.000	874.50	(N/A)	1
W-36	0.000	874.50	(N/A)	1
W-37	0.000	876.22	(N/A)	1
W-38	0.000	875.53	(N/A)	1
W-39	0.000	876.85	(N/A)	1
W-40	0.000	874.50	(N/A)	1
W-41	0.000	877.22	(N/A)	1
AV-3	0.000	867.11	(N/A)	0
MH-1	0.000	(N/A)	(N/A)	0
J-16	0.000	866.80	(N/A)	0

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps On)

Pond Report

Subnetwork Summary

Subnetwork

Gravity
Subnetwork

Pond Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)
-------	---	-------------------------------

Scenario: 20 Pumps On



NW17 34-23-4

Color Coding Legend
Pump: Status (Initial)



	= On
	= Off

Color Coding Legend
Pressure Pipe: Velocity (m/s)





	<= 0.01
	<= 1.50
	<= 3.00
	Other

Scenario: 20 Pumps On

Color Coding Legend
Pump: Status (Initial)

 = On
 = Off

Color Coding Legend
Pressure Pipe: Velocity (m/s)

 <= 0.01
 <= 1.50
 <= 3.00
 Other

NW17 34--23-4



Detailed Calculation Summary (Huxley Sewer Model.stsw, 20 Pumps On)

Executive Summary

Scenario	
Label	20 Pumps On
<hr/>	
Computation Results	
<hr/>	
Subnetwork Results	Number of Gravity Subnetworks: 1 Number of Pressure Subnetworks: 1 >>>> Info: Pressure subnetwork flowing to: MH-1 >>>> Info: Pressure analysis iterations: 12 >>>> Info: Convergence was achieved. >>>> Info: Gravity subnetwork draining to: O-8 >>>> Info: Convergence was achieved.

Detailed Calculation Summary (Huxley Sewer Model.stsw, 20 Pumps On)

Calculation Options

<General>			
Label	Base Calculation Options	Calculation Type	Analysis
Time Analysis Type	Steady State		
Gravity Hydraulics			
Maximum Network Traversals	5	Governing Upstream Pipe Selection Method	Pipe with Maximum QV
Flow Convergence Test	0.001	Structure Loss Mode	Hydraulic Grade
Tractive Stress (Global Minimum)	0.000 Pascals	Report Hydrologic Time Step?	True
Flow Profile Method	Backwater Analysis	Save Detailed Headloss Data?	False
Number of Flow Profile Steps	5	Gravity Friction Method	Manning's Water at 20C (68F)
Hydraulic Grade Convergence Test	0.00 m	Liquid Label	
Average Velocity Method	Actual Uniform Flow Velocity	Use Explicit Depth and Slope Equations?	False
Minimum Structure Headloss	0.00 m		
Pressure			
Peak Flow Ratio	75.0 %	Pattern Setup	<None>
Extreme Flow Setup	<None>	Steady State Hydrograph Equivalent	Peak
Pressure Hydraulics			
Use Controls During Steady State?	True	Use Linear Interpolation For Multipoint Pumps?	False
Wet Well Convergence Increment	0.2 m	Use Controls During Steady State?	True
Use Pumped Flows?	True	Liquid Specific Gravity	0.998
Pressure Subnetwork Accuracy	0.001	Pressure Subnetwork Minimum Possible Pressure	-14 psi
Pressure Subnetwork Trials	40	Pressure Friction Method	Hazen-Williams
SWMM Hydrology			
Default Infiltration Method	Horton	SWMM Hydrologic Increment	0.250 hours
Headloss (AASHTO)			
Expansion, Ke	0.350	Shaping Adjustment, Cs	0.500
Contraction, Kc	0.250	Non-Piped Flow Adjustment, Cn	1.300

Detailed Calculation Summary (Huxley Sewer Model.stsw, 20 Pumps On)

Bend Angle vs. Bend Loss Curve

Bend Angle (degrees)	Bend Loss Coefficient, Kb
0.00	0.000
15.00	0.190
30.00	0.350
45.00	0.470
60.00	0.560
75.00	0.640
90.00	0.700

HEC-22 Energy Losses

Consider Non-Piped Plunging Flow?	True
-----------------------------------	------

HEC-22 Energy Losses (Second Edition)

Elevations Considered Equal Within	0.15 m	Half Bench Submerged Factor	0.950
Flat Unsubmerged Factor	1.000	Full Bench Unsubmerged Factor	0.070
Flat Submerged Factor	1.000	Full Bench Submerged Factor	0.750
Depressed Unsubmerged Factor	1.000	Improved Bench Unsubmerged Factor	0.035
Depressed Submerged Factor	1.000	Improved Bench Submerged Factor	0.375
Half Bench Unsubmerged Factor	0.150		

HEC-22 Energy Losses (Third Edition)

Flat Submerged Coefficient	-0.050	Half Bench Unsubmerged Coefficient	-0.850
Flat Unsubmerged Coefficient	-0.050	Full Bench Submerged Coefficient	-0.250
Depressed Submerged Coefficient	0.000	Full Bench Unsubmerged Coefficient	-0.930
Depressed Unsubmerged Coefficient	0.000	Improved Submerged Coefficient	-0.600
Half Bench Submerged Coefficient	-0.050	Improved Unsubmerged Coefficient	-0.980

Detailed Calculation Summary (Huxley Sewer Model.stsw, 20 Pumps On)

Calculation Summary (502: 20 Pumps On)

Time (hours)	Balanced?	Trials	Relative Flow Change
All Time Steps (0)	True	0	(N/A)
0.00	True	(N/A)	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 20 Pumps On)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-9	0.000	0.51	0.27	(N/A)
P-135	0.000	0.51	0.27	(N/A)
P-134	0.000	0.51	0.27	(N/A)
P-133	0.000	0.51	0.27	(N/A)
P-6	0.000	0.48	0.26	(N/A)
P-25	0.000	0.48	0.26	(N/A)
P-23	0.000	0.46	0.25	(N/A)
P-107	0.000	0.44	0.24	(N/A)
P-110	0.000	0.44	0.24	(N/A)
P-106	0.000	0.44	0.24	(N/A)
P-21	0.000	0.43	0.23	(N/A)
P-115	0.000	0.42	0.23	(N/A)
P-80	0.000	0.42	0.23	(N/A)
P-114	0.000	0.42	0.23	(N/A)
P-61	0.000	0.42	0.22	(N/A)
P-16	0.000	0.42	0.22	(N/A)
P-100	0.000	0.42	0.22	(N/A)
P-87	0.000	0.42	0.22	(N/A)
P-71	0.000	0.41	0.22	(N/A)
P-66	0.000	0.40	0.21	(N/A)
P-79	0.000	0.40	0.21	(N/A)
P-69	0.000	0.39	0.21	(N/A)
P-64	0.000	0.39	0.21	(N/A)
P-70	0.000	0.39	0.21	(N/A)
P-81	0.000	0.39	0.21	(N/A)
P-116	0.000	0.39	0.21	(N/A)
P-76	0.000	0.36	0.19	(N/A)
P-75	0.000	0.36	0.19	(N/A)
P-103	0.000	0.35	0.19	(N/A)
P-102	0.000	0.35	0.19	(N/A)
P-84	0.000	0.35	0.19	(N/A)
P-85	0.000	0.34	0.19	(N/A)
P-90	0.000	0.34	0.19	(N/A)
P-13	0.000	0.30	0.16	(N/A)
P-26	0.000	0.48	0.00	(N/A)
P-22	0.000	0.46	0.00	(N/A)
P-109	0.000	0.44	0.00	(N/A)
P-20	0.000	0.43	0.00	(N/A)
P-50	0.000	0.42	0.00	(N/A)
P-31	0.000	0.42	0.00	(N/A)
P-19	0.000	0.42	0.00	(N/A)
P-41	0.000	0.41	0.00	(N/A)
P-36	0.000	0.40	0.00	(N/A)
P-49	0.000	0.40	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 20 Pumps On)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-39	0.000	0.39	0.00	(N/A)
P-34	0.000	0.39	0.00	(N/A)
P-40	0.000	0.39	0.00	(N/A)
P-54	0.000	0.39	0.00	(N/A)
P-46	0.000	0.36	0.00	(N/A)
P-45	0.000	0.36	0.00	(N/A)
P-53	0.000	0.35	0.00	(N/A)
P-52	0.000	0.35	0.00	(N/A)
P-57	0.000	0.35	0.00	(N/A)
P-58	0.000	0.34	0.00	(N/A)
P-117	0.000	0.00	0.00	(N/A)
P-86	0.000	0.00	0.00	(N/A)
P-91	0.000	0.00	0.00	(N/A)
P-101	0.000	0.00	0.00	(N/A)
P-72	0.000	0.00	0.00	(N/A)
P-74	0.000	0.00	0.00	(N/A)
P-77	0.000	0.00	0.00	(N/A)
P-73	0.000	0.00	0.00	(N/A)
P-99	0.000	0.00	0.00	(N/A)
P-78	0.000	0.00	0.00	(N/A)
P-96	0.000	0.00	0.00	(N/A)
P-97	0.000	0.00	0.00	(N/A)
P-68	0.000	0.00	0.00	(N/A)
P-82	0.000	0.00	0.00	(N/A)
P-60	0.000	0.00	0.00	(N/A)
P-65	0.000	0.00	0.00	(N/A)
P-93	0.000	0.00	0.00	(N/A)
P-63	0.000	0.00	0.00	(N/A)
P-67	0.000	0.00	0.00	(N/A)
P-14	0.000	0.00	0.00	(N/A)
P-83	0.000	0.00	0.00	(N/A)
P-24	0.000	0.00	0.00	(N/A)
P-62	0.000	0.00	0.00	(N/A)
P-29	0.000	0.00	0.00	(N/A)
P-37	0.000	0.00	0.00	(N/A)
P-32	0.000	0.00	0.00	(N/A)
P-59	0.000	0.00	0.00	(N/A)
P-94	0.000	0.00	0.00	(N/A)
P-98	0.000	0.00	0.00	(N/A)
P-95	0.000	0.00	0.00	(N/A)
P-30	0.000	0.00	0.00	(N/A)
P-33	0.000	0.00	0.00	(N/A)
P-43	0.000	0.00	0.00	(N/A)
P-35	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 20 Pumps On)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-44	0.000	0.00	0.00	(N/A)
P-27	0.000	0.00	0.00	(N/A)
P-38	0.000	0.00	0.00	(N/A)
P-48	0.000	0.00	0.00	(N/A)
P-42	0.000	0.00	0.00	(N/A)
P-47	0.000	0.00	0.00	(N/A)
P-108	0.000	0.00	0.00	(N/A)
P-28	0.000	0.00	0.00	(N/A)
P-15	0.000	0.00	0.00	(N/A)
P-7	0.000	0.00	0.00	(N/A)
P-51	0.000	0.00	0.00	(N/A)
P-55	0.000	0.00	0.00	(N/A)
P-56	0.000	0.00	0.00	(N/A)
P-92	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 20 Pumps On)

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
J-18	0.000	938.83	(N/A)	91
J-38	0.000	937.68	(N/A)	91
J-12	0.000	942.04	(N/A)	91
J-7	0.000	942.02	(N/A)	91
J-2	0.000	938.49	(N/A)	91
J-25	0.000	940.76	(N/A)	90
J-37	0.000	937.58	(N/A)	90
J-4	0.000	935.90	(N/A)	89
J-6	0.000	940.76	(N/A)	89
J-36	0.000	936.64	(N/A)	89
J-35	0.000	935.50	(N/A)	87
J-34	0.000	932.46	(N/A)	83
J-33	0.000	930.82	(N/A)	81
J-3	0.000	922.85	(N/A)	71
J-15	0.000	884.58	(N/A)	18
W-11	0.000	874.39	(N/A)	1
W-13	0.000	873.92	(N/A)	1
W-14	0.000	873.47	(N/A)	1
W-15	0.000	873.76	(N/A)	1
W-16	0.000	874.05	(N/A)	1
W-19	0.000	874.10	(N/A)	1
W-20	0.000	874.36	(N/A)	1
W-26	0.000	876.16	(N/A)	1
W-27	0.000	877.65	(N/A)	1
W-30	0.000	874.31	(N/A)	1
W-1	0.000	874.50	(N/A)	1
W-2	0.000	874.50	(N/A)	1
W-3	0.000	874.24	(N/A)	1
W-4	0.000	874.12	(N/A)	1
W-5	0.000	874.37	(N/A)	1
W-6	0.000	873.72	(N/A)	1
W-7	0.000	874.50	(N/A)	1
W-8	0.000	874.50	(N/A)	1
W-9	0.000	873.85	(N/A)	1
W-10	0.000	874.50	(N/A)	1
W-12	0.000	873.62	(N/A)	1
W-17	0.000	874.24	(N/A)	1
W-18	0.000	875.28	(N/A)	1
W-21	0.000	873.51	(N/A)	1
W-22	0.000	873.78	(N/A)	1
W-23	0.000	873.98	(N/A)	1
W-24	0.000	874.24	(N/A)	1
W-25	0.000	875.24	(N/A)	1
W-28	0.000	873.87	(N/A)	1

Detailed Calculation Summary (Huxley Sewer Model.stsw, 20 Pumps On)

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
W-29	0.000	874.03	(N/A)	1
W-31	0.000	875.84	(N/A)	1
W-32	0.000	877.11	(N/A)	1
W-33	0.000	878.00	(N/A)	1
W-34	0.000	874.50	(N/A)	1
W-35	0.000	874.50	(N/A)	1
W-36	0.000	874.50	(N/A)	1
W-37	0.000	876.22	(N/A)	1
W-38	0.000	875.53	(N/A)	1
W-39	0.000	876.85	(N/A)	1
W-40	0.000	874.50	(N/A)	1
W-41	0.000	877.22	(N/A)	1
AV-3	0.000	867.18	(N/A)	0
MH-1	0.000	(N/A)	(N/A)	0
J-16	0.000	866.84	(N/A)	0

Scenario: 25 Pumps On



Color Coding Legend
Pump: Status (Initial)

	= On
	= Off

Color Coding Legend
Pressure Pipe: Velocity (m/s)

	≤ 0.01
	≤ 1.50
	≤ 3.00
	Other

Scenario: 25 Pumps On



Color Coding Legend	
Pump: Status (Initial)	
	= On
	= Off

Color Coding Legend	
Pressure Pipe: Velocity (m/s)	
	<= 0.01
	<= 1.50
	<= 3.00
	Other

NW17 34-23-4

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps On)

Executive Summary

Scenario	
Label	25 Pumps On
Computation Results	
Subnetwork Results	Number of Gravity Subnetworks: 1 Number of Pressure Subnetworks: 1
	>>>> Info: Pressure subnetwork flowing to: MH-1 >>>> Info: Pressure analysis iterations: 12 >>>> Info: Convergence was achieved.
	>>>> Info: Gravity subnetwork draining to: O-8 >>>> Info: Convergence was achieved.

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps On)

Calculation Options

<General>			
Label	Base Calculation Options	Calculation Type	Analysis
Time Analysis Type	Steady State		
Gravity Hydraulics			
Maximum Network Traversals	5	Governing Upstream Pipe Selection Method	Pipe with Maximum QV
Flow Convergence Test	0.001	Structure Loss Mode	Hydraulic Grade
Tractive Stress (Global Minimum)	0.000 Pascals	Report Hydrologic Time Step?	True
Flow Profile Method	Backwater Analysis	Save Detailed Headloss Data?	False
Number of Flow Profile Steps	5	Gravity Friction Method	Manning's Water at 20C (68F)
Hydraulic Grade Convergence Test	0.00 m	Liquid Label	
Average Velocity Method	Actual Uniform Flow Velocity	Use Explicit Depth and Slope Equations?	False
Minimum Structure Headloss	0.00 m		
Pressure			
Peak Flow Ratio	75.0 %	Pattern Setup	<None>
Extreme Flow Setup	<None>	Steady State Hydrograph Equivalent	Peak
Pressure Hydraulics			
Use Controls During Steady State?	True	Use Linear Interpolation For Multipoint Pumps?	False
Wet Well Convergence Increment	0.2 m	Use Controls During Steady State?	True
Use Pumped Flows?	True	Liquid Specific Gravity	0.998
Pressure Subnetwork Accuracy	0.001	Pressure Subnetwork Minimum Possible Pressure	-14 psi
Pressure Subnetwork Trials	40	Pressure Friction Method	Hazen-Williams
SWMM Hydrology			
Default Infiltration Method	Horton	SWMM Hydrologic Increment	0.250 hours
Headloss (AASHTO)			
Expansion, Ke	0.350	Shaping Adjustment, Cs	0.500
Contraction, Kc	0.250	Non-Piped Flow Adjustment, Cn	1.300

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps On)

Bend Angle vs. Bend Loss Curve

Bend Angle (degrees)	Bend Loss Coefficient, Kb
0.00	0.000
15.00	0.190
30.00	0.350
45.00	0.470
60.00	0.560
75.00	0.640
90.00	0.700

HEC-22 Energy Losses

Consider Non-Piped Plunging Flow?	True
-----------------------------------	------

HEC-22 Energy Losses (Second Edition)

Elevations Considered Equal Within	0.15 m	Half Bench Submerged Factor	0.950
Flat Unsubmerged Factor	1.000	Full Bench Unsubmerged Factor	0.070
Flat Submerged Factor	1.000	Full Bench Submerged Factor	0.750
Depressed Unsubmerged Factor	1.000	Improved Bench Unsubmerged Factor	0.035
Depressed Submerged Factor	1.000	Improved Bench Submerged Factor	0.375
Half Bench Unsubmerged Factor	0.150		

HEC-22 Energy Losses (Third Edition)

Flat Submerged Coefficient	-0.050	Half Bench Unsubmerged Coefficient	-0.850
Flat Unsubmerged Coefficient	-0.050	Full Bench Submerged Coefficient	-0.250
Depressed Submerged Coefficient	0.000	Full Bench Unsubmerged Coefficient	-0.930
Depressed Unsubmerged Coefficient	0.000	Improved Submerged Coefficient	-0.600
Half Bench Submerged Coefficient	-0.050	Improved Unsubmerged Coefficient	-0.980

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps On)

Calculation Summary (503: 25 Pumps On)

Time (hours)	Balanced?	Trials	Relative Flow Change
All Time Steps (1)	True	12	0.0001179
0.00	True	12	0.0001179

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps On)

Pipe Report

Subnetwork Summary

Subnetwork Gravity
Subnetwork Subnetwork

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-3	0.000	8.19	4.40	(N/A)
P-4	0.000	4.35	2.33	(N/A)
P-118	0.000	3.84	2.06	(N/A)
P-18	0.000	8.19	2.02	(N/A)
P-139	0.000	8.19	2.02	(N/A)
P-17	0.000	8.19	2.02	(N/A)
P-120	0.000	3.36	1.80	(N/A)
P-119	0.000	3.36	1.80	(N/A)
P-121	0.000	2.94	1.58	(N/A)
P-122	0.000	2.54	1.36	(N/A)
P-123	0.000	2.18	1.17	(N/A)
P-10	0.000	2.17	1.17	(N/A)
P-2	0.000	2.15	1.16	(N/A)
P-124	0.000	1.83	0.98	(N/A)
P-104	0.000	1.54	0.82	(N/A)
P-125	0.000	1.50	0.81	(N/A)
P-5	0.000	1.44	0.77	(N/A)
P-88	0.000	1.44	0.77	(N/A)
P-8	0.000	1.26	0.67	(N/A)
P-131	0.000	1.24	0.67	(N/A)
P-130	0.000	1.24	0.67	(N/A)
P-126	0.000	1.17	0.63	(N/A)
P-132	0.000	0.98	0.53	(N/A)
P-111	0.000	0.93	0.50	(N/A)
P-137	0.000	0.93	0.50	(N/A)
P-11	0.000	0.93	0.50	(N/A)
P-138	0.000	0.93	0.50	(N/A)
P-6	0.000	0.85	0.46	(N/A)
P-129	0.000	0.85	0.46	(N/A)
P-128	0.000	0.85	0.46	(N/A)
P-127	0.000	0.85	0.45	(N/A)
P-106	0.000	0.75	0.40	(N/A)
P-105	0.000	0.75	0.40	(N/A)
P-133	0.000	0.72	0.39	(N/A)
P-87	0.000	0.72	0.38	(N/A)
P-1	0.000	0.72	0.38	(N/A)
P-117	0.000	0.68	0.36	(N/A)
P-116	0.000	0.68	0.36	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps On)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-136	0.000	0.67	0.36	(N/A)
P-112	0.000	0.64	0.35	(N/A)
P-12	0.000	0.52	0.28	(N/A)
P-29	0.000	0.49	0.26	(N/A)
P-135	0.000	0.46	0.25	(N/A)
P-134	0.000	0.46	0.25	(N/A)
P-25	0.000	0.42	0.22	(N/A)
P-13	0.000	0.42	0.22	(N/A)
P-23	0.000	0.40	0.21	(N/A)
P-24	0.000	0.39	0.21	(N/A)
P-107	0.000	0.38	0.21	(N/A)
P-110	0.000	0.38	0.21	(N/A)
P-93	0.000	0.36	0.19	(N/A)
P-16	0.000	0.36	0.19	(N/A)
P-100	0.000	0.36	0.19	(N/A)
P-60	0.000	0.36	0.19	(N/A)
P-115	0.000	0.35	0.19	(N/A)
P-80	0.000	0.35	0.19	(N/A)
P-114	0.000	0.35	0.19	(N/A)
P-113	0.000	0.35	0.19	(N/A)
P-14	0.000	0.35	0.19	(N/A)
P-83	0.000	0.35	0.19	(N/A)
P-67	0.000	0.34	0.18	(N/A)
P-65	0.000	0.33	0.18	(N/A)
P-68	0.000	0.33	0.18	(N/A)
P-82	0.000	0.33	0.18	(N/A)
P-66	0.000	0.33	0.18	(N/A)
P-96	0.000	0.29	0.16	(N/A)
P-78	0.000	0.29	0.15	(N/A)
P-99	0.000	0.28	0.15	(N/A)
P-73	0.000	0.27	0.14	(N/A)
P-72	0.000	0.26	0.14	(N/A)
P-84	0.000	0.26	0.14	(N/A)
P-89	0.000	0.26	0.14	(N/A)
P-75	0.000	0.26	0.14	(N/A)
P-76	0.000	0.26	0.14	(N/A)
P-103	0.000	0.26	0.14	(N/A)
P-102	0.000	0.25	0.14	(N/A)
P-9	0.000	0.20	0.10	(N/A)
P-28	0.000	0.49	0.00	(N/A)
P-26	0.000	0.42	0.00	(N/A)
P-22	0.000	0.40	0.00	(N/A)
P-27	0.000	0.39	0.00	(N/A)
P-109	0.000	0.38	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps On)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-92	0.000	0.36	0.00	(N/A)
P-19	0.000	0.36	0.00	(N/A)
P-30	0.000	0.36	0.00	(N/A)
P-50	0.000	0.35	0.00	(N/A)
P-56	0.000	0.35	0.00	(N/A)
P-37	0.000	0.34	0.00	(N/A)
P-35	0.000	0.33	0.00	(N/A)
P-38	0.000	0.33	0.00	(N/A)
P-55	0.000	0.33	0.00	(N/A)
P-36	0.000	0.33	0.00	(N/A)
P-94	0.000	0.29	0.00	(N/A)
P-48	0.000	0.29	0.00	(N/A)
P-98	0.000	0.28	0.00	(N/A)
P-43	0.000	0.27	0.00	(N/A)
P-42	0.000	0.26	0.00	(N/A)
P-57	0.000	0.26	0.00	(N/A)
P-45	0.000	0.26	0.00	(N/A)
P-46	0.000	0.26	0.00	(N/A)
P-53	0.000	0.26	0.00	(N/A)
P-52	0.000	0.25	0.00	(N/A)
P-90	0.000	0.00	0.00	(N/A)
P-91	0.000	0.00	0.00	(N/A)
P-15	0.000	0.00	0.00	(N/A)
P-101	0.000	0.00	0.00	(N/A)
P-85	0.000	0.00	0.00	(N/A)
P-86	0.000	0.00	0.00	(N/A)
P-74	0.000	0.00	0.00	(N/A)
P-77	0.000	0.00	0.00	(N/A)
P-81	0.000	0.00	0.00	(N/A)
P-79	0.000	0.00	0.00	(N/A)
P-69	0.000	0.00	0.00	(N/A)
P-70	0.000	0.00	0.00	(N/A)
P-64	0.000	0.00	0.00	(N/A)
P-97	0.000	0.00	0.00	(N/A)
P-71	0.000	0.00	0.00	(N/A)
P-61	0.000	0.00	0.00	(N/A)
P-63	0.000	0.00	0.00	(N/A)
P-21	0.000	0.00	0.00	(N/A)
P-62	0.000	0.00	0.00	(N/A)
P-32	0.000	0.00	0.00	(N/A)
P-31	0.000	0.00	0.00	(N/A)
P-33	0.000	0.00	0.00	(N/A)
P-20	0.000	0.00	0.00	(N/A)
P-58	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps On)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-59	0.000	0.00	0.00	(N/A)
P-54	0.000	0.00	0.00	(N/A)
P-95	0.000	0.00	0.00	(N/A)
P-39	0.000	0.00	0.00	(N/A)
P-41	0.000	0.00	0.00	(N/A)
P-34	0.000	0.00	0.00	(N/A)
P-40	0.000	0.00	0.00	(N/A)
P-44	0.000	0.00	0.00	(N/A)
P-47	0.000	0.00	0.00	(N/A)
P-7	0.000	0.00	0.00	(N/A)
P-51	0.000	0.00	0.00	(N/A)
P-49	0.000	0.00	0.00	(N/A)
P-108	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps On)

Node Report

Subnetwork Summary

Subnetwork Gravity
Subnetwork Subnetwork

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
J-10	0.000	944.14	(N/A)	101
J-53	0.000	944.85	(N/A)	101
J-52	0.000	944.99	(N/A)	101
J-51	0.000	945.12	(N/A)	101
J-47	0.000	944.75	(N/A)	100
J-46	0.000	944.55	(N/A)	100
J-48	0.000	944.83	(N/A)	100
J-13	0.000	945.22	(N/A)	100
J-19	0.000	945.22	(N/A)	100
J-20	0.000	945.22	(N/A)	100
J-21	0.000	945.22	(N/A)	100
J-11	0.000	945.16	(N/A)	100
J-45	0.000	944.14	(N/A)	100
J-49	0.000	944.86	(N/A)	100
J-50	0.000	944.89	(N/A)	100
J-8	0.000	944.90	(N/A)	100
J-9	0.000	943.37	(N/A)	100
J-22	0.000	944.65	(N/A)	100
J-26	0.000	945.17	(N/A)	99
J-27	0.000	945.23	(N/A)	99
J-31	0.000	945.43	(N/A)	99
J-28	0.000	945.27	(N/A)	98
J-41	0.000	942.52	(N/A)	97
J-32	0.000	945.69	(N/A)	97
J-42	0.000	942.62	(N/A)	97
J-40	0.000	942.29	(N/A)	97
J-43	0.000	942.77	(N/A)	97
J-44	0.000	942.88	(N/A)	97
J-5	0.000	942.97	(N/A)	97
J-29	0.000	945.31	(N/A)	97
J-39	0.000	941.97	(N/A)	97
J-38	0.000	941.48	(N/A)	97
J-23	0.000	943.17	(N/A)	96
J-12	0.000	945.74	(N/A)	96
J-30	0.000	945.36	(N/A)	96
J-7	0.000	945.36	(N/A)	96
J-14	0.000	941.84	(N/A)	96
J-17	0.000	941.79	(N/A)	96

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps On)

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
J-24	0.000	943.40	(N/A)	95
J-1	0.000	941.65	(N/A)	95
J-18	0.000	941.50	(N/A)	95
J-2	0.000	941.17	(N/A)	95
J-4	0.000	939.51	(N/A)	94
J-25	0.000	943.47	(N/A)	94
J-37	0.000	940.58	(N/A)	94
J-36	0.000	939.76	(N/A)	93
J-6	0.000	943.47	(N/A)	93
J-35	0.000	938.78	(N/A)	92
J-34	0.000	936.20	(N/A)	89
J-33	0.000	934.81	(N/A)	87
J-3	0.000	926.10	(N/A)	75
J-15	0.000	885.64	(N/A)	19
W-11	0.000	874.39	(N/A)	1
W-13	0.000	873.92	(N/A)	1
W-14	0.000	873.47	(N/A)	1
W-15	0.000	873.76	(N/A)	1
W-16	0.000	874.05	(N/A)	1
W-19	0.000	874.10	(N/A)	1
W-20	0.000	874.36	(N/A)	1
W-26	0.000	876.16	(N/A)	1
W-27	0.000	877.65	(N/A)	1
W-30	0.000	874.31	(N/A)	1
W-1	0.000	874.50	(N/A)	1
W-2	0.000	874.50	(N/A)	1
W-3	0.000	874.24	(N/A)	1
W-4	0.000	874.12	(N/A)	1
W-5	0.000	874.37	(N/A)	1
W-6	0.000	873.72	(N/A)	1
W-7	0.000	874.50	(N/A)	1
W-8	0.000	874.50	(N/A)	1
W-9	0.000	873.85	(N/A)	1
W-10	0.000	874.50	(N/A)	1
W-12	0.000	873.62	(N/A)	1
W-17	0.000	874.24	(N/A)	1
W-18	0.000	875.28	(N/A)	1
W-21	0.000	873.51	(N/A)	1
W-22	0.000	873.78	(N/A)	1
W-23	0.000	873.98	(N/A)	1
W-24	0.000	874.24	(N/A)	1
W-25	0.000	875.24	(N/A)	1
W-28	0.000	873.87	(N/A)	1
W-29	0.000	874.03	(N/A)	1

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps On)

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
W-31	0.000	875.84	(N/A)	1
W-32	0.000	877.11	(N/A)	1
W-33	0.000	878.00	(N/A)	1
W-34	0.000	874.50	(N/A)	1
W-35	0.000	874.50	(N/A)	1
W-36	0.000	874.50	(N/A)	1
W-37	0.000	876.22	(N/A)	1
W-38	0.000	875.53	(N/A)	1
W-39	0.000	876.85	(N/A)	1
W-40	0.000	874.50	(N/A)	1
W-41	0.000	877.22	(N/A)	1
AV-3	0.000	867.24	(N/A)	0
MH-1	0.000	(N/A)	(N/A)	0
J-16	0.000	866.89	(N/A)	0

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps On)

Pond Report

Subnetwork Summary

Subnetwork Gravity
Subnetwork Subnetwork

Pond Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)
-------	---	-------------------------------

Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On - 3/8 HP)

Executive Summary

Scenario	
Label	5 Pumps On - 3/8 HP

Computation Results	
Subnetwork Results	Number of Gravity Subnetworks: 1 Number of Pressure Subnetworks: 1 >>>> Info: Pressure subnetwork flowing to: MH-1 >>>> Info: Pressure analysis iterations: 11 >>>> Info: Convergence was achieved. >>>> Info: Gravity subnetwork draining to: O-8 >>>> Info: Convergence was achieved.

Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On - 3/8 HP)

Calculation Options

<General>			
Label	Base Calculation Options	Calculation Type	Analysis
Time Analysis Type	Steady State		
Gravity Hydraulics			
Maximum Network Traversals	5	Governing Upstream Pipe Selection Method	Pipe with Maximum QV
Flow Convergence Test	0.001	Structure Loss Mode	Hydraulic Grade
Tractive Stress (Global Minimum)	0.000 Pascals	Report Hydrologic Time Step?	True
Flow Profile Method	Backwater Analysis	Save Detailed Headloss Data?	False
Number of Flow Profile Steps	5	Gravity Friction Method	Manning's
Hydraulic Grade Convergence Test	0.00 m	Liquid Label	Water at 20C (68F)
Average Velocity Method	Actual Uniform Flow Velocity	Use Explicit Depth and Slope Equations?	False
Minimum Structure Headloss	0.00 m		
Pressure			
Peak Flow Ratio	75.0 %	Pattern Setup	<None>
Extreme Flow Setup	<None>	Steady State Hydrograph Equivalent	Peak
Pressure Hydraulics			
Use Controls During Steady State?	True	Use Linear Interpolation For Multipoint Pumps?	False
Wet Well Convergence Increment	0.2 m	Use Controls During Steady State?	True
Use Pumped Flows?	True	Liquid Specific Gravity	0.998
Pressure Subnetwork Accuracy	0.001	Pressure Subnetwork Minimum Possible Pressure	-14 psi
Pressure Subnetwork Trials	40	Pressure Friction Method	Hazen-Williams
SWMM Hydrology			
Default Infiltration Method	Horton	SWMM Hydrologic Increment	0.250 hours
Headloss (AASHTO)			
Expansion, Ke	0.350	Shaping Adjustment, Cs	0.500
Contraction, Kc	0.250	Non-Piped Flow Adjustment, Cn	1.300

Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On - 3/8 HP)

Bend Angle vs. Bend Loss Curve

Bend Angle (degrees)	Bend Loss Coefficient, Kb
0.00	0.000
15.00	0.190
30.00	0.350
45.00	0.470
60.00	0.560
75.00	0.640
90.00	0.700

HEC-22 Energy Losses

Consider Non-Piped Plunging Flow?	True
-----------------------------------	------

HEC-22 Energy Losses (Second Edition)

Elevations Considered Equal Within	0.15 m	Half Bench Submerged Factor	0.950
Flat Unsubmerged Factor	1.000	Full Bench Unsubmerged Factor	0.070
Flat Submerged Factor	1.000	Full Bench Submerged Factor	0.750
Depressed Unsubmerged Factor	1.000	Improved Bench Unsubmerged Factor	0.035
Depressed Submerged Factor	1.000	Improved Bench Submerged Factor	0.375
Half Bench Unsubmerged Factor	0.150		

HEC-22 Energy Losses (Third Edition)

Flat Submerged Coefficient	-0.050	Half Bench Unsubmerged Coefficient	-0.850
Flat Unsubmerged Coefficient	-0.050	Full Bench Submerged Coefficient	-0.250
Depressed Submerged Coefficient	0.000	Full Bench Unsubmerged Coefficient	-0.930
Depressed Unsubmerged Coefficient	0.000	Improved Submerged Coefficient	-0.600
Half Bench Submerged Coefficient	-0.050	Improved Unsubmerged Coefficient	-0.980

Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On
- 3/8 HP)

Calculation Summary (498: 5 Pumps On - 3/8 HP)

Time (hours)	Balanced?	Trials	Relative Flow Change
All Time Steps (0)	True	11	0.0001480
0.00	True	11	0.0001480

Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On - 3/8 HP)

Pipe Report

Subnetwork Summary

Subnetwork Gravity
Subnetwork

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-3	0.000	4.48	2.41	(N/A)
P-4	0.000	2.43	1.30	(N/A)
P-17	0.000	4.48	1.11	(N/A)
P-18	0.000	4.48	1.11	(N/A)
P-139	0.000	4.48	1.11	(N/A)
P-2	0.000	2.05	1.10	(N/A)
P-122	0.000	2.05	1.10	(N/A)
P-121	0.000	2.05	1.10	(N/A)
P-120	0.000	2.05	1.10	(N/A)
P-119	0.000	2.05	1.10	(N/A)
P-118	0.000	2.05	1.10	(N/A)
P-127	0.000	1.22	0.66	(N/A)
P-126	0.000	1.22	0.66	(N/A)
P-125	0.000	1.22	0.66	(N/A)
P-124	0.000	1.22	0.66	(N/A)
P-123	0.000	1.22	0.66	(N/A)
P-10	0.000	1.20	0.65	(N/A)
P-88	0.000	1.16	0.62	(N/A)
P-79	0.000	0.91	0.49	(N/A)
P-113	0.000	0.91	0.49	(N/A)
P-112	0.000	0.91	0.49	(N/A)
P-111	0.000	0.91	0.49	(N/A)
P-63	0.000	0.90	0.48	(N/A)
P-69	0.000	0.89	0.48	(N/A)
P-61	0.000	0.89	0.48	(N/A)
P-1	0.000	0.89	0.48	(N/A)
P-84	0.000	0.88	0.47	(N/A)
P-89	0.000	0.88	0.47	(N/A)
P-9	0.000	0.64	0.35	(N/A)
P-135	0.000	0.64	0.35	(N/A)
P-134	0.000	0.64	0.35	(N/A)
P-133	0.000	0.64	0.35	(N/A)
P-132	0.000	0.64	0.35	(N/A)
P-131	0.000	0.64	0.35	(N/A)
P-130	0.000	0.64	0.35	(N/A)
P-8	0.000	0.59	0.32	(N/A)
P-104	0.000	0.59	0.32	(N/A)
P-13	0.000	0.56	0.30	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On - 3/8 HP)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-136	0.000	0.56	0.30	(N/A)
P-137	0.000	0.56	0.30	(N/A)
P-11	0.000	0.56	0.30	(N/A)
P-138	0.000	0.56	0.30	(N/A)
P-6	0.000	0.33	0.18	(N/A)
P-129	0.000	0.33	0.18	(N/A)
P-128	0.000	0.33	0.18	(N/A)
P-12	0.000	0.32	0.17	(N/A)
P-5	0.000	0.26	0.14	(N/A)
P-49	0.000	0.91	0.00	(N/A)
P-33	0.000	0.90	0.00	(N/A)
P-39	0.000	0.89	0.00	(N/A)
P-31	0.000	0.89	0.00	(N/A)
P-57	0.000	0.88	0.00	(N/A)
P-105	0.000	0.00	0.00	(N/A)
P-116	0.000	0.00	0.00	(N/A)
P-90	0.000	0.00	0.00	(N/A)
P-87	0.000	0.00	0.00	(N/A)
P-114	0.000	0.00	0.00	(N/A)
P-106	0.000	0.00	0.00	(N/A)
P-117	0.000	0.00	0.00	(N/A)
P-86	0.000	0.00	0.00	(N/A)
P-85	0.000	0.00	0.00	(N/A)
P-91	0.000	0.00	0.00	(N/A)
P-74	0.000	0.00	0.00	(N/A)
P-101	0.000	0.00	0.00	(N/A)
P-102	0.000	0.00	0.00	(N/A)
P-75	0.000	0.00	0.00	(N/A)
P-76	0.000	0.00	0.00	(N/A)
P-103	0.000	0.00	0.00	(N/A)
P-72	0.000	0.00	0.00	(N/A)
P-77	0.000	0.00	0.00	(N/A)
P-16	0.000	0.00	0.00	(N/A)
P-60	0.000	0.00	0.00	(N/A)
P-100	0.000	0.00	0.00	(N/A)
P-73	0.000	0.00	0.00	(N/A)
P-66	0.000	0.00	0.00	(N/A)
P-99	0.000	0.00	0.00	(N/A)
P-68	0.000	0.00	0.00	(N/A)
P-70	0.000	0.00	0.00	(N/A)
P-65	0.000	0.00	0.00	(N/A)
P-64	0.000	0.00	0.00	(N/A)
P-67	0.000	0.00	0.00	(N/A)
P-78	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On - 3/8 HP)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-21	0.000	0.00	0.00	(N/A)
P-96	0.000	0.00	0.00	(N/A)
P-24	0.000	0.00	0.00	(N/A)
P-71	0.000	0.00	0.00	(N/A)
P-81	0.000	0.00	0.00	(N/A)
P-23	0.000	0.00	0.00	(N/A)
P-97	0.000	0.00	0.00	(N/A)
P-25	0.000	0.00	0.00	(N/A)
P-93	0.000	0.00	0.00	(N/A)
P-82	0.000	0.00	0.00	(N/A)
P-80	0.000	0.00	0.00	(N/A)
P-115	0.000	0.00	0.00	(N/A)
P-62	0.000	0.00	0.00	(N/A)
P-29	0.000	0.00	0.00	(N/A)
P-110	0.000	0.00	0.00	(N/A)
P-107	0.000	0.00	0.00	(N/A)
P-83	0.000	0.00	0.00	(N/A)
P-14	0.000	0.00	0.00	(N/A)
P-53	0.000	0.00	0.00	(N/A)
P-30	0.000	0.00	0.00	(N/A)
P-19	0.000	0.00	0.00	(N/A)
P-98	0.000	0.00	0.00	(N/A)
P-94	0.000	0.00	0.00	(N/A)
P-20	0.000	0.00	0.00	(N/A)
P-54	0.000	0.00	0.00	(N/A)
P-58	0.000	0.00	0.00	(N/A)
P-59	0.000	0.00	0.00	(N/A)
P-95	0.000	0.00	0.00	(N/A)
P-37	0.000	0.00	0.00	(N/A)
P-32	0.000	0.00	0.00	(N/A)
P-41	0.000	0.00	0.00	(N/A)
P-34	0.000	0.00	0.00	(N/A)
P-43	0.000	0.00	0.00	(N/A)
P-48	0.000	0.00	0.00	(N/A)
P-51	0.000	0.00	0.00	(N/A)
P-38	0.000	0.00	0.00	(N/A)
P-27	0.000	0.00	0.00	(N/A)
P-55	0.000	0.00	0.00	(N/A)
P-109	0.000	0.00	0.00	(N/A)
P-46	0.000	0.00	0.00	(N/A)
P-52	0.000	0.00	0.00	(N/A)
P-42	0.000	0.00	0.00	(N/A)
P-44	0.000	0.00	0.00	(N/A)
P-47	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On - 3/8 HP)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-36	0.000	0.00	0.00	(N/A)
P-40	0.000	0.00	0.00	(N/A)
P-26	0.000	0.00	0.00	(N/A)
P-22	0.000	0.00	0.00	(N/A)
P-35	0.000	0.00	0.00	(N/A)
P-28	0.000	0.00	0.00	(N/A)
P-50	0.000	0.00	0.00	(N/A)
P-56	0.000	0.00	0.00	(N/A)
P-92	0.000	0.00	0.00	(N/A)
P-45	0.000	0.00	0.00	(N/A)
P-15	0.000	0.00	0.00	(N/A)
P-108	0.000	0.00	0.00	(N/A)
P-7	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On - 3/8 HP)

Node Report

Subnetwork Summary

Subnetwork	Gravity Subnetwork
------------	-----------------------

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
J-10	0.000	892.40	(N/A)	28
J-9	0.000	892.10	(N/A)	27
J-13	0.000	893.54	(N/A)	27
J-19	0.000	893.54	(N/A)	27
J-20	0.000	893.54	(N/A)	27
J-21	0.000	893.54	(N/A)	27
J-45	0.000	892.33	(N/A)	27
J-53	0.000	892.68	(N/A)	27
J-52	0.000	892.74	(N/A)	27
J-46	0.000	892.44	(N/A)	26
J-47	0.000	892.54	(N/A)	26
J-51	0.000	892.83	(N/A)	26
J-48	0.000	892.60	(N/A)	26
J-49	0.000	892.66	(N/A)	26
J-11	0.000	892.89	(N/A)	26
J-1	0.000	892.87	(N/A)	26
J-14	0.000	892.87	(N/A)	26
J-17	0.000	892.87	(N/A)	26
J-50	0.000	892.72	(N/A)	26
J-42	0.000	892.38	(N/A)	26
J-8	0.000	892.78	(N/A)	26
J-41	0.000	892.18	(N/A)	26
J-22	0.000	892.72	(N/A)	26
J-40	0.000	891.93	(N/A)	26
J-43	0.000	892.41	(N/A)	26
J-39	0.000	891.71	(N/A)	26
J-44	0.000	892.43	(N/A)	26
J-38	0.000	891.48	(N/A)	26
J-5	0.000	892.44	(N/A)	25
J-18	0.000	892.38	(N/A)	25
J-26	0.000	893.05	(N/A)	25
J-4	0.000	890.81	(N/A)	25
J-2	0.000	892.16	(N/A)	25
J-27	0.000	893.16	(N/A)	25
J-37	0.000	891.62	(N/A)	24
J-28	0.000	893.38	(N/A)	24
J-23	0.000	892.44	(N/A)	24
J-31	0.000	892.89	(N/A)	24

Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On - 3/8 HP)

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
J-36	0.000	891.06	(N/A)	24
J-29	0.000	893.38	(N/A)	23
J-35	0.000	890.56	(N/A)	23
J-24	0.000	892.44	(N/A)	23
J-32	0.000	892.89	(N/A)	22
J-30	0.000	893.38	(N/A)	22
J-34	0.000	889.53	(N/A)	22
J-7	0.000	893.38	(N/A)	22
J-33	0.000	888.97	(N/A)	22
J-25	0.000	892.44	(N/A)	22
J-12	0.000	892.89	(N/A)	21
J-6	0.000	892.44	(N/A)	20
J-3	0.000	886.25	(N/A)	19
J-15	0.000	873.04	(N/A)	1
W-11	0.000	874.39	(N/A)	1
W-13	0.000	873.92	(N/A)	1
W-14	0.000	873.47	(N/A)	1
W-15	0.000	873.76	(N/A)	1
W-16	0.000	874.05	(N/A)	1
W-19	0.000	874.10	(N/A)	1
W-20	0.000	874.36	(N/A)	1
W-26	0.000	876.16	(N/A)	1
W-27	0.000	877.65	(N/A)	1
W-30	0.000	874.31	(N/A)	1
W-1	0.000	874.50	(N/A)	1
W-2	0.000	874.50	(N/A)	1
W-3	0.000	874.24	(N/A)	1
W-4	0.000	874.12	(N/A)	1
W-5	0.000	874.37	(N/A)	1
W-6	0.000	873.72	(N/A)	1
W-7	0.000	874.50	(N/A)	1
W-8	0.000	874.50	(N/A)	1
W-9	0.000	873.85	(N/A)	1
W-10	0.000	874.50	(N/A)	1
W-12	0.000	873.62	(N/A)	1
W-17	0.000	874.24	(N/A)	1
W-18	0.000	875.28	(N/A)	1
W-21	0.000	873.51	(N/A)	1
W-22	0.000	873.78	(N/A)	1
W-23	0.000	873.98	(N/A)	1
W-24	0.000	874.24	(N/A)	1
W-25	0.000	875.24	(N/A)	1
W-28	0.000	873.87	(N/A)	1
W-29	0.000	874.03	(N/A)	1

Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On - 3/8 HP)

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
W-31	0.000	875.84	(N/A)	1
W-32	0.000	877.11	(N/A)	1
W-33	0.000	878.00	(N/A)	1
W-34	0.000	874.50	(N/A)	1
W-35	0.000	874.50	(N/A)	1
W-36	0.000	874.50	(N/A)	1
W-37	0.000	876.22	(N/A)	1
W-38	0.000	875.53	(N/A)	1
W-39	0.000	876.85	(N/A)	1
W-40	0.000	874.50	(N/A)	1
W-41	0.000	877.22	(N/A)	1
MH-1	0.000	(N/A)	(N/A)	0
AV-3	0.000	867.02	(N/A)	0
J-16	0.000	866.33	(N/A)	-1

Detailed Calculation Summary (Huxley Sewer Model.stsw, 5 Pumps On - 3/8 HP)

Pond Report

Subnetwork Summary

Subnetwork	Gravity Subnetwork
------------	-----------------------

Pond Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)
-------	--	-------------------------------------

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps On - 3/8 HP)

Executive Summary

Scenario	
Label	10 Pumps On - 3/8 HP

Computation Results	
Subnetwork Results	Number of Gravity Subnetworks: 1 Number of Pressure Subnetworks: 1 >>>> Info: Pressure subnetwork flowing to: MH-1 >>>> Info: Pressure analysis iterations: 11 >>>> Info: Convergence was achieved. >>>> Info: Gravity subnetwork draining to: O-8 >>>> Info: Convergence was achieved.

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps On - 3/8 HP)

Calculation Options

<General>			
Label	Base Calculation Options	Calculation Type	Analysis
Time Analysis Type	Steady State		
Gravity Hydraulics			
Maximum Network Traversals	5	Governing Upstream Pipe Selection Method	Pipe with Maximum QV
Flow Convergence Test	0.001	Structure Loss Mode	Hydraulic Grade
Tractive Stress (Global Minimum)	0.000 Pascals	Report Hydrologic Time Step?	True
Flow Profile Method	Backwater Analysis	Save Detailed Headloss Data?	False
Number of Flow Profile Steps	5	Gravity Friction Method	Manning's
Hydraulic Grade Convergence Test	0.00 m	Liquid Label	Water at 20C (68F)
Average Velocity Method	Actual Uniform Flow Velocity	Use Explicit Depth and Slope Equations?	False
Minimum Structure Headloss	0.00 m		
Pressure			
Peak Flow Ratio	75.0 %	Pattern Setup	<None>
Extreme Flow Setup	<None>	Steady State Hydrograph Equivalent	Peak
Pressure Hydraulics			
Use Controls During Steady State?	True	Use Linear Interpolation For Multipoint Pumps?	False
Wet Well Convergence Increment	0.2 m	Use Controls During Steady State?	True
Use Pumped Flows?	True	Liquid Specific Gravity	0.998
Pressure Subnetwork Accuracy	0.001	Pressure Subnetwork Minimum Possible Pressure	-14 psi
Pressure Subnetwork Trials	40	Pressure Friction Method	Hazen-Williams
SWMM Hydrology			
Default Infiltration Method	Horton	SWMM Hydrologic Increment	0.250 hours
Headloss (AASHTO)			
Expansion, Ke	0.350	Shaping Adjustment, Cs	0.500
Contraction, Kc	0.250	Non-Piped Flow Adjustment, Cn	1.300

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps On - 3/8 HP)

Bend Angle vs. Bend Loss Curve

Bend Angle (degrees)	Bend Loss Coefficient, Kb
0.00	0.000
15.00	0.190
30.00	0.350
45.00	0.470
60.00	0.560
75.00	0.640
90.00	0.700

HEC-22 Energy Losses

Consider Non-Piped Plunging Flow?	True
-----------------------------------	------

HEC-22 Energy Losses (Second Edition)

Elevations Considered Equal Within	0.15 m	Half Bench Submerged Factor	0.950
Flat Unsubmerged Factor	1.000	Full Bench Unsubmerged Factor	0.070
Flat Submerged Factor	1.000	Full Bench Submerged Factor	0.750
Depressed Unsubmerged Factor	1.000	Improved Bench Unsubmerged Factor	0.035
Depressed Submerged Factor	1.000	Improved Bench Submerged Factor	0.375
Half Bench Unsubmerged Factor	0.150		

HEC-22 Energy Losses (Third Edition)

Flat Submerged Coefficient	-0.050	Half Bench Unsubmerged Coefficient	-0.850
Flat Unsubmerged Coefficient	-0.050	Full Bench Submerged Coefficient	-0.250
Depressed Submerged Coefficient	0.000	Full Bench Unsubmerged Coefficient	-0.930
Depressed Unsubmerged Coefficient	0.000	Improved Submerged Coefficient	-0.600
Half Bench Submerged Coefficient	-0.050	Improved Unsubmerged Coefficient	-0.980

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps On - 3/8 HP)

Calculation Summary (499: 10 Pumps On - 3/8 HP)

Time (hours)	Balanced?	Trials	Relative Flow Change
All Time Steps (1)	True	11	0.0001230
0.00	True	11	0.0001230

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps
On - 3/8 HP)
Pipe Report

Subnetwork Summary

Subnetwork Gravity
Subnetwork

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-3	0.000	5.95	3.19	(N/A)
P-4	0.000	3.31	1.78	(N/A)
P-17	0.000	5.95	1.47	(N/A)
P-18	0.000	5.95	1.47	(N/A)
P-139	0.000	5.95	1.47	(N/A)
P-122	0.000	2.64	1.42	(N/A)
P-121	0.000	2.64	1.42	(N/A)
P-120	0.000	2.64	1.42	(N/A)
P-119	0.000	2.64	1.42	(N/A)
P-118	0.000	2.64	1.42	(N/A)
P-2	0.000	2.01	1.08	(N/A)
P-10	0.000	1.78	0.95	(N/A)
P-126	0.000	1.54	0.83	(N/A)
P-125	0.000	1.54	0.83	(N/A)
P-124	0.000	1.54	0.83	(N/A)
P-123	0.000	1.54	0.83	(N/A)
P-5	0.000	1.39	0.75	(N/A)
P-88	0.000	1.39	0.75	(N/A)
P-105	0.000	1.21	0.65	(N/A)
P-111	0.000	1.18	0.63	(N/A)
P-8	0.000	1.13	0.61	(N/A)
P-104	0.000	1.13	0.61	(N/A)
P-133	0.000	0.97	0.52	(N/A)
P-132	0.000	0.97	0.52	(N/A)
P-131	0.000	0.97	0.52	(N/A)
P-130	0.000	0.97	0.52	(N/A)
P-6	0.000	0.95	0.51	(N/A)
P-129	0.000	0.95	0.51	(N/A)
P-128	0.000	0.95	0.51	(N/A)
P-127	0.000	0.95	0.51	(N/A)
P-137	0.000	0.81	0.43	(N/A)
P-11	0.000	0.81	0.43	(N/A)
P-138	0.000	0.81	0.43	(N/A)
P-24	0.000	0.63	0.34	(N/A)
P-61	0.000	0.62	0.33	(N/A)
P-1	0.000	0.62	0.33	(N/A)
P-93	0.000	0.61	0.33	(N/A)
P-106	0.000	0.61	0.33	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps On - 3/8 HP)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-82	0.000	0.61	0.33	(N/A)
P-117	0.000	0.61	0.33	(N/A)
P-116	0.000	0.61	0.33	(N/A)
P-97	0.000	0.60	0.32	(N/A)
P-114	0.000	0.60	0.32	(N/A)
P-113	0.000	0.60	0.32	(N/A)
P-112	0.000	0.60	0.32	(N/A)
P-71	0.000	0.60	0.32	(N/A)
P-66	0.000	0.59	0.32	(N/A)
P-78	0.000	0.58	0.31	(N/A)
P-72	0.000	0.56	0.30	(N/A)
P-102	0.000	0.56	0.30	(N/A)
P-9	0.000	0.41	0.22	(N/A)
P-135	0.000	0.41	0.22	(N/A)
P-134	0.000	0.41	0.22	(N/A)
P-12	0.000	0.36	0.19	(N/A)
P-13	0.000	0.25	0.13	(N/A)
P-136	0.000	0.25	0.13	(N/A)
P-27	0.000	0.63	0.00	(N/A)
P-31	0.000	0.62	0.00	(N/A)
P-92	0.000	0.61	0.00	(N/A)
P-55	0.000	0.61	0.00	(N/A)
P-95	0.000	0.60	0.00	(N/A)
P-41	0.000	0.60	0.00	(N/A)
P-36	0.000	0.59	0.00	(N/A)
P-48	0.000	0.58	0.00	(N/A)
P-42	0.000	0.56	0.00	(N/A)
P-52	0.000	0.56	0.00	(N/A)
P-89	0.000	0.00	0.00	(N/A)
P-90	0.000	0.00	0.00	(N/A)
P-87	0.000	0.00	0.00	(N/A)
P-101	0.000	0.00	0.00	(N/A)
P-74	0.000	0.00	0.00	(N/A)
P-75	0.000	0.00	0.00	(N/A)
P-76	0.000	0.00	0.00	(N/A)
P-103	0.000	0.00	0.00	(N/A)
P-77	0.000	0.00	0.00	(N/A)
P-85	0.000	0.00	0.00	(N/A)
P-84	0.000	0.00	0.00	(N/A)
P-86	0.000	0.00	0.00	(N/A)
P-91	0.000	0.00	0.00	(N/A)
P-73	0.000	0.00	0.00	(N/A)
P-99	0.000	0.00	0.00	(N/A)
P-96	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps On - 3/8 HP)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-81	0.000	0.00	0.00	(N/A)
P-79	0.000	0.00	0.00	(N/A)
P-69	0.000	0.00	0.00	(N/A)
P-70	0.000	0.00	0.00	(N/A)
P-64	0.000	0.00	0.00	(N/A)
P-68	0.000	0.00	0.00	(N/A)
P-65	0.000	0.00	0.00	(N/A)
P-67	0.000	0.00	0.00	(N/A)
P-80	0.000	0.00	0.00	(N/A)
P-115	0.000	0.00	0.00	(N/A)
P-16	0.000	0.00	0.00	(N/A)
P-60	0.000	0.00	0.00	(N/A)
P-100	0.000	0.00	0.00	(N/A)
P-63	0.000	0.00	0.00	(N/A)
P-21	0.000	0.00	0.00	(N/A)
P-14	0.000	0.00	0.00	(N/A)
P-83	0.000	0.00	0.00	(N/A)
P-110	0.000	0.00	0.00	(N/A)
P-107	0.000	0.00	0.00	(N/A)
P-23	0.000	0.00	0.00	(N/A)
P-25	0.000	0.00	0.00	(N/A)
P-62	0.000	0.00	0.00	(N/A)
P-29	0.000	0.00	0.00	(N/A)
P-19	0.000	0.00	0.00	(N/A)
P-30	0.000	0.00	0.00	(N/A)
P-33	0.000	0.00	0.00	(N/A)
P-20	0.000	0.00	0.00	(N/A)
P-32	0.000	0.00	0.00	(N/A)
P-43	0.000	0.00	0.00	(N/A)
P-34	0.000	0.00	0.00	(N/A)
P-37	0.000	0.00	0.00	(N/A)
P-53	0.000	0.00	0.00	(N/A)
P-57	0.000	0.00	0.00	(N/A)
P-58	0.000	0.00	0.00	(N/A)
P-59	0.000	0.00	0.00	(N/A)
P-98	0.000	0.00	0.00	(N/A)
P-94	0.000	0.00	0.00	(N/A)
P-54	0.000	0.00	0.00	(N/A)
P-39	0.000	0.00	0.00	(N/A)
P-28	0.000	0.00	0.00	(N/A)
P-26	0.000	0.00	0.00	(N/A)
P-22	0.000	0.00	0.00	(N/A)
P-35	0.000	0.00	0.00	(N/A)
P-50	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps
On - 3/8 HP)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-40	0.000	0.00	0.00	(N/A)
P-44	0.000	0.00	0.00	(N/A)
P-45	0.000	0.00	0.00	(N/A)
P-46	0.000	0.00	0.00	(N/A)
P-47	0.000	0.00	0.00	(N/A)
P-51	0.000	0.00	0.00	(N/A)
P-49	0.000	0.00	0.00	(N/A)
P-56	0.000	0.00	0.00	(N/A)
P-109	0.000	0.00	0.00	(N/A)
P-38	0.000	0.00	0.00	(N/A)
P-108	0.000	0.00	0.00	(N/A)
P-15	0.000	0.00	0.00	(N/A)
P-7	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps
On - 3/8 HP)
Node Report

Subnetwork Summary

Subnetwork Gravity
Subnetwork

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
J-10	0.000	910.95	(N/A)	54
J-53	0.000	911.50	(N/A)	53
J-52	0.000	911.61	(N/A)	53
J-9	0.000	910.36	(N/A)	53
J-45	0.000	910.85	(N/A)	53
J-48	0.000	911.43	(N/A)	53
J-46	0.000	911.10	(N/A)	53
J-47	0.000	911.30	(N/A)	53
J-51	0.000	911.63	(N/A)	53
J-49	0.000	911.46	(N/A)	53
J-11	0.000	911.64	(N/A)	53
J-13	0.000	911.64	(N/A)	53
J-19	0.000	911.64	(N/A)	53
J-20	0.000	911.64	(N/A)	53
J-21	0.000	911.64	(N/A)	53
J-50	0.000	911.48	(N/A)	53
J-8	0.000	911.51	(N/A)	53
J-22	0.000	911.31	(N/A)	52
J-26	0.000	911.93	(N/A)	52
J-27	0.000	911.98	(N/A)	52
J-31	0.000	911.86	(N/A)	51
J-28	0.000	912.08	(N/A)	51
J-41	0.000	909.80	(N/A)	51
J-42	0.000	909.92	(N/A)	51
J-43	0.000	910.10	(N/A)	51
J-5	0.000	910.35	(N/A)	51
J-44	0.000	910.24	(N/A)	51
J-40	0.000	909.42	(N/A)	51
J-23	0.000	910.83	(N/A)	50
J-39	0.000	909.08	(N/A)	50
J-29	0.000	912.20	(N/A)	50
J-38	0.000	908.73	(N/A)	50
J-32	0.000	912.08	(N/A)	50
J-24	0.000	910.99	(N/A)	49
J-4	0.000	907.69	(N/A)	49
J-30	0.000	912.20	(N/A)	49
J-1	0.000	909.01	(N/A)	49
J-14	0.000	909.01	(N/A)	49

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps On - 3/8 HP)

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
J-17	0.000	909.01	(N/A)	49
J-18	0.000	908.96	(N/A)	49
J-7	0.000	912.20	(N/A)	49
J-2	0.000	908.65	(N/A)	48
J-12	0.000	912.08	(N/A)	48
J-25	0.000	910.99	(N/A)	48
J-37	0.000	908.14	(N/A)	48
J-36	0.000	907.25	(N/A)	47
J-6	0.000	910.99	(N/A)	47
J-35	0.000	906.45	(N/A)	46
J-34	0.000	904.80	(N/A)	44
J-33	0.000	903.92	(N/A)	43
J-3	0.000	899.58	(N/A)	38
J-15	0.000	877.21	(N/A)	7
W-11	0.000	874.39	(N/A)	1
W-13	0.000	873.92	(N/A)	1
W-14	0.000	873.47	(N/A)	1
W-15	0.000	873.76	(N/A)	1
W-16	0.000	874.05	(N/A)	1
W-19	0.000	874.10	(N/A)	1
W-20	0.000	874.36	(N/A)	1
W-26	0.000	876.16	(N/A)	1
W-27	0.000	877.65	(N/A)	1
W-30	0.000	874.31	(N/A)	1
W-1	0.000	874.50	(N/A)	1
W-2	0.000	874.50	(N/A)	1
W-3	0.000	874.24	(N/A)	1
W-4	0.000	874.12	(N/A)	1
W-5	0.000	874.37	(N/A)	1
W-6	0.000	873.72	(N/A)	1
W-7	0.000	874.50	(N/A)	1
W-8	0.000	874.50	(N/A)	1
W-9	0.000	873.85	(N/A)	1
W-10	0.000	874.50	(N/A)	1
W-12	0.000	873.62	(N/A)	1
W-17	0.000	874.24	(N/A)	1
W-18	0.000	875.28	(N/A)	1
W-21	0.000	873.51	(N/A)	1
W-22	0.000	873.78	(N/A)	1
W-23	0.000	873.98	(N/A)	1
W-24	0.000	874.24	(N/A)	1
W-25	0.000	875.24	(N/A)	1
W-28	0.000	873.87	(N/A)	1
W-29	0.000	874.03	(N/A)	1

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps
On - 3/8 HP)

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
W-31	0.000	875.84	(N/A)	1
W-32	0.000	877.11	(N/A)	1
W-33	0.000	878.00	(N/A)	1
W-34	0.000	874.50	(N/A)	1
W-35	0.000	874.50	(N/A)	1
W-36	0.000	874.50	(N/A)	1
W-37	0.000	876.22	(N/A)	1
W-38	0.000	875.53	(N/A)	1
W-39	0.000	876.85	(N/A)	1
W-40	0.000	874.50	(N/A)	1
W-41	0.000	877.22	(N/A)	1
MH-1	0.000	(N/A)	(N/A)	0
AV-3	0.000	867.02	(N/A)	0
J-16	0.000	866.52	(N/A)	-1

Detailed Calculation Summary (Huxley Sewer Model.stsw, 10 Pumps
On - 3/8 HP)
Pond Report

Subnetwork Summary

Subnetwork	Gravity Subnetwork
------------	-----------------------

Pond Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)
-------	--	-------------------------------------

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps On - 3/8 HP)

Executive Summary

Scenario	
Label	15 Pumps On - 3/8 HP

Computation Results	
Subnetwork Results	Number of Gravity Subnetworks: 1 Number of Pressure Subnetworks: 1 >>>> Info: Pressure subnetwork flowing to: MH-1 >>>> Info: Pressure analysis iterations: 11 >>>> Info: Convergence was achieved. >>>> Info: Gravity subnetwork draining to: O-8 >>>> Info: Convergence was achieved.

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps On - 3/8 HP)

Calculation Options

<General>			
Label	Base Calculation Options	Calculation Type	Analysis
Time Analysis Type	Steady State		
Gravity Hydraulics			
Maximum Network Traversals	5	Governing Upstream Pipe Selection Method	Pipe with Maximum QV
Flow Convergence Test	0.001	Structure Loss Mode	Hydraulic Grade
Tractive Stress (Global Minimum)	0.000 Pascals	Report Hydrologic Time Step?	True
Flow Profile Method	Backwater Analysis	Save Detailed Headloss Data?	False
Number of Flow Profile Steps	5	Gravity Friction Method	Manning's
Hydraulic Grade Convergence Test	0.00 m	Liquid Label	Water at 20C (68F)
Average Velocity Method	Actual Uniform Flow Velocity	Use Explicit Depth and Slope Equations?	False
Minimum Structure Headloss	0.00 m		
Pressure			
Peak Flow Ratio	75.0 %	Pattern Setup	<None>
Extreme Flow Setup	<None>	Steady State Hydrograph Equivalent	Peak
Pressure Hydraulics			
Use Controls During Steady State?	True	Use Linear Interpolation For Multipoint Pumps?	False
Wet Well Convergence Increment	0.2 m	Use Controls During Steady State?	True
Use Pumped Flows?	True	Liquid Specific Gravity	0.998
Pressure Subnetwork Accuracy	0.001	Pressure Subnetwork Minimum Possible Pressure	-14 psi
Pressure Subnetwork Trials	40	Pressure Friction Method	Hazen-Williams
SWMM Hydrology			
Default Infiltration Method	Horton	SWMM Hydrologic Increment	0.250 hours
Headloss (AASHTO)			
Expansion, Ke	0.350	Shaping Adjustment, Cs	0.500
Contraction, Kc	0.250	Non-Piped Flow Adjustment, Cn	1.300

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps On - 3/8 HP)

Bend Angle vs. Bend Loss Curve

Bend Angle (degrees)	Bend Loss Coefficient, Kb
0.00	0.000
15.00	0.190
30.00	0.350
45.00	0.470
60.00	0.560
75.00	0.640
90.00	0.700

HEC-22 Energy Losses

Consider Non-Piped Plunging Flow?	True
-----------------------------------	------

HEC-22 Energy Losses (Second Edition)

Elevations Considered Equal Within	0.15 m	Half Bench Submerged Factor	0.950
Flat Unsubmerged Factor	1.000	Full Bench Unsubmerged Factor	0.070
Flat Submerged Factor	1.000	Full Bench Submerged Factor	0.750
Depressed Unsubmerged Factor	1.000	Improved Bench Unsubmerged Factor	0.035
Depressed Submerged Factor	1.000	Improved Bench Submerged Factor	0.375
Half Bench Unsubmerged Factor	0.150		

HEC-22 Energy Losses (Third Edition)

Flat Submerged Coefficient	-0.050	Half Bench Unsubmerged Coefficient	-0.850
Flat Unsubmerged Coefficient	-0.050	Full Bench Submerged Coefficient	-0.250
Depressed Submerged Coefficient	0.000	Full Bench Unsubmerged Coefficient	-0.930
Depressed Unsubmerged Coefficient	0.000	Improved Submerged Coefficient	-0.600
Half Bench Submerged Coefficient	-0.050	Improved Unsubmerged Coefficient	-0.980

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps On - 3/8 HP)

Calculation Summary (501: 15 Pumps On - 3/8 HP)

Time (hours)	Balanced?	Trials	Relative Flow Change
All Time Steps (1)	True	11	0.0001299
0.00	True	11	0.0001299

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps
On - 3/8 HP)
Pipe Report

Subnetwork Summary

Subnetwork Gravity
Subnetwork

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-3	0.000	6.66	3.57	(N/A)
P-4	0.000	3.48	1.87	(N/A)
P-118	0.000	3.17	1.70	(N/A)
P-18	0.000	6.66	1.64	(N/A)
P-139	0.000	6.66	1.64	(N/A)
P-17	0.000	6.66	1.64	(N/A)
P-119	0.000	2.65	1.42	(N/A)
P-2	0.000	2.14	1.15	(N/A)
P-122	0.000	2.14	1.15	(N/A)
P-121	0.000	2.14	1.15	(N/A)
P-120	0.000	2.14	1.15	(N/A)
P-10	0.000	1.79	0.96	(N/A)
P-125	0.000	1.69	0.91	(N/A)
P-124	0.000	1.69	0.91	(N/A)
P-123	0.000	1.69	0.91	(N/A)
P-88	0.000	1.68	0.90	(N/A)
P-126	0.000	1.26	0.68	(N/A)
P-5	0.000	1.22	0.66	(N/A)
P-8	0.000	1.14	0.61	(N/A)
P-104	0.000	1.14	0.61	(N/A)
P-132	0.000	0.90	0.49	(N/A)
P-131	0.000	0.90	0.49	(N/A)
P-130	0.000	0.90	0.49	(N/A)
P-11	0.000	0.89	0.48	(N/A)
P-138	0.000	0.89	0.48	(N/A)
P-116	0.000	0.88	0.47	(N/A)
P-112	0.000	0.86	0.46	(N/A)
P-111	0.000	0.86	0.46	(N/A)
P-127	0.000	0.83	0.45	(N/A)
P-12	0.000	0.78	0.42	(N/A)
P-29	0.000	0.52	0.28	(N/A)
P-62	0.000	0.51	0.27	(N/A)
P-9	0.000	0.50	0.27	(N/A)
P-135	0.000	0.50	0.27	(N/A)
P-134	0.000	0.50	0.27	(N/A)
P-133	0.000	0.50	0.27	(N/A)
P-13	0.000	0.49	0.27	(N/A)
P-136	0.000	0.49	0.27	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps On - 3/8 HP)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-137	0.000	0.49	0.27	(N/A)
P-110	0.000	0.48	0.26	(N/A)
P-107	0.000	0.48	0.26	(N/A)
P-106	0.000	0.48	0.26	(N/A)
P-105	0.000	0.48	0.26	(N/A)
P-61	0.000	0.46	0.25	(N/A)
P-1	0.000	0.46	0.25	(N/A)
P-63	0.000	0.46	0.25	(N/A)
P-14	0.000	0.46	0.25	(N/A)
P-83	0.000	0.46	0.25	(N/A)
P-117	0.000	0.46	0.25	(N/A)
P-79	0.000	0.44	0.24	(N/A)
P-113	0.000	0.44	0.23	(N/A)
P-68	0.000	0.43	0.23	(N/A)
P-69	0.000	0.43	0.23	(N/A)
P-66	0.000	0.43	0.23	(N/A)
P-96	0.000	0.43	0.23	(N/A)
P-81	0.000	0.42	0.23	(N/A)
P-76	0.000	0.40	0.22	(N/A)
P-6	0.000	0.40	0.22	(N/A)
P-129	0.000	0.40	0.22	(N/A)
P-128	0.000	0.40	0.22	(N/A)
P-84	0.000	0.40	0.21	(N/A)
P-89	0.000	0.40	0.21	(N/A)
P-101	0.000	0.39	0.21	(N/A)
P-28	0.000	0.52	0.00	(N/A)
P-32	0.000	0.51	0.00	(N/A)
P-109	0.000	0.48	0.00	(N/A)
P-31	0.000	0.46	0.00	(N/A)
P-33	0.000	0.46	0.00	(N/A)
P-56	0.000	0.46	0.00	(N/A)
P-49	0.000	0.44	0.00	(N/A)
P-38	0.000	0.43	0.00	(N/A)
P-39	0.000	0.43	0.00	(N/A)
P-36	0.000	0.43	0.00	(N/A)
P-94	0.000	0.43	0.00	(N/A)
P-54	0.000	0.42	0.00	(N/A)
P-46	0.000	0.40	0.00	(N/A)
P-57	0.000	0.40	0.00	(N/A)
P-51	0.000	0.39	0.00	(N/A)
P-114	0.000	0.00	0.00	(N/A)
P-115	0.000	0.00	0.00	(N/A)
P-108	0.000	0.00	0.00	(N/A)
P-7	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps On - 3/8 HP)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-90	0.000	0.00	0.00	(N/A)
P-87	0.000	0.00	0.00	(N/A)
P-102	0.000	0.00	0.00	(N/A)
P-91	0.000	0.00	0.00	(N/A)
P-86	0.000	0.00	0.00	(N/A)
P-85	0.000	0.00	0.00	(N/A)
P-103	0.000	0.00	0.00	(N/A)
P-74	0.000	0.00	0.00	(N/A)
P-75	0.000	0.00	0.00	(N/A)
P-72	0.000	0.00	0.00	(N/A)
P-77	0.000	0.00	0.00	(N/A)
P-73	0.000	0.00	0.00	(N/A)
P-99	0.000	0.00	0.00	(N/A)
P-78	0.000	0.00	0.00	(N/A)
P-70	0.000	0.00	0.00	(N/A)
P-64	0.000	0.00	0.00	(N/A)
P-65	0.000	0.00	0.00	(N/A)
P-67	0.000	0.00	0.00	(N/A)
P-82	0.000	0.00	0.00	(N/A)
P-71	0.000	0.00	0.00	(N/A)
P-97	0.000	0.00	0.00	(N/A)
P-60	0.000	0.00	0.00	(N/A)
P-16	0.000	0.00	0.00	(N/A)
P-100	0.000	0.00	0.00	(N/A)
P-93	0.000	0.00	0.00	(N/A)
P-21	0.000	0.00	0.00	(N/A)
P-80	0.000	0.00	0.00	(N/A)
P-24	0.000	0.00	0.00	(N/A)
P-23	0.000	0.00	0.00	(N/A)
P-25	0.000	0.00	0.00	(N/A)
P-42	0.000	0.00	0.00	(N/A)
P-47	0.000	0.00	0.00	(N/A)
P-44	0.000	0.00	0.00	(N/A)
P-48	0.000	0.00	0.00	(N/A)
P-58	0.000	0.00	0.00	(N/A)
P-59	0.000	0.00	0.00	(N/A)
P-53	0.000	0.00	0.00	(N/A)
P-95	0.000	0.00	0.00	(N/A)
P-19	0.000	0.00	0.00	(N/A)
P-30	0.000	0.00	0.00	(N/A)
P-20	0.000	0.00	0.00	(N/A)
P-98	0.000	0.00	0.00	(N/A)
P-43	0.000	0.00	0.00	(N/A)
P-34	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps On - 3/8 HP)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-41	0.000	0.00	0.00	(N/A)
P-37	0.000	0.00	0.00	(N/A)
P-35	0.000	0.00	0.00	(N/A)
P-40	0.000	0.00	0.00	(N/A)
P-45	0.000	0.00	0.00	(N/A)
P-50	0.000	0.00	0.00	(N/A)
P-92	0.000	0.00	0.00	(N/A)
P-27	0.000	0.00	0.00	(N/A)
P-26	0.000	0.00	0.00	(N/A)
P-22	0.000	0.00	0.00	(N/A)
P-55	0.000	0.00	0.00	(N/A)
P-52	0.000	0.00	0.00	(N/A)
P-15	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps
On - 3/8 HP)
Node Report

Subnetwork Summary

Subnetwork Gravity
Subnetwork

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
J-10	0.000	919.39	(N/A)	66
J-53	0.000	920.05	(N/A)	66
J-52	0.000	920.09	(N/A)	65
J-13	0.000	920.36	(N/A)	65
J-19	0.000	920.36	(N/A)	65
J-20	0.000	920.36	(N/A)	65
J-21	0.000	920.36	(N/A)	65
J-51	0.000	920.16	(N/A)	65
J-11	0.000	920.21	(N/A)	65
J-9	0.000	918.69	(N/A)	65
J-45	0.000	919.11	(N/A)	65
J-46	0.000	919.34	(N/A)	65
J-47	0.000	919.51	(N/A)	65
J-48	0.000	919.55	(N/A)	65
J-49	0.000	919.59	(N/A)	64
J-50	0.000	919.62	(N/A)	64
J-8	0.000	919.67	(N/A)	64
J-22	0.000	919.46	(N/A)	64
J-31	0.000	920.66	(N/A)	64
J-26	0.000	919.90	(N/A)	63
J-27	0.000	920.00	(N/A)	63
J-41	0.000	918.30	(N/A)	63
J-42	0.000	918.40	(N/A)	63
J-40	0.000	918.04	(N/A)	63
J-43	0.000	918.44	(N/A)	63
J-44	0.000	918.46	(N/A)	63
J-39	0.000	917.64	(N/A)	62
J-5	0.000	918.49	(N/A)	62
J-28	0.000	920.06	(N/A)	62
J-38	0.000	917.22	(N/A)	62
J-32	0.000	920.78	(N/A)	62
J-23	0.000	918.57	(N/A)	61
J-29	0.000	920.06	(N/A)	61
J-4	0.000	915.98	(N/A)	61
J-18	0.000	917.40	(N/A)	61
J-12	0.000	920.87	(N/A)	61
J-1	0.000	917.16	(N/A)	61
J-14	0.000	917.16	(N/A)	61

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps On - 3/8 HP)

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
J-17	0.000	917.16	(N/A)	61
J-24	0.000	918.68	(N/A)	60
J-2	0.000	916.95	(N/A)	60
J-30	0.000	920.06	(N/A)	60
J-7	0.000	920.06	(N/A)	60
J-37	0.000	916.37	(N/A)	60
J-25	0.000	918.79	(N/A)	59
J-36	0.000	915.77	(N/A)	59
J-35	0.000	915.23	(N/A)	58
J-6	0.000	918.79	(N/A)	58
J-34	0.000	914.11	(N/A)	57
J-33	0.000	913.21	(N/A)	56
J-3	0.000	907.10	(N/A)	48
J-15	0.000	879.55	(N/A)	11
W-11	0.000	874.39	(N/A)	1
W-13	0.000	873.92	(N/A)	1
W-14	0.000	873.47	(N/A)	1
W-15	0.000	873.76	(N/A)	1
W-16	0.000	874.05	(N/A)	1
W-19	0.000	874.10	(N/A)	1
W-20	0.000	874.36	(N/A)	1
W-26	0.000	876.16	(N/A)	1
W-27	0.000	877.65	(N/A)	1
W-30	0.000	874.31	(N/A)	1
W-1	0.000	874.50	(N/A)	1
W-2	0.000	874.50	(N/A)	1
W-3	0.000	874.24	(N/A)	1
W-4	0.000	874.12	(N/A)	1
W-5	0.000	874.37	(N/A)	1
W-6	0.000	873.72	(N/A)	1
W-7	0.000	874.50	(N/A)	1
W-8	0.000	874.50	(N/A)	1
W-9	0.000	873.85	(N/A)	1
W-10	0.000	874.50	(N/A)	1
W-12	0.000	873.62	(N/A)	1
W-17	0.000	874.24	(N/A)	1
W-18	0.000	875.28	(N/A)	1
W-21	0.000	873.51	(N/A)	1
W-22	0.000	873.78	(N/A)	1
W-23	0.000	873.98	(N/A)	1
W-24	0.000	874.24	(N/A)	1
W-25	0.000	875.24	(N/A)	1
W-28	0.000	873.87	(N/A)	1
W-29	0.000	874.03	(N/A)	1

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps On - 3/8 HP)

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
W-31	0.000	875.84	(N/A)	1
W-32	0.000	877.11	(N/A)	1
W-33	0.000	878.00	(N/A)	1
W-34	0.000	874.50	(N/A)	1
W-35	0.000	874.50	(N/A)	1
W-36	0.000	874.50	(N/A)	1
W-37	0.000	876.22	(N/A)	1
W-38	0.000	875.53	(N/A)	1
W-39	0.000	876.85	(N/A)	1
W-40	0.000	874.50	(N/A)	1
W-41	0.000	877.22	(N/A)	1
MH-1	0.000	(N/A)	(N/A)	0
AV-3	0.000	867.02	(N/A)	0
J-16	0.000	866.62	(N/A)	-1

Detailed Calculation Summary (Huxley Sewer Model.stsw, 15 Pumps
On - 3/8 HP)
Pond Report

Subnetwork Summary

Subnetwork Gravity
Subnetwork Subnetwork

Pond Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)
-------	--	-------------------------------------

Detailed Calculation Summary (Huxley Sewer Model.stsw, 20 Pumps On - 3/8 HP)

Executive Summary

Scenario	
Label	20 Pumps On - 3/8 HP

Computation Results	
Subnetwork Results	Number of Gravity Subnetworks: 1 Number of Pressure Subnetworks: 1 >>>> Info: Pressure subnetwork flowing to: MH-1 >>>> Info: Pressure analysis iterations: 11 >>>> Info: Convergence was achieved. >>>> Info: Gravity subnetwork draining to: O-8 >>>> Info: Convergence was achieved.

Detailed Calculation Summary (Huxley Sewer Model.stsw, 20 Pumps On - 3/8 HP)

Calculation Options

<General>			
Label	Base Calculation Options	Calculation Type	Analysis
Time Analysis Type	Steady State		
Gravity Hydraulics			
Maximum Network Traversals	5	Governing Upstream Pipe Selection Method	Pipe with Maximum QV
Flow Convergence Test	0.001	Structure Loss Mode	Hydraulic Grade
Tractive Stress (Global Minimum)	0.000 Pascals	Report Hydrologic Time Step?	True
Flow Profile Method	Backwater Analysis	Save Detailed Headloss Data?	False
Number of Flow Profile Steps	5	Gravity Friction Method	Manning's
Hydraulic Grade Convergence Test	0.00 m	Liquid Label	Water at 20C (68F)
Average Velocity Method	Actual Uniform Flow Velocity	Use Explicit Depth and Slope Equations?	False
Minimum Structure Headloss	0.00 m		
Pressure			
Peak Flow Ratio	75.0 %	Pattern Setup	<None>
Extreme Flow Setup	<None>	Steady State Hydrograph Equivalent	Peak
Pressure Hydraulics			
Use Controls During Steady State?	True	Use Linear Interpolation For Multipoint Pumps?	False
Wet Well Convergence Increment	0.2 m	Use Controls During Steady State?	True
Use Pumped Flows?	True	Liquid Specific Gravity	0.998
Pressure Subnetwork Accuracy	0.001	Pressure Subnetwork Minimum Possible Pressure	-14 psi
Pressure Subnetwork Trials	40	Pressure Friction Method	Hazen-Williams
SWMM Hydrology			
Default Infiltration Method	Horton	SWMM Hydrologic Increment	0.250 hours
Headloss (AASHTO)			
Expansion, Ke	0.350	Shaping Adjustment, Cs	0.500
Contraction, Kc	0.250	Non-Piped Flow Adjustment, Cn	1.300

Detailed Calculation Summary (Huxley Sewer Model.stsw, 20 Pumps On - 3/8 HP)

Bend Angle vs. Bend Loss Curve

Bend Angle (degrees)	Bend Loss Coefficient, Kb
0.00	0.000
15.00	0.190
30.00	0.350
45.00	0.470
60.00	0.560
75.00	0.640
90.00	0.700

HEC-22 Energy Losses

Consider Non-Piped Plunging Flow?	True
-----------------------------------	------

HEC-22 Energy Losses (Second Edition)

Elevations Considered Equal Within	0.15 m	Half Bench Submerged Factor	0.950
Flat Unsubmerged Factor	1.000	Full Bench Unsubmerged Factor	0.070
Flat Submerged Factor	1.000	Full Bench Submerged Factor	0.750
Depressed Unsubmerged Factor	1.000	Improved Bench Unsubmerged Factor	0.035
Depressed Submerged Factor	1.000	Improved Bench Submerged Factor	0.375
Half Bench Unsubmerged Factor	0.150		

HEC-22 Energy Losses (Third Edition)

Flat Submerged Coefficient	-0.050	Half Bench Unsubmerged Coefficient	-0.850
Flat Unsubmerged Coefficient	-0.050	Full Bench Submerged Coefficient	-0.250
Depressed Submerged Coefficient	0.000	Full Bench Unsubmerged Coefficient	-0.930
Depressed Unsubmerged Coefficient	0.000	Improved Submerged Coefficient	-0.600
Half Bench Submerged Coefficient	-0.050	Improved Unsubmerged Coefficient	-0.980

Detailed Calculation Summary (Huxley Sewer Model.stsw, 20 Pumps On - 3/8 HP)

Calculation Summary (502: 20 Pumps On - 3/8 HP)

Time (hours)	Balanced?	Trials	Relative Flow Change
All Time Steps (0)	True	0	(N/A)
0.00	True	(N/A)	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 20 Pumps
On - 3/8 HP)
Pipe Report

Subnetwork Summary

Subnetwork Pressure
 Subnetwork -
 1

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-3	0.000	6.89	3.70	(N/A)
P-4	0.000	3.72	2.00	(N/A)
P-120	0.000	3.17	1.70	(N/A)
P-119	0.000	3.17	1.70	(N/A)
P-118	0.000	3.17	1.70	(N/A)
P-18	0.000	6.89	1.70	(N/A)
P-139	0.000	6.89	1.70	(N/A)
P-17	0.000	6.89	1.70	(N/A)
P-121	0.000	2.76	1.48	(N/A)
P-2	0.000	2.37	1.27	(N/A)
P-122	0.000	2.37	1.27	(N/A)
P-10	0.000	1.94	1.04	(N/A)
P-126	0.000	1.78	0.96	(N/A)
P-125	0.000	1.78	0.96	(N/A)
P-124	0.000	1.78	0.96	(N/A)
P-123	0.000	1.78	0.96	(N/A)
P-127	0.000	1.44	0.77	(N/A)
P-5	0.000	1.28	0.69	(N/A)
P-88	0.000	1.28	0.69	(N/A)
P-128	0.000	1.10	0.59	(N/A)
P-131	0.000	1.06	0.57	(N/A)
P-130	0.000	1.06	0.57	(N/A)
P-8	0.000	0.97	0.52	(N/A)
P-104	0.000	0.97	0.52	(N/A)
P-137	0.000	0.87	0.47	(N/A)
P-11	0.000	0.87	0.47	(N/A)
P-138	0.000	0.87	0.47	(N/A)
P-129	0.000	0.77	0.41	(N/A)
P-132	0.000	0.75	0.40	(N/A)
P-105	0.000	0.74	0.40	(N/A)
P-113	0.000	0.73	0.39	(N/A)
P-112	0.000	0.73	0.39	(N/A)
P-111	0.000	0.73	0.39	(N/A)
P-1	0.000	0.72	0.39	(N/A)
P-12	0.000	0.68	0.37	(N/A)
P-89	0.000	0.61	0.33	(N/A)
P-136	0.000	0.57	0.31	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 20 Pumps On - 3/8 HP)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-9	0.000	0.44	0.24	(N/A)
P-135	0.000	0.44	0.24	(N/A)
P-134	0.000	0.44	0.24	(N/A)
P-133	0.000	0.44	0.24	(N/A)
P-6	0.000	0.43	0.23	(N/A)
P-25	0.000	0.41	0.22	(N/A)
P-23	0.000	0.39	0.21	(N/A)
P-107	0.000	0.39	0.21	(N/A)
P-110	0.000	0.39	0.21	(N/A)
P-106	0.000	0.39	0.21	(N/A)
P-115	0.000	0.38	0.20	(N/A)
P-80	0.000	0.38	0.20	(N/A)
P-114	0.000	0.38	0.20	(N/A)
P-21	0.000	0.37	0.20	(N/A)
P-61	0.000	0.36	0.19	(N/A)
P-16	0.000	0.36	0.19	(N/A)
P-100	0.000	0.36	0.19	(N/A)
P-87	0.000	0.36	0.19	(N/A)
P-71	0.000	0.35	0.19	(N/A)
P-79	0.000	0.35	0.19	(N/A)
P-66	0.000	0.34	0.18	(N/A)
P-81	0.000	0.34	0.18	(N/A)
P-116	0.000	0.34	0.18	(N/A)
P-64	0.000	0.34	0.18	(N/A)
P-69	0.000	0.34	0.18	(N/A)
P-70	0.000	0.34	0.18	(N/A)
P-76	0.000	0.31	0.17	(N/A)
P-75	0.000	0.31	0.17	(N/A)
P-103	0.000	0.31	0.17	(N/A)
P-84	0.000	0.30	0.16	(N/A)
P-85	0.000	0.30	0.16	(N/A)
P-90	0.000	0.30	0.16	(N/A)
P-102	0.000	0.30	0.16	(N/A)
P-13	0.000	0.26	0.14	(N/A)
P-26	0.000	0.41	0.00	(N/A)
P-22	0.000	0.39	0.00	(N/A)
P-109	0.000	0.39	0.00	(N/A)
P-50	0.000	0.38	0.00	(N/A)
P-20	0.000	0.37	0.00	(N/A)
P-31	0.000	0.36	0.00	(N/A)
P-19	0.000	0.36	0.00	(N/A)
P-41	0.000	0.35	0.00	(N/A)
P-49	0.000	0.35	0.00	(N/A)
P-36	0.000	0.34	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 20 Pumps On - 3/8 HP)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-54	0.000	0.34	0.00	(N/A)
P-34	0.000	0.34	0.00	(N/A)
P-39	0.000	0.34	0.00	(N/A)
P-40	0.000	0.34	0.00	(N/A)
P-46	0.000	0.31	0.00	(N/A)
P-45	0.000	0.31	0.00	(N/A)
P-53	0.000	0.31	0.00	(N/A)
P-57	0.000	0.30	0.00	(N/A)
P-58	0.000	0.30	0.00	(N/A)
P-52	0.000	0.30	0.00	(N/A)
P-117	0.000	0.00	0.00	(N/A)
P-101	0.000	0.00	0.00	(N/A)
P-86	0.000	0.00	0.00	(N/A)
P-91	0.000	0.00	0.00	(N/A)
P-74	0.000	0.00	0.00	(N/A)
P-72	0.000	0.00	0.00	(N/A)
P-77	0.000	0.00	0.00	(N/A)
P-73	0.000	0.00	0.00	(N/A)
P-99	0.000	0.00	0.00	(N/A)
P-78	0.000	0.00	0.00	(N/A)
P-96	0.000	0.00	0.00	(N/A)
P-68	0.000	0.00	0.00	(N/A)
P-65	0.000	0.00	0.00	(N/A)
P-60	0.000	0.00	0.00	(N/A)
P-67	0.000	0.00	0.00	(N/A)
P-97	0.000	0.00	0.00	(N/A)
P-63	0.000	0.00	0.00	(N/A)
P-82	0.000	0.00	0.00	(N/A)
P-93	0.000	0.00	0.00	(N/A)
P-24	0.000	0.00	0.00	(N/A)
P-14	0.000	0.00	0.00	(N/A)
P-83	0.000	0.00	0.00	(N/A)
P-62	0.000	0.00	0.00	(N/A)
P-29	0.000	0.00	0.00	(N/A)
P-48	0.000	0.00	0.00	(N/A)
P-30	0.000	0.00	0.00	(N/A)
P-33	0.000	0.00	0.00	(N/A)
P-32	0.000	0.00	0.00	(N/A)
P-37	0.000	0.00	0.00	(N/A)
P-43	0.000	0.00	0.00	(N/A)
P-59	0.000	0.00	0.00	(N/A)
P-98	0.000	0.00	0.00	(N/A)
P-94	0.000	0.00	0.00	(N/A)
P-95	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 20 Pumps
On - 3/8 HP)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-44	0.000	0.00	0.00	(N/A)
P-47	0.000	0.00	0.00	(N/A)
P-42	0.000	0.00	0.00	(N/A)
P-51	0.000	0.00	0.00	(N/A)
P-55	0.000	0.00	0.00	(N/A)
P-27	0.000	0.00	0.00	(N/A)
P-35	0.000	0.00	0.00	(N/A)
P-38	0.000	0.00	0.00	(N/A)
P-92	0.000	0.00	0.00	(N/A)
P-15	0.000	0.00	0.00	(N/A)
P-56	0.000	0.00	0.00	(N/A)
P-28	0.000	0.00	0.00	(N/A)
P-7	0.000	0.00	0.00	(N/A)
P-108	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 20 Pumps On - 3/8 HP)

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
J-2	0.000	921.71	(N/A)	67
J-24	0.000	923.43	(N/A)	67
J-30	0.000	924.53	(N/A)	67
J-4	0.000	919.78	(N/A)	66
J-37	0.000	921.01	(N/A)	66
J-12	0.000	924.54	(N/A)	66
J-7	0.000	924.53	(N/A)	66
J-25	0.000	923.50	(N/A)	66
J-36	0.000	920.29	(N/A)	65
J-6	0.000	923.50	(N/A)	65
J-35	0.000	919.41	(N/A)	64
J-34	0.000	917.09	(N/A)	61
J-33	0.000	915.84	(N/A)	60
J-3	0.000	909.74	(N/A)	52
J-15	0.000	880.38	(N/A)	12
W-11	0.000	874.39	(N/A)	1
W-13	0.000	873.92	(N/A)	1
W-14	0.000	873.47	(N/A)	1
W-15	0.000	873.76	(N/A)	1
W-16	0.000	874.05	(N/A)	1
W-19	0.000	874.10	(N/A)	1
W-20	0.000	874.36	(N/A)	1
W-26	0.000	876.16	(N/A)	1
W-27	0.000	877.65	(N/A)	1
W-30	0.000	874.31	(N/A)	1
W-1	0.000	874.50	(N/A)	1
W-2	0.000	874.50	(N/A)	1
W-3	0.000	874.24	(N/A)	1
W-4	0.000	874.12	(N/A)	1
W-5	0.000	874.37	(N/A)	1
W-6	0.000	873.72	(N/A)	1
W-7	0.000	874.50	(N/A)	1
W-8	0.000	874.50	(N/A)	1
W-9	0.000	873.85	(N/A)	1
W-10	0.000	874.50	(N/A)	1
W-12	0.000	873.62	(N/A)	1
W-17	0.000	874.24	(N/A)	1
W-18	0.000	875.28	(N/A)	1
W-21	0.000	873.51	(N/A)	1
W-22	0.000	873.78	(N/A)	1
W-23	0.000	873.98	(N/A)	1
W-24	0.000	874.24	(N/A)	1
W-25	0.000	875.24	(N/A)	1
W-28	0.000	873.87	(N/A)	1

Detailed Calculation Summary (Huxley Sewer Model.stsw, 20 Pumps On - 3/8 HP)

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
W-29	0.000	874.03	(N/A)	1
W-31	0.000	875.84	(N/A)	1
W-32	0.000	877.11	(N/A)	1
W-33	0.000	878.00	(N/A)	1
W-34	0.000	874.50	(N/A)	1
W-35	0.000	874.50	(N/A)	1
W-36	0.000	874.50	(N/A)	1
W-37	0.000	876.22	(N/A)	1
W-38	0.000	875.53	(N/A)	1
W-39	0.000	876.85	(N/A)	1
W-40	0.000	874.50	(N/A)	1
W-41	0.000	877.22	(N/A)	1
MH-1	0.000	(N/A)	(N/A)	0
AV-3	0.000	867.02	(N/A)	0
J-16	0.000	866.66	(N/A)	0

Detailed Calculation Summary (Huxley Sewer Model.stsw, 20 Pumps
On - 3/8 HP)

Pond Report

Subnetwork Summary

Subnetwork Pressure
 Subnetwork -
 1

Pond Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)
-------	--	-------------------------------------

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps On - 3/8 HP)

Executive Summary

Scenario	
Label	25 Pumps On - 3/8 HP

Computation Results	
Subnetwork Results	Number of Gravity Subnetworks: 1 Number of Pressure Subnetworks: 1 >>>> Info: Pressure subnetwork flowing to: MH-1 >>>> Info: Pressure analysis iterations: 11 >>>> Info: Convergence was achieved. >>>> Info: Gravity subnetwork draining to: O-8 >>>> Info: Convergence was achieved.

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps On - 3/8 HP)

Calculation Options

<General>			
Label	Base Calculation Options	Calculation Type	Analysis
Time Analysis Type	Steady State		
Gravity Hydraulics			
Maximum Network Traversals	5	Governing Upstream Pipe Selection Method	Pipe with Maximum QV
Flow Convergence Test	0.001	Structure Loss Mode	Hydraulic Grade
Tractive Stress (Global Minimum)	0.000 Pascals	Report Hydrologic Time Step?	True
Flow Profile Method	Backwater Analysis	Save Detailed Headloss Data?	False
Number of Flow Profile Steps	5	Gravity Friction Method	Manning's
Hydraulic Grade Convergence Test	0.00 m	Liquid Label	Water at 20C (68F)
Average Velocity Method	Actual Uniform Flow Velocity	Use Explicit Depth and Slope Equations?	False
Minimum Structure Headloss	0.00 m		
Pressure			
Peak Flow Ratio	75.0 %	Pattern Setup	<None>
Extreme Flow Setup	<None>	Steady State Hydrograph Equivalent	Peak
Pressure Hydraulics			
Use Controls During Steady State?	True	Use Linear Interpolation For Multipoint Pumps?	False
Wet Well Convergence Increment	0.2 m	Use Controls During Steady State?	True
Use Pumped Flows?	True	Liquid Specific Gravity	0.998
Pressure Subnetwork Accuracy	0.001	Pressure Subnetwork Minimum Possible Pressure	-14 psi
Pressure Subnetwork Trials	40	Pressure Friction Method	Hazen-Williams
SWMM Hydrology			
Default Infiltration Method	Horton	SWMM Hydrologic Increment	0.250 hours
Headloss (AASHTO)			
Expansion, Ke	0.350	Shaping Adjustment, Cs	0.500
Contraction, Kc	0.250	Non-Piped Flow Adjustment, Cn	1.300

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps On - 3/8 HP)

Bend Angle vs. Bend Loss Curve

Bend Angle (degrees)	Bend Loss Coefficient, Kb
0.00	0.000
15.00	0.190
30.00	0.350
45.00	0.470
60.00	0.560
75.00	0.640
90.00	0.700

HEC-22 Energy Losses

Consider Non-Piped Plunging Flow?	True
-----------------------------------	------

HEC-22 Energy Losses (Second Edition)

Elevations Considered Equal Within	0.15 m	Half Bench Submerged Factor	0.950
Flat Unsubmerged Factor	1.000	Full Bench Unsubmerged Factor	0.070
Flat Submerged Factor	1.000	Full Bench Submerged Factor	0.750
Depressed Unsubmerged Factor	1.000	Improved Bench Unsubmerged Factor	0.035
Depressed Submerged Factor	1.000	Improved Bench Submerged Factor	0.375
Half Bench Unsubmerged Factor	0.150		

HEC-22 Energy Losses (Third Edition)

Flat Submerged Coefficient	-0.050	Half Bench Unsubmerged Coefficient	-0.850
Flat Unsubmerged Coefficient	-0.050	Full Bench Submerged Coefficient	-0.250
Depressed Submerged Coefficient	0.000	Full Bench Unsubmerged Coefficient	-0.930
Depressed Unsubmerged Coefficient	0.000	Improved Submerged Coefficient	-0.600
Half Bench Submerged Coefficient	-0.050	Improved Unsubmerged Coefficient	-0.980

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps On - 3/8 HP)

Calculation Summary (503: 25 Pumps On - 3/8 HP)

Time (hours)	Balanced?	Trials	Relative Flow Change
All Time Steps (0)	True	0	(N/A)
0.00	True	(N/A)	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps On - 3/8 HP) Pipe Report

Subnetwork Summary

Subnetwork Pressure
Subnetwork -
1

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-3	0.000	7.13	3.83	(N/A)
P-4	0.000	3.81	2.04	(N/A)
P-118	0.000	3.33	1.79	(N/A)
P-18	0.000	7.14	1.76	(N/A)
P-139	0.000	7.14	1.76	(N/A)
P-17	0.000	7.13	1.76	(N/A)
P-120	0.000	2.92	1.57	(N/A)
P-119	0.000	2.92	1.57	(N/A)
P-121	0.000	2.57	1.38	(N/A)
P-122	0.000	2.24	1.20	(N/A)
P-10	0.000	1.93	1.03	(N/A)
P-2	0.000	1.92	1.03	(N/A)
P-123	0.000	1.88	1.01	(N/A)
P-124	0.000	1.59	0.85	(N/A)
P-104	0.000	1.41	0.76	(N/A)
P-125	0.000	1.31	0.70	(N/A)
P-5	0.000	1.30	0.70	(N/A)
P-88	0.000	1.30	0.70	(N/A)
P-8	0.000	1.16	0.62	(N/A)
P-131	0.000	1.10	0.59	(N/A)
P-130	0.000	1.10	0.59	(N/A)
P-126	0.000	1.03	0.55	(N/A)
P-132	0.000	0.87	0.47	(N/A)
P-111	0.000	0.83	0.45	(N/A)
P-137	0.000	0.83	0.44	(N/A)
P-11	0.000	0.83	0.44	(N/A)
P-138	0.000	0.83	0.44	(N/A)
P-6	0.000	0.75	0.40	(N/A)
P-129	0.000	0.75	0.40	(N/A)
P-128	0.000	0.75	0.40	(N/A)
P-127	0.000	0.75	0.40	(N/A)
P-106	0.000	0.65	0.35	(N/A)
P-105	0.000	0.65	0.35	(N/A)
P-133	0.000	0.63	0.34	(N/A)
P-87	0.000	0.61	0.33	(N/A)
P-1	0.000	0.61	0.33	(N/A)
P-117	0.000	0.60	0.32	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps On - 3/8 HP)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-116	0.000	0.60	0.32	(N/A)
P-136	0.000	0.59	0.32	(N/A)
P-112	0.000	0.57	0.31	(N/A)
P-12	0.000	0.48	0.26	(N/A)
P-29	0.000	0.40	0.22	(N/A)
P-135	0.000	0.39	0.21	(N/A)
P-134	0.000	0.39	0.21	(N/A)
P-13	0.000	0.36	0.19	(N/A)
P-25	0.000	0.35	0.19	(N/A)
P-23	0.000	0.34	0.18	(N/A)
P-110	0.000	0.33	0.18	(N/A)
P-107	0.000	0.33	0.18	(N/A)
P-24	0.000	0.32	0.17	(N/A)
P-93	0.000	0.31	0.17	(N/A)
P-14	0.000	0.31	0.17	(N/A)
P-83	0.000	0.31	0.17	(N/A)
P-115	0.000	0.31	0.17	(N/A)
P-80	0.000	0.31	0.17	(N/A)
P-114	0.000	0.31	0.17	(N/A)
P-113	0.000	0.31	0.17	(N/A)
P-16	0.000	0.31	0.16	(N/A)
P-100	0.000	0.31	0.16	(N/A)
P-60	0.000	0.30	0.16	(N/A)
P-82	0.000	0.29	0.16	(N/A)
P-67	0.000	0.29	0.15	(N/A)
P-65	0.000	0.28	0.15	(N/A)
P-68	0.000	0.28	0.15	(N/A)
P-66	0.000	0.28	0.15	(N/A)
P-96	0.000	0.26	0.14	(N/A)
P-78	0.000	0.26	0.14	(N/A)
P-99	0.000	0.25	0.13	(N/A)
P-73	0.000	0.24	0.13	(N/A)
P-84	0.000	0.24	0.13	(N/A)
P-89	0.000	0.24	0.13	(N/A)
P-72	0.000	0.24	0.13	(N/A)
P-103	0.000	0.24	0.13	(N/A)
P-76	0.000	0.24	0.13	(N/A)
P-75	0.000	0.24	0.13	(N/A)
P-102	0.000	0.23	0.12	(N/A)
P-9	0.000	0.15	0.08	(N/A)
P-28	0.000	0.40	0.00	(N/A)
P-26	0.000	0.35	0.00	(N/A)
P-22	0.000	0.34	0.00	(N/A)
P-109	0.000	0.33	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps On - 3/8 HP)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-27	0.000	0.32	0.00	(N/A)
P-92	0.000	0.31	0.00	(N/A)
P-56	0.000	0.31	0.00	(N/A)
P-50	0.000	0.31	0.00	(N/A)
P-19	0.000	0.31	0.00	(N/A)
P-30	0.000	0.30	0.00	(N/A)
P-55	0.000	0.29	0.00	(N/A)
P-37	0.000	0.29	0.00	(N/A)
P-35	0.000	0.28	0.00	(N/A)
P-38	0.000	0.28	0.00	(N/A)
P-36	0.000	0.28	0.00	(N/A)
P-94	0.000	0.26	0.00	(N/A)
P-48	0.000	0.26	0.00	(N/A)
P-98	0.000	0.25	0.00	(N/A)
P-43	0.000	0.24	0.00	(N/A)
P-57	0.000	0.24	0.00	(N/A)
P-42	0.000	0.24	0.00	(N/A)
P-53	0.000	0.24	0.00	(N/A)
P-46	0.000	0.24	0.00	(N/A)
P-45	0.000	0.24	0.00	(N/A)
P-52	0.000	0.23	0.00	(N/A)
P-90	0.000	0.00	0.00	(N/A)
P-91	0.000	0.00	0.00	(N/A)
P-15	0.000	0.00	0.00	(N/A)
P-108	0.000	0.00	0.00	(N/A)
P-101	0.000	0.00	0.00	(N/A)
P-74	0.000	0.00	0.00	(N/A)
P-86	0.000	0.00	0.00	(N/A)
P-85	0.000	0.00	0.00	(N/A)
P-77	0.000	0.00	0.00	(N/A)
P-81	0.000	0.00	0.00	(N/A)
P-79	0.000	0.00	0.00	(N/A)
P-69	0.000	0.00	0.00	(N/A)
P-70	0.000	0.00	0.00	(N/A)
P-64	0.000	0.00	0.00	(N/A)
P-97	0.000	0.00	0.00	(N/A)
P-71	0.000	0.00	0.00	(N/A)
P-61	0.000	0.00	0.00	(N/A)
P-63	0.000	0.00	0.00	(N/A)
P-21	0.000	0.00	0.00	(N/A)
P-62	0.000	0.00	0.00	(N/A)
P-58	0.000	0.00	0.00	(N/A)
P-59	0.000	0.00	0.00	(N/A)
P-54	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps
On - 3/8 HP)

Pipe Report

Label	Time (Maximum Flow) (hours)	Flow (Maximum) (L/s)	Velocity (Maximum Calculated) (m/s)	Depth (Maximum) / Rise (%)
P-95	0.000	0.00	0.00	(N/A)
P-32	0.000	0.00	0.00	(N/A)
P-31	0.000	0.00	0.00	(N/A)
P-33	0.000	0.00	0.00	(N/A)
P-20	0.000	0.00	0.00	(N/A)
P-41	0.000	0.00	0.00	(N/A)
P-39	0.000	0.00	0.00	(N/A)
P-34	0.000	0.00	0.00	(N/A)
P-51	0.000	0.00	0.00	(N/A)
P-47	0.000	0.00	0.00	(N/A)
P-44	0.000	0.00	0.00	(N/A)
P-49	0.000	0.00	0.00	(N/A)
P-40	0.000	0.00	0.00	(N/A)
P-7	0.000	0.00	0.00	(N/A)

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps
 On - 3/8 HP)

Node Report

Subnetwork Summary

Subnetwork Pressure
 Subnetwork -
 1

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
J-10	0.000	926.79	(N/A)	76
J-53	0.000	927.36	(N/A)	76
J-52	0.000	927.48	(N/A)	76
J-46	0.000	927.11	(N/A)	76
J-47	0.000	927.27	(N/A)	76
J-45	0.000	926.79	(N/A)	76
J-51	0.000	927.58	(N/A)	76
J-48	0.000	927.33	(N/A)	76
J-9	0.000	926.17	(N/A)	75
J-13	0.000	927.66	(N/A)	75
J-19	0.000	927.66	(N/A)	75
J-20	0.000	927.66	(N/A)	75
J-21	0.000	927.66	(N/A)	75
J-49	0.000	927.35	(N/A)	75
J-11	0.000	927.60	(N/A)	75
J-50	0.000	927.38	(N/A)	75
J-8	0.000	927.38	(N/A)	75
J-22	0.000	927.17	(N/A)	75
J-26	0.000	927.60	(N/A)	74
J-27	0.000	927.65	(N/A)	74
J-31	0.000	927.82	(N/A)	74
J-28	0.000	927.68	(N/A)	73
J-41	0.000	925.38	(N/A)	73
J-40	0.000	925.19	(N/A)	73
J-42	0.000	925.46	(N/A)	73
J-43	0.000	925.57	(N/A)	73
J-39	0.000	924.95	(N/A)	73
J-44	0.000	925.66	(N/A)	73
J-5	0.000	925.74	(N/A)	73
J-38	0.000	924.57	(N/A)	73
J-32	0.000	928.03	(N/A)	72
J-29	0.000	927.71	(N/A)	72
J-23	0.000	925.89	(N/A)	72
J-14	0.000	924.73	(N/A)	71
J-17	0.000	924.68	(N/A)	71
J-30	0.000	927.75	(N/A)	71
J-1	0.000	924.58	(N/A)	71

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps On - 3/8 HP)

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
J-12	0.000	928.07	(N/A)	71
J-4	0.000	923.07	(N/A)	71
J-18	0.000	924.50	(N/A)	71
J-24	0.000	926.06	(N/A)	71
J-7	0.000	927.75	(N/A)	71
J-2	0.000	924.23	(N/A)	71
J-37	0.000	923.75	(N/A)	70
J-25	0.000	926.12	(N/A)	69
J-36	0.000	923.10	(N/A)	69
J-35	0.000	922.34	(N/A)	68
J-6	0.000	926.12	(N/A)	68
J-34	0.000	920.34	(N/A)	66
J-33	0.000	919.27	(N/A)	65
J-3	0.000	912.59	(N/A)	56
J-15	0.000	881.27	(N/A)	13
W-11	0.000	874.39	(N/A)	1
W-13	0.000	873.92	(N/A)	1
W-14	0.000	873.47	(N/A)	1
W-15	0.000	873.76	(N/A)	1
W-16	0.000	874.05	(N/A)	1
W-19	0.000	874.10	(N/A)	1
W-20	0.000	874.36	(N/A)	1
W-26	0.000	876.16	(N/A)	1
W-27	0.000	877.65	(N/A)	1
W-30	0.000	874.31	(N/A)	1
W-1	0.000	874.50	(N/A)	1
W-2	0.000	874.50	(N/A)	1
W-3	0.000	874.24	(N/A)	1
W-4	0.000	874.12	(N/A)	1
W-5	0.000	874.37	(N/A)	1
W-6	0.000	873.72	(N/A)	1
W-7	0.000	874.50	(N/A)	1
W-8	0.000	874.50	(N/A)	1
W-9	0.000	873.85	(N/A)	1
W-10	0.000	874.50	(N/A)	1
W-12	0.000	873.62	(N/A)	1
W-17	0.000	874.24	(N/A)	1
W-18	0.000	875.28	(N/A)	1
W-21	0.000	873.51	(N/A)	1
W-22	0.000	873.78	(N/A)	1
W-23	0.000	873.98	(N/A)	1
W-24	0.000	874.24	(N/A)	1
W-25	0.000	875.24	(N/A)	1
W-28	0.000	873.87	(N/A)	1

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps
On - 3/8 HP)

Node Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)	Depth (Maximum) (m)	Pressure (Maximum) (psi)
W-29	0.000	874.03	(N/A)	1
W-31	0.000	875.84	(N/A)	1
W-32	0.000	877.11	(N/A)	1
W-33	0.000	878.00	(N/A)	1
W-34	0.000	874.50	(N/A)	1
W-35	0.000	874.50	(N/A)	1
W-36	0.000	874.50	(N/A)	1
W-37	0.000	876.22	(N/A)	1
W-38	0.000	875.53	(N/A)	1
W-39	0.000	876.85	(N/A)	1
W-40	0.000	874.50	(N/A)	1
W-41	0.000	877.22	(N/A)	1
MH-1	0.000	(N/A)	(N/A)	0
AV-3	0.000	867.02	(N/A)	0
J-16	0.000	866.70	(N/A)	0

Detailed Calculation Summary (Huxley Sewer Model.stsw, 25 Pumps On - 3/8 HP) Pond Report

Subnetwork Summary

	Pressure
Subnetwork	Subnetwork -
	1

Pond Report

Label	Time to Maximum Hydraulic Grade (hours)	Hydraulic Grade (Maximum) (m)

APPENDIX C

Submersible Pumps

Orenco® PF-Series 60Hz, 1-Phase Pumps

Applications

Orenco's 60Hz, 1-phase, 4in (100mm) Submersible Effluent Pumps are designed to transport screened effluent (with low TSS counts) from septic or dosing tanks. These pumps are engineered using lightweight, corrosion-resistant stainless steel and polymers, and are field serviceable and repairable with common tools. They're also CSA and UL certified to US and Canadian safety standards for effluent pumps.

PF-Series pumps are used in a variety of applications, including pressurized drainfields, packed-bed filters, mounds, aerobic units, effluent irrigation, liquid-only (effluent) sewers, wetlands, lagoons, and more. These pumps are designed to be used with a Biotube® pump vault or after a secondary treatment system.



General

To specify this pump for your installation, require the following:


- Minimum 24-hour run-dry capability (liquid end) with no deterioration in pump life or performance*
- 1/8in (3mm) bypass orifice to ensure flow recirculation for motor cooling and to prevent air binding
- 1/8in (3mm) mesh intake screen to limit solids
- Liquid-end repair kit availability for better long-term cost to own
- TRI-SEAL™ floating impeller design on 10, 20, and 30gpm (0.6, 1.3, and 1.9L/sec) models; floating stack design on 50 and 75gpm (3.2 and 4.7L/sec) models
- Franklin Electric Super Stainless motors are rated for continuous use and frequent cycling, with surge arrestors, hermetically sealed motor housing for moisture-free windings, and Kingsbury-type thrust bearing for thrust absorption
- Thermal overload protection trips at 203-221°F (95-105°C) for 1-phase motors through 1.5hp (1.12kW)
- Type SOOW 600V motor cable (model PF751512 uses 14 AWG, SJ00W, 300V cord)

* Not applicable for 5hp (3.73kW) models

Standard Models

See [Specifications on page 2](#) for a list of standard pumps. For a complete list of available pumps, call Orenco.

Product Code Diagram



Pump, PF-Series

* 1/2hp (0.37kW) only

† Available for 10gpm (0.6L/sec), 1/2hp (0.37kW)

‡ Note: 20ft cords are available only for pumps through 1 1/2hp

Specifications

Pump Model	Design gpm (L/sec)	Horsepower (kW)	Phase	Nameplate voltage	Actual voltage	Design flow amps	Max amps	Discharge size and material ¹	Length in (mm)	Min. liquid level in (mm) ²	Weight lb (kg) ³	Rated cycles per day
PF100511 ⁹	10 (0.6)	0.50 (0.37)	1	115	120	12.7	12.7	1¼in GFP	23.0 (584)	16 (406)	26 (12)	300
PF100511CV ⁹	10 (0.6)	0.50 (0.37)	1	115	120	12.7	12.7	1¼in GFP	23.0 (584)	16 (406)	26 (12)	300
PF100512 ⁹	10 (0.6)	0.50 (0.37)	1	230	240	6.3	6.3	1¼in GFP	23.0 (584)	16 (406)	26 (12)	300
PF100712 ^{4,5,9}	10 (0.6)	0.75 (0.56)	1	230	240	8.3	8.3	1¼in GFP	25.9 (658)	17 (432)	30 (14)	300
PF101012 ^{5,6,9}	10 (0.6)	1.00 (0.75)	1	230	240	9.6	9.6	1¼in GFP	27.9 (709)	18 (457)	33 (15)	100
PF200511 ⁹	20 (1.3)	0.50 (0.37)	1	115	120	12.3	12.5	1¼in GFP	22.3 (566)	18 (457)	25 (11)	300
PF200512 ⁹	20 (1.3)	0.50 (0.37)	1	230	240	6.4	6.5	1¼in GFP	22.5 (572)	18 (457)	26 (12)	300
PF201012 ^{4,5,9}	20 (1.3)	1.00 (0.75)	1	230	240	10.5	10.5	1¼in GFP	28.4 (721)	20 (508)	33 (15)	100
PF201512 ^{4,5}	20 (1.3)	1.50 (1.12)	1	230	240	12.4	12.6	1¼in GFP	34.0 (864)	24 (610)	41 (19)	100
PF300511 ⁹	30 (1.9)	0.50 (0.37)	1	115	120	11.8	11.8	1¼in GFP	21.3 (541)	20 (508)	28 (13)	300
PF300512 ⁹	30 (1.9)	0.50 (0.37)	1	230	240	6.2	6.2	1¼in GFP	21.3 (541)	20 (508)	25 (11)	300
PF300712 ⁹	30 (1.9)	0.75 (0.56)	1	230	240	8.5	8.5	1¼in GFP	24.8 (630)	21 (533)	29 (13)	300
PF301012 ^{4,9}	30 (1.9)	1.00 (0.75)	1	230	240	10.4	10.4	1¼in GFP	27.0 (686)	22 (559)	32 (15)	100
PF301512 ^{4,5}	30 (1.9)	1.50 (1.12)	1	230	240	12.6	12.6	1¼in GFP	32.8 (833)	24 (610)	40 (18)	100
PF302012 ^{5,6,7}	30 (1.9)	2.00 (1.49)	1	230	240	11.0	11.0	1¼in SS	35.5 (902)	26 (660)	44 (20)	100
PF303012 ^{5,6,7,8}	30 (1.9)	3.00 (2.23)	1	230	240	16.8	16.8	1¼in SS	44.5 (1130)	33 (838)	54 (24)	100
PF305012 ^{5,6,7,8}	30 (1.9)	5.00 (3.73)	1	230	240	25.6	25.8	1¼in SS	66.5 (1689)	53 (1346)	82 (37)	100
PF500511 ⁹	50 (3.2)	0.50 (0.37)	1	115	120	12.1	12.1	2in SS	20.3 (516)	24 (610)	27 (12)	300
PF500512 ⁹	50 (3.2)	0.50 (0.37)	1	230	240	6.2	6.2	2in SS	20.3 (516)	24 (610)	27 (12)	300
PF500712 ⁹	50 (3.2)	0.75 (0.56)	1	230	240	8.5	8.5	2in SS	23.7 (602)	25 (635)	31 (14)	300
PF501012 ⁹	50 (3.2)	1.00 (0.75)	1	230	240	10.1	10.1	2in SS	27.0 (686)	26 (660)	35 (16)	100
PF501512 ⁴	50 (3.2)	1.50 (1.12)	1	230	240	12.5	12.6	2in SS	32.5 (826)	30 (762)	41 (19)	100
PF503012 ^{4,5,7,8}	50 (3.2)	3.00 (2.23)	1	230	240	17.7	17.7	2in SS	52.0 (1321)	37 (940)	55 (25)	100
PF505012 ^{5,6,7,8}	50 (3.2)	5.00 (3.73)	1	230	240	26.2	26.4	2in SS	77.0 (1956)	55 (1397)	64 (29)	100
PF751012 ⁹	75 (4.7)	1.00 (0.75)	1	230	240	9.9	10.0	2in SS	27.0 (686)	27 (686)	34 (15)	100
PF751512	75 (4.7)	1.50 (1.12)	1	230	240	12.1	12.3	2in SS	33.4 (848)	30 (762)	44 (20)	100

1. GFP = glass-filled polypropylene; SS = stainless steel. The 1 1/4in NPT GFP discharge is 2 7/8in octagonal across flats; the 1 1/4in NPT SS discharge is 2 1/8in octagonal across flats; and the 2in NPT SS discharge is 2 7/8in hexagonal across flats. Discharge is NPT threaded receptacle-style port, US nominal size, to accommodate Orenco discharge hose and valve assemblies. Consult your Orenco distributor about fittings to connect hose and valve assemblies to metric-sized piping.

2. Minimum liquid level is for single pumps when installed in an Orenco Biotube Pump Vault or Universal Flow Inducer. In other applications, minimum liquid level should be top of pump. Consult Orenco for more information.

3. Weight includes carton and 10ft (3m) cord.

4. High-pressure discharge assembly required.

5. Do not use cam-lock option (Q) on discharge assembly.

6. Custom discharge assembly required for these pumps. Contact Orenco.

7. Capacitor pack (sold separately or installed in a custom control panel) required for this pump. Contact Orenco.

8. Torque locks are available for all pumps, and they are supplied with 3hp and 5hp pumps.

9. ClickTight™ compatible.



Materials of Construction

Discharge	Glass-filled polypropylene or stainless steel
Discharge bearing	Engineered thermoplastic (PEEK)
Diffusers	Glass-filled PPO (SABIC's NORYL™ GFN3 resin)
Impellers	Celanese's Celcon® acetal copolymer on 10, 20, and 30gpm models; 50gpm impellers are NORYL GFN3 resin
Intake screen	Polypropylene
Suction connection	Stainless steel
Drive shaft	7/16in hexagonal stainless steel, 300 series
Coupling	Sintered stainless steel, 300 series
Shell	Stainless steel, 300 series
Motor	Franklin Electric motor filled with deionized water and propylene glycol for constant lubrication. Stainless steel shell.




Using a Pump Curve

A pump curve helps you determine the best pump for your system. Pump curves show the relationship between flow (gpm or L/sec) and pressure (total dynamic head or TDH), providing a graphical representation of a pump's optimal performance range. Pumps perform best at their nominal flow rate – the value, measured in gpm, expressed by the first two numerals in an Orenco pump nomenclature. These graphs use solid lines to show the optimal pump operation range. Dashed lines indicate flow rates outside of the optimal range for each pump. For the most accurate pump specifications, use Orenco's PumpSelect™ software.

Pump Curves



Pump Curves, cont.



<< QUOTE >>



PAGE 1

QUOTE DATE 2023-12-13
QUOTE NO 15485

S
O
L
D

T
O

S
H
I
P

T
O

TOTAL DUE 11,437.37

SLS1	SLS2	DUE DATE	DISC DUE DATE	ORDER NO	ORDER DATE	SHIP DATE	SHIP NO
		2024-01-30	2023-12-13	00192902	2023-12-13		

TERMS DESCRIPTION	CUSTOMER PO NO	SHIP VIA
n/30 EOM	PME	

ITEM ID	TX CL	UNITS	ORDERED	SHIPPED	UNIT PRICE	EXTENSION
19755	0	EA.	1.0000	0.0000	2,325.2400	2,325.24
Orenco PF100511-20 Pump 10gpm 1/2Hp Orenco Effluent Pump 10gpm, 1/2Hp, 115V, 60Hz, 1-Phase, 20' Cord						
PUMP	0	EA	1.0000	0.0000	2,725.5000	2,725.50
Orenco PF100711-20 Pump 10gpm 1/2Hp Orenco Effluent Pump 10gpm, 3/4Hp, 115V, 60Hz, 1-Phase, 20' Cord						
19800RMWB-A	0	EA	1.0000	0.0000	5,841.9900	5,841.99
ProStep Package A ProSTEP Pump Package c/w Hanging Discharge, ClickTight MVP Panel, ClickTight Floats, 10GPM Pump (PF1005), Biotube Pump Vault, etc.						

GST SALES TAX
544.64

TAXABLE	NONTAXABLE	FREIGHT	SALES TAX	FUEL SURCHARGE	TOTAL
10,892.73	0.00	0.00	544.64	0.00	11,437.37
TOTAL DUE					11,437.37

Kim Schurtz

From: Kory Read <KoryR@wilbert.ca>
Sent: December 13, 2023 12:21 PM
To: Ashwin Kumar Kamalesh
Cc: Kim Schurtz
Subject: RE: Huxley Wastewater Study - Pump Quotes
Attachments: QUOTE - PUMPS - PME - 00192902.Pdf

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Hi Ashwin,

Attached you will find a quote for these pumps. I also included the kit, which these pumps are part of. It includes filter, housing, pump, fittings, panel, floats.

Please let me know if you have any questions.

Take care and happy holidays,

Kory Read
Commercial Sales & Marketing
Alberta Wilbert Sales Ltd.
Cell: 587.926.1655
Office: 780.447.2222
Direct Line: 780.732.4302
Web: www.wilbert.ca



From: Ashwin Kumar Kamalesh <akamalesh@mpe.ca>
Sent: December 13, 2023 12:04 PM
To: Kory Read <KoryR@wilbert.ca>
Cc: Kim Schurtz <kschurtz@mpe.ca>
Subject: [EXTERNAL] Huxley Wastewater Study - Pump Quotes

Hi Kory,

I just left you a voicemail asking for a quote for low pressure pumps. I got your contact information from Saadia from the MPE Edmonton office.

We are looking for a quote for PF1005/PF1007 pumps (attached). This is for a low-pressure system that has a 2" and 3" HDPE sewer lines. Please feel free to call me to discuss.

Thanks,

Ashwin Kumar Kamalesh, M.Sc., E.I.T.
Environmental Systems Engineer-in-Training
Tel. (403) 219-6308
Cel. (403) 714-4474
Email. akamalesh@mpe.ca
www.mpe.ca



APPENDIX D

Cost Estimates



a division of Englobe

Hamlet of Huxley - Wastewater Study
CLASS 4 COST ESTIMATE

March 18, 2024

DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	COST
1 Mobilization/Demobilization	1	L.S.	\$ 214,074	\$ 214,074
2 Care of Water	1	L.S.	\$ 30,000	\$ 30,000
3 Erosion and Sediment Control	1	L.S.	\$ 25,000	\$ 25,000
4 Traffic Control, Vehicle Access and Parking	1	L.S.	\$ 40,000	\$ 40,000
5 Decommission Existing Low Pressure Sanitary Collection System	1	L.S.	\$ 50,000	\$ 50,000
6 Truck Haul Sewage from Existing Septic Tanks	1	L.S.	\$ 50,000	\$ 50,000
7 75 mm PVC Sanitary Main	2200	m	\$ 500	\$ 1,100,000
8 Type 5A Manholes	56	V.M.	\$ 2,800	\$ 156,800
9 Road Excavation and Restoration	5676	m ²	\$ 65	\$ 368,940
10 Landscape Restoration	400	m ²	\$ 40	\$ 16,000
11 100 mm Sanitary Service Connection (Provisional)	41	L.S.	\$ 7,000	\$ 287,000
12 Rock Excavation and Drilling (Provisional)	200	m	\$ 85	\$ 17,000
Subtotal				\$ 2,354,814
Contingency (40%)				\$ 941,900
Engineering (15%)				\$ 494,500
TOTAL				\$ 3,790,000

Note: Does not include GST